

Energy Audit Report

(Oct 2022)

King George's Medical University

Uttar Pradesh, Lucknow

(The Reference Contract No. GEMC-511687777294462 dated 03rd Aug 2022.)



Conducted by

Bhagwat Technologies and Energy Conservation Pvt Ltd

New Delhi

Contents

Acknowledgement	5
Introduction	6
KGMU Energy & Environment Consciousness	7
Executive Summary.....	9
Summary of Key Savings Potential.....	10
Scope of Work as per RfP	12
Approach & Methodology	13
Basic Data.....	14
Grid based Electrical Energy and Key Observations	14
Purchased Annual Electricity Cost Comparison of last 03 years.....	14
Evaluation of Unit Cost for Last 03 Years.....	14
Details of Connection.....	15
Existing Solar PV Plants	17
LPG Consumption details.....	20
Diesel Gen Sets and Diesel Consumption	21
Solar Thermal Concentrator.....	22
Electricity Bill Analysis Connection wise	24
NEW MORTUARY DEPARTMENT A/C NO:- 3747481000	24
Account No. 9747481000; C.T.V.S Department; 700218 Registrar, KGMU.....	26
Account No. 8547481000; Hospital Substation; 71595 Registrar , KGMU	28
Account No. 5134370261; New Dental Extension Block ; 703688 Registrar , KGMU	30
Account No. 9547481000; Cobalt substation; 613917 Registrar, KGMU	33
Account No. 1747481000; Psychiatric department ; 00434 Registrar , KGMU	35
Account No. 7547481000; Queen marry Hospital; 30339 Registrar , KGMU	37
Account No. 4540285915; QMH(New 100 Bedded hospital); 4540285915 Registrar , KGMU	39
Account No. 5747481000; Trauma Center; 689414 Registrar , KGMU	41
Account No. 7747481000; Old Mortuary substation; 005699 Registrar , KGMU	43
Account No. 9753334424; Teaching Block(Kalam Center; 703712 Registrar , KGMU.....	45
Account No. 1214770000; Old Dental building(Dental Science University Building , PHI); 678537 Registrar, KGMU	47
Account No. 4697779403; New OPD Block.; 703687 Registrar, KGMU	49
Account No. 4747481000; Cancer unit; 678442 Registrar . KGMU	51
.....	52
Type-5 Faculty building(J.N Road); 7200191928 Registrar , KGMU	53
Account No. 6747481000; Old Dental Building ; 566149 Registrar , KGMU.....	55

Account No. 1133332000; Gautam Buddha Hostel. ; 678569 Registrar , KGMU	57
Account No. 1647481000; Shatabdi Hospital; 678594 Registrar, KGMU	59
Account No. 2747481000; Cardiology Department; 577925 Registrar, KGMU.....	61
Account No. 7077481000; T.G. Hostel; 9202 Registrar , KGMU	63
Account No. 6357245033; T.G. Hostel Residential Type -2; 100057 Registrar , KGMU	65
Account No. 2157481000; RALC Building (Artificial Limb Centre); 86966 Registrar , KGMU	68
Account No. 4042748045; Employees Quarter Type-1; 4042748045 Registrar , KGMU	70
Seasonal Variation	72
Load connected to different meters in the total electricity consumption	74
DG Sets Performance Analysis	76
Power Factor Analysis	82
Connection wise Operating Power Factor	82
Performance of APFC Installed at Various Locations.....	83
Recommendations for Power Factor Improvement	85
Table : PF Improvement Recommendation for New Mortuary Department	85
Table : PF Improvement Recommendation for CTVS Departments	86
Table : PF Improvement Recommendation for New Dental Extension Block	87
Table : PF Improvement Recommendation for Psychiatric Department.....	88
Table : PF Improvement Recommendation for Queen Marry Hospital.....	89
Table : PF Improvement Recommendation for Trauma Center	90
Table : PF Improvement Recommendation for Old Mortuary Substation	91
Table : PF Improvement Recommendation for Techning Block (Kalam Centre)	92
Table : PF Improvement Recommendation for New OPD Block.....	93
Table : PF Improvement Recommendation for Cancer Unit.....	94
Table : PF Improvement Recommendation for Old Dental	95
Table : PF Improvement Recommendation for Gautam Buddha Hospital	96
Table : PF Improvement Recommendation for Shatabdi Hospital	97
Table : PF Improvement Recommendation for T G Hostel	98
Table : PF Improvement Recommendation for T G Hostel Residential Type 2.....	99
Table : PF Improvement Recommendation for Artificial Limb Center(RALC BUILDING)	100
Table : PF Improvement Recommendation for Employees Quarter Type-1	101
Maximum Demand Analysis	102
Transformers Study.....	105
Pumps	115
Recommendations for Pumps replacement with EE Pumps	118

Energy Management System	119
Air Conditioning Systems	120
List of available Window and Split ACs are as below:-	121
Energy Savings Possibilities in Windows and Split ACs.....	123
Other Air-Conditioned Plant Details	124
Chillers Performance Study.....	125
Shatabdi Phase I Hospital.....	125
New OPD	126
New Dental	127
Kalam Center.....	128
CTVS	129
Chilled Water & Condenser Pumps Study.....	130
Cooling Towers Study.....	140
Study of Air Handling Units (AHUs).....	145
AHU of New Dental	147
AHUs of New OPD	148
IoT Based Building Management System for Energy Savings	153
Thermographic Study.....	154
Concentrated Solar Thermal (CST) Systems Performance.....	171
Solar PV Power Plants Potential (Grid Connected).....	175
Application of Heat Reflective Coating	177
Induction Cooking in the Cooking Areas.....	179
District Cooling System	181
Carbon Footprint and Sustainability Practices of the KGMU.....	183
Standard operating practices for efficient use of energy at KGMU.	184

Acknowledgement



Image Source : <https://www.kgmu.org/>

Bhagwat Technologies and Energy Conservation Pvt Limited (BTECON) is sincerely thankful to the King George's Medical University (KGMU), Uttar Pradesh, Lucknow and Uttar Pradesh New & Renewable Energy Development (UPNEDA) for entrusting this prestigious assignment to undertake the Energy Audit of the KGMU campus.

BTECON is thankful to all the officials of KGMU and UPNEDA who were part of this study for their continuous support. The particular key officials of the Energy Audit team to mention here are as below :-

KGMU Team :-

1. Dr. Kirti Srivastava, Professor Department of Radiotherapy, Member Secretary Environment Committee and Head of the University Environment Department
2. Er.Virendra Kumar Yadav, AE, PWD, Energy Audit Project In-charge, KGMU
3. Er. Birendra Kumar Dubey, JE, PWD, Electrical
4. Er. Sunil Kumar Kushwaha, JE, PWD, Mechanical
5. Er.Satya Prakash Pandey, JE, PWD, Electrical- Outsource
6. Er.Umesh Chandra Yadav, JE, PWD, Mechanical
7. Er.Dinesh Kumar, JE, PWD, Electronics
8. Er.Babloo Singh, JE, PWD, Mechanical

UPNEDA Team :-

1. Sh. Ashok Kumar Srivastava, In charge UPSDA, UPNEDA, Uttar Pradesh
2. Sh. Girish Kumar, Senior Energy Consultant, BEE Cell, SDA, Uttar Pradesh

Introduction

India at the 26th session of the Conference of the Parties (COP26) to the United Nations Framework Convention on Climate Change (UNFCCC) held in Glasgow, United Kingdom, expressed to intensify its climate action by presenting to the world five nectar elements (Panchamrit) of India's climate action. The Union Cabinet chaired by the Prime Minister Shri Narendra Modi, has approved India's updated Nationally Determined Contribution (NDC) to be communicated to the United Nations Framework Convention on Climate Change (UNFCCC). As per the updated NDC, India now stands committed to reduce Emissions Intensity of its GDP by 45 percent by 2030, from 2005 level and achieve about 50 percent cumulative electric power installed capacity from non-fossil fuel-based energy resources by 2030. This update to India's existing NDC translates the 'Panchamrit' announced at COP 26 into enhanced climate targets. The update is also a step towards achieving India's long term goal of reaching net-zero by 2070.

King George Medical University (KGMU) is already introduced a number of Energy Efficiency (EE) (which is also called the first fuel of savings energy) and Renewable Energy (RE) measures and committed to further introduce similar measures which will surely be a contribution towards meeting the state as well as nation's commitment towards Climate Change.

An Energy Audit of the KGMU campus has been envisaged through a tripartite agreement between the KGMU, Uttar Pradesh New & Renewable Energy Development Agency (UPNEDA) and Bhagwat Technologies & Energy Conservation Pvt Ltd (BTECON).

The Energy Conservation Act, 2001 defines Energy Audit as "the verification, monitoring and analysis of use of energy including submission of technical report containing recommendations for improving energy efficiency with cost benefit analysis and an action plan to reduce energy consumption".

An energy audit is usually conducted to understand how energy is used and to find opportunities for improvement and energy saving through implementing possible EE and RE measures. With this key objective Energy Audit was planned in the KGMU. The Energy Audit will also comply the Criteria VII (Institutional Values & Best Practices) of National Assessment and Accreditation Council (NAAC).

King George Medical University (KGMU), Lucknow is more than 100 years old. The university campus is spread over an area of roughly 100,000 sq meters. Presently the total connected load of all the buildings including hostels etc. is 13060.77 KVA as per the Electricity Bills information.

Non-Conventional Energy Development Agency, U.P. (NEDA) was set up in 1983 as a registered society under the Department of Additional Sources of Energy, Govt. of U.P. The Agency has inter-Alia following functions:-

- Propagation of the concept of renewable sources of energy and energy conservation.
- Promoting the use of renewable energy systems and means of saving energy in various sectors.
- Research and development primarily of applied nature in the field of renewable sources of energy and energy conservation.

The agency is working in the field of Solar Energy, Wind Energy, Bio Energy, Micro Hydel and Energy Conservation besides energy planning and other aspects of energy management.

Bhagwat Technologies & Energy Conservation Pvt. Ltd. (BTECON) has been entrusted to undertake the Energy Audit service in KGMU. The Company was incorporated in the year 2002 as a Private Limited Company with registered and principal offices in Delhi. It is empanelled with UPNEDA.

KGMU Energy & Environment Consciousness

The KGMU is highly conscious regarding the energy consumption within the campus. This is testimony to the fact that it has executed a number of energy efficiency as well as renewable energy projects to reduce the energy consumption as well as dependency on the fossil fuel based energy sources. The earlier energy audit study was executed in the year 2015.

Some of the energy conservation and renewable energy measures as were executed: -

- Replacement of 250 W sodium lights with 120 W LED lights. Around 600 such LED lights were installed for the indoor areas of the hospital, replacing the old 150 lights and addition of remaining 450 new lights. There was also replace 12 High-mast lights of 850 W with those of 250 W lights, in the outdoor areas.
- installation of APFC panels for Power Factor improvement and thereby KVAh Consumption reduction
- use of Concentrated Solar Thermal system to provide steam for the cooking in lieu of LPG

Concentrated Solar system is installed to provide steam for the cooking suitable for cooking 3000 meals per session. A Total 30 numbers Parabola are installed in the year 2017 on the rooftop of the Shatabdi Phase-II Buildings.



Fig. Part of the Solar Concentrator Thermal System

- installation of Rooftop Solar PV power plants of 1370 kW

A Total 400 kW capacity Grid Connected Solar PV Projects comprising of 08 (Eight) sites (Kalam Center , 70 kW; Urology Department, 40 kW; Padiatric Department, 50 kW; Respiratory Medicine Department, 50 kW; General Surgery Department, 50 kW; Neurology Department, 40 kW, PRO Office, 50 kW and Medicine Board, 50 kW) was installed with the help of UPNEDA along with 970 kW capacity of Solar PV Projects comprising of 15(Fifteen) sites (Manshik Department, 50 kW; Old Age Manshik Department, 100 kW; Pathology Department, 100 kW; Trauma Center, 100 kW; Library, 30 kW; Old OPD, 50 kW; Shatabdi Hospital, Phase-I, 80 kW; Private Board, 50 kW; Plastic Surgery, 100 kW; Netro(Eye) Department, 50 kW; Prashuti Ebong Shtree Rog Department, 50 kW; Rheumatology Department, 50 kW; Physiology & Biochemistry Department, 60 kW; Cardiology Department , 50 kW and Pediatric Oncology Department, 50 kW) with the help of U.P.R.N.N. Unit -10.



Fig . Google Earth View of the Solar PV Panels Installed on various buildings within KGMU Campus


KGMU is also continuously looking for attaining further savings through taking energy efficiency and renewable energy measures



Fig. Solar Plants visited during the Energy Audit Study (Neurology Department)

Executive Summary

1. KGMU is very much energy conscious and has already undertaken a number of energy efficient and renewable energy measures ; It uses Solar PV power plant and Solar Thermal Concentrator . It has also implemented energy efficient lights and APFC panels for energy conservation
2. The Hospital uses different form of conventional energy like electricity , LPG and Diesel
3. As a part of the study , Basic Data for various energy sources , carbon footprint, potential of white reflective coating , performance of the solar thermal concentrator system, potential of installing induction cooking , potential of solar PV system and analysis of the performance of the existing system, performance of HVAC systems , potential and feasibility for district cooling system , standard operating practices for efficient use of energy , etc. have been studied
4. An increasing trend of electricity consumption in the period 2021-22 in comparison to 2020-21 is observed
5. A total 23 meters connection are studied
6. Electricity consumption of different meters in the total consumption of Hospital during April 2021 to March 2022 :-



7. The Hospital carbon footprint (t CO₂-e) has been estimated 21544 which can be used as a benchmark for future energy conservation and sustainability strategy

Summary of Key Savings Potential

SN	Particulars	Tentative Energy Savings	Tentative Annual Monetary Savings, Lakhs	Tentative Investment, Lakhs	Tentative Payback Period (Months)
1	Based on our preliminary assessment another 27 Rooftops can be used for more Solar PV Power generation with a potential of 2135 kWp	2991800 kWh	403	747	22
2	Unused Steam of the Concentrated Solar Thermal (CST) can be used for other application like steam sterilizers	129600 kWh	17.5	1.5	Immediate
3	Application of Heat Reflective Coating	reduce the building cooling energy need		Rs.35/- per sq ft	as per application
4	BLDC fans of 30 W per fan in lieu of 70-80 W per fan (Fiber body) and 100 W (Metallic Body) of the traditional fans. The Hospital is using around 10000 traditional fans.	1620000 kWh	218.7	200.0	11
5	Occupancy /Motion sensor based automatic Lighting on and off in the areas like offices & Lobby areas	50% savings potential		Rs.09/- per sq ft	NA
6	PF Improvement Recommendation for New Mortuary Department	145564 kVAh	10	10.5	12
7	PF Improvement Recommendation for CTVS Department	335236 kVAh	24	12	6
8	PF Improvement Recommendation for New Dental Extension Block	116225 kVAh	8	14	20
9	PF Improvement Recommendation for Psychiatric Department	62154 kVAh	4	5.5	15
10	PF Improvement Recommendation for Queen Marry Hospital	126697 kVAh	9	2.8	4
11	PF Improvement Recommendation for Trauma Center	401286 kVAh	28	11	5
12	PF Improvement Recommendation for Old Mortuary Substation	324012 kVAh	23	16.8	9
13	PF Improvement Recommendation for Teaching Block (Kalam Center)	2268812 kVAh	161	41.9	3
14	PF Improvement Recommendation for New OPD Block	76782 kVAh	5	10.5	23
15	PF Improvement Recommendation for Cancer Unit	15503 kVAh	1	1.5	16
16	PF Improvement Recommendation for Old Dental	240138 kVAh	17	10.5	7
17	PF Improvement Recommendation for Gautam Buddha Hospital	140325 kVAh	10	5	6
18	PF Improvement Recommendation for Shatabdi Hospital	951739 kVAh	68	23.5	4
19	PF Improvement Recommendation for TG Hostel	79768 kVAh	6	5	11

20	PF Improvement Recommendation for TG Hostel Residential Type 2	207657 kVAh	15	4	3
21	PF Improvement Recommendation for ARTIFICIAL LIMB CENTER (RALC BUILDING)	105723 kVAh	8	5.3	8
22	PF Improvement Recommendation for Employees Quarter Type-1	223744 kVAh	16	2.5	2
23	MD Penalty can be avoided through Right load and Contract demand planning	Around 33 Lakhs MD penalty paid from April 2021 to March 2022		As per the Planning	Immediate
24	Pumps Replacement with EE Pumps	55572 kWh	7.56	1.5	2.4
25	Energy Management System including grid and solar pv power for informed decisions	indirect savings		1150000	NA
26	Energy Savings in Window and Split ACs replacing with higher Star rated ACs	767700 kWh	103.6	Replacement as and when requirement basis	
27	AHU Filters is found dirty and affecting the plants performance; the cleaning of the filters is suggested on regular basis	Energy Consumption increases in absence of proper maintenance practices			
28	Induction Cooking in the cooking areas	The commercial scale Induction cooking can be piloted in a particular cooking area which makes meals and the decision can be taken based on that experience.			

Scope of Work as per RfP

- Collection of Basic Data for various energy sources being used in the university.
- Identification of Energy Consuming areas and Measurements & quantification
- Data analysis
- Identification of energy conservation & renewable energy potential
- Capital investments and payback period.
- Calculation of carbon footprint
- To check temperature of wiring and electric joints at key locations through thermographic imager.
- Measurement of the temperature of roof of top floors inside (inner surface of the roof) as well as outside (outer surface of the roof where sunshine is falling) & Identification of savings potential
- To check the performance of the Solar Thermal Concentrator system
- To identify feasibility and potential of installing induction cooking in the cooking areas
- Action plan formulation for implementing Energy efficiency Measures.
- To identify potential of solar PV system (Grid connected solar roof top plants) and analysing the performance of the existing system (check RfP)
- To check performance of HVAC systems
- To identify potential and feasibility for district cooling system covering all the buildings of KGMU.
- To prepare standard operating practices for efficient use of energy at KGMU.
- To create energy conservation awareness among the end users.
- Any other work deemed appropriate by the agency or advised by KGMU/UPNEDA during the study, which can add value to the assignment.

Approach & Methodology

The Tender “Energy Audit of King George Medical University (KGMU), Lucknow” was issued by Uttar Pradesh New and Renewable Energy Development Agency (UPNEDA) with Uttar Pradesh State Designated Agency (UPSDA) in the GEM (Government e Marketplace) Portal.

The UPNEDA empaneled agencies were allowed to participate and Bhagwat Technologies and Energy Conservation Pvt Limited (BTECON) got selected and awarded the assignment.



Fig. Image : BTECON Team Measurements

The University campus is spread over an area of roughly 100,000 sq meters and the total connected load of all the buildings including hostels etc. is 13060.77 KVA. The Energy Audit was started with a kick-off meeting at the UPNEDA H.Q. in Lucknow, Uttar Pradesh on 08th Aug 2022 and tripartite contract in between UPNEDA, KGMU and Energy Audit Agency, BTECON was undertaken. The same day a Walkthrough Audit was organized for the Energy Audit Team and the meeting was organized amongst the key University Professors and representatives. The Energy Audit work on-site was started on 16th Aug 2022 following the below timeline as the same was submitted with the tender application by the Auditing agency: -

Sr.No.	Task	Time Duration								
		W-1	W-2	W-3	W-4	W-5	W-6	W-7	W-8	Next 15 days
1	Kick-off Meeting with UPNEDA,SDA / Building Owner Representatives									
2	Sites visit and discussions with the Building Authorities									
3	Sites data collection and measurements									
4	Draft Energy Audit Report for Comments & Suggestions									
5	Final Energy Audit Report after incorporating the Suggestions									

Note : W stands for Week ; Total duration considered for the site study is 45 days; Draft report submission within 60 days and

The experienced team of the company got involved into the study to undertake the survey, measurements and discussion with the key officials. The instruments such as Ultrasonic Flow Meter, Three Phase Power Analyzers, Single Phase Power Analyzers, Data Loggers, Lux Meters, Thermal instruments, etc. duly calibrated were used for carrying out energy audits.


The on-site Energy Audit work as per the scope was started in parallel in 03 (Three) key areas such as Data Collection from various departments, various measurements and renewable energy related activities. In parallel to all these , the back office data entry as a part of the analysis for reporting was also started. The time was the essence of the project and that was the key reason for such an initiatives.

The Draft Energy Audit report was submitted within a month of the Zero date of the project and the recommendations were incorporated into the final report. Along with the Final report submission an awareness program was also initiated by the Auditing agency.


Basic Data

Grid based Electrical Energy and Key Observations

Purchased Annual Electricity Cost Comparison of last 03 years



Evaluation of Unit Cost for Last 03 Years



Details of Connection

The Details of Connection is mentioned below. The sanctioned load data is as per the Electricity Bills

SN	Department/Place	Connection No	Account No	Date of Connection	Tariff Type	Sanctioned Load (kVA)	Name of the Buildings
1	New Mortuary substation	678528	374748 1000	1/1/200 1	HV-I	223	Sardar Patel Hostel/Resident Hostel, Physiology Dept, Bio Chemistry dept, SPM Dept
2	C.T.V.S Department	700218	974748 1000	8/4/201 1	HV-I	445	Complete CTVS Dept
3	Hospital Substation	71595	854748 1000	1/1/200 1	HV-I	1137	Radiotherapy dept, Radio diagnosis dept, Main hospital Building, Old OPD, Pharmacology Dept, Old Neurology Building, Plastic surgery dept, Medicine ward & M.R.I, , C.T Scan, Ophthalmic dept all surgical wards.
4	New Dental Extension Block	703688	513437 0261	28/11/2 012	HV-I	737	Complete new dental Extension building
5	Cobalt substation	613917	954748 1000	1/1/200 1	HV-I	659	Medicine dept, Plastic surgery dept, surgery dept, I.D.H. building, Old neurology, Pediatric dept, Old CV hostel etc
6	Psychiatric department	00434	174748 1000	1/1/200 1	HV-I	158	Psychiatric dept, Trauma emergency room, holding screening area & Geriatric mental health dept.
7	Queen Marry Hospital	30339	754748 1000	1/1/200 1	HV-I	411	Complete Queen marry Hospital & Old LRH and NCR hostel.
8	QMH (New 100 Bed hospital)	454028 5915	454028 5915	27/04/2 019	HV-I	333.33	Complete 100 Bed Hospital (QMH)
9	Trauma Center	689414	574748 1000	1/1/200 4	HV-I	540	Trauma Center (Ground floor to 3rd Floor)

10	Old Mortuary substation	005699	774748 1000	1/1/200 1	HV-I	1087	Pathology dept, Microbiology dept, New old VL Girls Hostel, DK Hostel, VC Office, Pediatric dept, forensic medicine dept etc.
11	Teaching Block (Kalam Center)	703712	975333 4424	15/12/2 014		2632	Complete Teaching Block, Hostel etc
12	Old Dental building (Dental Science University Building, PHI)	678537	121477 0000	15/07/2 005	HV-I	45	Complete old dental faculty building
13	New OPD Block.	703687	469777 9403	25/11/2 012	HV-I	698	Complete New OPD building
14	Cancer unit	678442	474748 1000	1/1/200 1	HV-I	112	Complete Cancer Unit (QMH)
15	Type-5 Faculty building (J.N Road)	720019 1928	720019 1928	16/02/2 005	LMV-I	444.44	Complete Faculty building A Block & B Block
16	Old Dental Building	566149	674748 1000	1/1/200 3	HV-I	445	Complete Old dental faculty building
17	Gautam Buddha Hostel.	678569	113333 2000	23/05/2 008	HV-I	667	Complete Gautam buddha Hostel block
18	Shatabdi Hospital.	678594	164748 1000	29/04/2 008	HV-I	1334	Shatabdi Hospital Phase-1 , New Rain Basera , V.C Residence
19	Cardiology Department	577925	274748 1000	1/1/200 1	HV-I	223	Complete Cardiology Department
20	T.G. Hostel	9202	707748 1000	1/1/200 1	HV-I	198	Faculty & employees Residence
21	T.G. Hostel Residential Type -2	100057	635724 5033	15/12/2 014	LMV-I	334	Nurses Hostel.
22	RALC Building (Artificial Limb Centre)	86966	215748 1000	1/1/200 1	HV-I	334	Old Orthopedic, DPMR, Rheumatology (Proposed Covid-19 Hospital)
23	Employees Quarter Type-1	404274 8045	404274 8045	16/02/2 015	LMV-I	78	Type-1 Employees Quarter Near RALC
Total						13274.77	

Existing Solar PV Plants

The KGMU Hospital campus has a total 1370 kW capacity of Grid Connected Solar Rooftop Project.

A Total 400 kW capacity Grid Connected Solar PV Projects comprising of 08 (Eight) sites was installed with the help of UPNEDA: -

- I. Kalam Center, 70 kW
- II. Urology Department, 40 kW
- III. Padiatric Department, 50 kW
- IV. Respiratory Medicine Department, 50 kW
- V. General Surgery Department, 50 kW
- VI. Neurology Department, 40 kW,
- VII. PRO Office, 50 kW and
- VIII. Medicine Board, 50 kW









Another 970 kW capacity of Solar PV Projects comprising of 15(Fifteen) sites are installed with the help of U.P.R.N.N. Unit -10 :-

- I. Manshik Department, 50 kW
- II. Old Age Manshik Department, 100 kW
- III. Pathology Department, 100 kW
- IV. Trauma Center, 100 kW
- V. Library, 30 kW
- VI. Old OPD, 50 kW
- VII. Shatabdi Hospital, Phase-I, 80 kW;
- VIII. Private Board, 50 kW
- IX. Plastic Surgery, 100 kW
- X. Netro(Eye) Department, 50 kW;
- XI. Prashuti Ebong Shtree Rog Department, 50 kW;
- XII. Rheumatology Department, 50 kW;
- XIII. Physiology & Biochemistry Department, 60 kW;
- XIV. Cardiology Department, 50 kW and
- XV. Pediatric Oncology Department, 50 kW)

Key Notes :-

- I. The Solar PV Plants of total 1370 kW capacity is producing 5000 units electricity per day, consequently, the saving of Rupees 17 Lac per month (Ref. KGMU Data)
- II. The joint Survey of KGMU and UPNEDA is going on to find the suitable places to install more Solar power plants under the NEDA (Subah) Project (Ref. KGMU Data)
- III. No Net Metering is in practice at this moment ; the Solar PV Plants are only replacing the Grid Power based on its generation quantity .
- IV. Monkey Menace is existing
- V. Better Maintenance is a must for better generation and extended life of the systems
- VI. The Energy Audit team did physical survey of some sites and had the below observations:-

	<p>Remote Monitoring Units are existing ; monitoring through online link on regular basis will help in better plants monitoring and performance</p>
	<p>Panels regular cleaning is necessary for better generation</p>
	<p>Loose cables touching ground; should have proper cable dressing through the conduits so that monkey menace is avoided. Also, it helps to avoid plants outages.</p>

	<p>Regular Inspection reduces the chances of having non-connected arrays and generation loss</p>
	<p>Damage Solar Panels are to be replaced for better generation and life of the Plant</p>
	<p>Damage Solar Panels are to be replaced for better generation and life of the Plant</p>

LPG Consumption details

S. No.	Name of Fooding Facility	Landmark	LPG Consumption Details		
			Number of cylinders per day (Approx.)	Annul LPG Cylenders (Approx.)	Total kg's (Commercial cylinder @ 19kg)
1	M/S Mohini Caters Center	Near MRI	2	720	13680
2	C V Hall Mess	C.V. Hall	2	720	13680
3	Annapurna Kitchen	Power Grid Sadan-Rain Basera	1	365	6935
4	M/S Brijesh Singh	Shatabdi Phase-I	2	720	13680
5	Patient Diet Kitchen (Central Kitchen) of M/s Jaiswal Canteen	Shatabdi Phase- II	1.5	540	10260
6	Kitchen 1905	Trama Center Building	1.5	540	10260
7	Nitin Kapoor Cafeteria	Central Library Building	2	730	13870
8	Roti Making Facility	Above 1905 Kitchen	8	2880	54720
9	Rajendra Kumar	Registrar Office	0.5	180	3420
10	Shri Mohammed Nadeem	Canteen New OPD	1	360	6840
11	Shri Mohammed Amir	Canteen, Lari Cardiology	1	360	6840
12	M/s Chai Canteen	Queen Merry Hospital	0.6	216	4104
Total				8331	158289

Diesel Gen Sets and Diesel Consumption

Sr.N.	Location of DG sets	KVA	Make	Number of DG	Annual Diesel Consumption during April 2021 to March 2022(Litre)
1	RALC Campus, DPMR Dept., Orthopedic Dept., Rheumatology DG	250 KVA	Greaves	2	40610
		100 KVA	Kirloskar	1	
		500 KVA	Supernova	1	
2	Gandhi Ward	320 KVA	Cummins	2	
		60 KVA	Kirloskar	1	
3	PRO Office	500 KVA	Cummins	1	
		320 KVA	Cummins	3	
4	New Dental Dept. Old Dental Dept.	320 KVA	Cummins	1	
		125 KVA	Kirloskar	1	
		61 KVA	Kirloskar	2	
5	Geriatric Mental Dept., Mental Dept., Adolescent Psychic	100 KVA	Kirloskar	2	
		62.5 KVA	Cummins	1	
		125 KVA	Jackson	1	
6	Trauma Center	250 KVA	Cummins	3	
		125 KVA	Cummins	1	
7	CTVS Dept.	320 KVA	Kirloskar	1	
		125 KVA	Kirloskar	1	
8	Queen Mary Dept.	250 KVA	Greaves	1	
		250 KVA	Cummins	1	
		125 KVA	Kirloskar	2	
9	Microbiology, Virology TV Lab	250 KVA	Cummins	2	
		250 KVA	Kirloskar	1	
		125 KVA	Cummins	1	
10	Pathology Dept.	200 KVA	Greaves	1	
		45 KVA	Kirloskar	1	
11	PHI Bhawan	62.5 KVA	Kirloskar	1	
12	Library & Administrative Building, RH hostel, Marchery, New guest house, Nehru hostel.	200 KVA	Cummins	1	
		20 KVA	Kirloskar	1	
		50 KVA	Cummins	1	
		45 KVA	Kirloskar	1	
		7.5 KVA	Kirloskar	1	
13	TG Hostel	125 KVA	Kirloskar	1	
		125 KVA	Kirloskar	1	
14	Shatabdi Phase-1	500 KVA	Kirloskar	1	
		500 KVA	Cummins	1	
		10 KVA	Kirloskar	1	
15	Shatabdi Phase-2	500 KVA	Cummins	3	
16	Lary Cardiology	250 KVA	Greaves	2	
		125 KVA	Cummins	1	
17	New OPD	250 KVA	Cummins	2	
18	SPM Dept.	62.5 KVA	Kirloskar	1	
19	Faculty Accommodation	62.5 KVA	Greaves	2	
20	IT Cell	30 KVA	Kirloskar	1	
21	Kalam Center	320 KVA	Cummins	2	
22	Advance Research	45 KVA	Kirloskar	1	
		15 KVA	Kirloskar	1	
23	Burn Unit Plastic Surgery Dept.	250 KVA	Kirloskar	1	

Solar Thermal Concentrator

Solar Steam Cooking System for Steam Cooking Application

The Solar Steam Cooking System suitable for cooking 3000 meals per session was supplied, installed and Commissioned by M/S. Taylormade Renewables Ltd Ahmedabad and was handed over on 10/06/2017 with the support of UPNEDA and MNRE. The system is installed on the rooftop of the Shatabdi Phase-II Buildings with the below components: -



S.No .	Particulars/ Item Description	Quantity
1	Parabola / Dish - Area 16 sq. M. each	30 Nos
2	Receiver	30 Nos
3	Rotating Support	30 Nos
4	Stands	30 Nos
5	Foundation Cross	30 Nos
6	Bearing Plate	30 Nos
7	Steam Header	04 Nos
8	Solar Grade Mirrors	30 Nos
9	Valves & Fittings(steam side)	01 unit
10	Valves and Controls	01 unit
11	Tracking Mechanism , Gear box , wire rope & counter weight	04 Set
12	Control panel for Automatic Tracking of Sun	04 Nos
13	Cooking vessels - Indirect type - 350 litres	02 Nos
14	Cooking vessels - Direct type - 500 litres	04 Nos
15	PR V station	01 No
16	Sim based Data Logger for Online performance monitoring	01 No
17	Steam Flow Meter	01 No
18	Pressure Transmitter	01 No
19	Temperature Transmitter	03 Nos
20	Pressure Gauge	06 Nos
21	Insulated pipeline in meters	Up to Kitchen and Vessels

Designed Information

1. Heat Required for Application in the form of steam 8.40 Lac k Cal per day
2. Required Temperature and Pressure of useful Heat : Temp 140 Deg C and 3 Bar Pressure
3. Present Fuel Consumption is 12 LPG Cylinders per day that is 4380 LPG cylinders per year
4. The system was installed at the KGMU, Lucknow Hospital for 3000 meals per session usages



Expected Outcome




5. Expected Outcome is Average Heat Delivery per day : 8.15 Lac kCal
6. Fuel Savings with prevailing fuel /LPG per day : 14.4 LPG Cylinders per day or 4032 LPG Cylinders per year @ 280 sunny days

Electricity Bill Analysis Connection wise

NEW MORTUARY DEPARTMENT A/C NO:- 3747481000



Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	223	523	206466	196944	0.95	1630581.40	198724.80	154295.69	227869.60	2211471	10.7
May-21	223	551	184758	176586	0.96	1459088.20	209258.40	143803.76	249036.80	2061187	11.16
Jun-21	223	648	228078	219432	0.96	1801316.20	246057.60	177750.00	322635.20	2547759	11.17
Jul-21	223	650	188640	174942	0.93	1506402.00	63555.00	115602.00	0.00	1685559	8.94
Aug-21	223	664	71348	67425	0.95	553147.62	252213.80	88273.13	334947.20	1228582	17.22
Sep-21	223	620	301564	290547	0.96	2381857.18	235660.80	218951.97	301841.60	3138312	10.41
Oct-21	223	338	12186	9474	0.78	95769.40	128592.00	23404.91	87704.00	335470	27.53
Nov-21	223	6	3120	1236	0.40	24148.00	63555.00	6577.73	0.00	94281	30.22
Dec-21	223	7	4128	1572	0.38	32111.20	63555.00	7174.97	0.00	102841	24.91
Jan-22	223	505	20609	18726	0.91	162314.26	192021.60	42667.43	214563.20	611566	29.67
Feb-22	223	56	53604	49128	0.92	422976.34	63555.00	36489.85	0.00	523021	9.76
Mar-22	223	350	166698	159102	0.95	1296948.00	176928.00	125829.00	184776.00	1784481	10.70










Account No. 9747481000; C.T.V.S Department; 700218 Registrar, KGMU

Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	445	447	102805	84175	0.82	811659.50	169708.00	73693.76	1216.00	1056277	10.3
May-21	445	430	98955	81540	0.82	781224.50	163400.00	70848.34	0.00	1015473	10.3
Jun-21	445	490	135345	115550	0.85	1068725.50	186124.00	96667.31	34048.00	1385565	10.2
Jul-21	445	476	248230	211545	0.85	1960517.00	180804.00	162354.68	23408.00	2327084	9.4
Aug-21	445	476	151820	126535	0.83	1197298.00	160804.00	105113.25	23408.00	1486623	9.8
Sep-21	445	440	142170	119535	0.84	971193.00	180633.00	99476.00	180633.00	1431935	10.1
Oct-21	445	429	161660	153960	0.95	1276614.00	163058.00	107975.40	0.00	1547647	9.6
Nov-21	445	326	62265	56390	0.91	491393.50	126825.00	46366.39	0.00	664585	10.7
Dec-21	445	272	65845	59425	0.90	519675.50	126825.00	48487.54	0.00	694988	10.6
Jan-22	445	241	55950	51815	0.93	441505.00	126825.00	42624.75	0.00	610955	10.9
Feb-22	445	286	61470	55830	0.91	485113.00	126825.00	45895.35	0.00	657833	10.7
Mar-22	445	300	65610	55115	0.84	724812.00	165585.00	512055.00	0.00	1402452	21.4







Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	1137	600	137578	124140	0.90	792993.0	204379.0	102092.0	70558.0	1170022	8.5
May-21	1137	628	168918	163302	0.97	1333952.20	324045.00	124349.79	0.00	1782347	10.6
Jun-21	1137	628	228060	220782	0.97	1801174.00	324945.60	159458.97	0.00	2285579	10.0
Jul-21	1137	855	228060	220782	0.97	1801174.00	324945.60	159458.97	0.00	2285579	10.0
Aug-21	1137	953	206670	199716	0.97	1632193.0	361972.8	149562.4	0.00	2143728	10.4
Sep-21	1137	836	253362	251592	0.99	2001059.80	324045.00	174382.86	0.00	2499488	9.9
Oct-21	1137	500	207970	201360	0.97	1727992.0	254047.0	146896.0	0.00	2128935	10.2
Nov-21	1137	345	90378	89892	0.99	713486.20	324045.00	77814.84	0.00	1115346	12.3
Dec-21	1137	414	142416	139968	0.98	1124586.40	324045.00	108647.36	0.00	1557279	10.9
Jan-22	1137	534	168270	165804	0.99	1328833.00	324045.00	123965.85	0.00	1776844	10.6
Feb-22	1137	505	128358	125622	0.98	1013528.20	324045.00	100317.99	0.00	1437891	11.2
Mar-22	1137	500	92724	91304	0.98	702152.0	324540.0	89205.0	0.0	1115897	12.0




Monthly Electricity Consumption, kWh



Monthly Electricity Bill, Rs.






Monthly Electricity Bill, MD





Account No. 5134370261; New Dental Extension Block ; 703688 Registrar , KGMU



Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	737	163	33710	31660	0.94	265809.00	210045.00	35689.05	0.00	511543	15.2
May-21	737	567	60230	54640	0.91	475317.00	215460.00	51808.28	0.00	742585	12.3
Jun-21	737	620	44570	40880	0.92	351603.00	235562.00	44037.38	0.00	631202	14.2
Jul-21	737	653	157630	144530	0.92	1244777.00	248216.00	111974.48	0.00	1604967	10.2
Aug-21	737	664	83910	76830	0.92	662389.00	262206.00	68594.83	0.00	993190	11.8
Sep-21	737	600	75780	62090	0.82	905802.00	226138.00	61823.00	0.00	1193763	15.8
Oct-21	737	531	91540	84350	0.92	722666.00	210045.00	69953.33	0.00	1002664	11.0
Nov-21	737	373	21500	20190	0.94	169350.00	210045.00	28454.63	0.00	407850	19.0
Dec-21	737	132	27410	25900	0.94	216039.00	210045.00	31956.30	0.00	458040	16.7
Jan-22	737	192	34890	33660	0.96	275131.00	210045.00	36388.20	0.00	521564	14.9
Feb-22	737	177	31320	28490	0.91	246928.00	210045.00	34272.98	0.00	491246	15.7
Mar-22	737	150	33620	31490	0.94	510779.00	210045.00	35635.00	0.00	756459	22.5















Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	659	456	144347	143879	1.00	1174038.54	187815.00	102138.87	0.00	1463992	10.1
May-21	659	429	180803	180380	1.00	1470679.01	187815.00	124387.05	0.00	1782881	9.9
Jun-21	659	523	196463	196004	1.00	1598104.43	202714.80	135061.44	0.00	1935881	9.9
Jul-21	659	620	179190	178544	1.00	1457602.85	243412.80	127576.17	0.00	1828592	10.2
Aug-21	659	628	179196	178548	1.00	1457602.85	243412.80	243412.80	0.00	1944428	10.9
Sep-21	659	580	200420	199473	1.00	1973197.00	194188.00	136837.00	0.00	2304222	11.5
Oct-21	659	549	194582	193903	1.00	1582798.73	212792.40	134669.33	0.00	1930260	9.9
Nov-21	659	264	102091	101464	0.99	830199.47	187815.00	76351.09	0.00	1094366	10.7
Dec-21	659	318	124290	123771	1.00	1010832.73	187815.00	89898.58	0.00	1288546	10.4
Jan-22	659	400	156472	156217	1.00	1272697.66	187815.00	109538.45	0.00	1570051	10.0
Feb-22	659	371	98037	97069	0.99	797212.07	187815.00	73877.03	0.00	1058904	10.8
Mar-22	659	350	116379	115776	0.99	950110.00	187815.00	85071.00	0.00	1222996	10.5










Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	158	54	6072	5368	0.88	5545.00	43035.00	6788.00	0.00	55368	9.12
May-21	158	54	13618	11760	0.86	107082.20	45030.00	11408.42	0.00	163521	12.01
Jun-21	158	54	13618	11760	0.86	107082.20	45030.00	11408.42	0.00	163521	12.01
Jul-21	158	60	52300	49136	0.94	371434.00	45030.00	34328.00	0.00	450792	8.62
Aug-21	158	88	12362	9836	0.80	97159.80	45030.00	10664.24	0.00	152854	12.36
Sep-21	158	100	44290	41164	0.93	355181.00	45030.00	29581.00	0.00	429792	9.70
Oct-21	158	211	12708	9414	0.74	99893.20	80073.60	16502.55	40067.20	236537	18.61
Nov-21	158	30	9220	5592	0.61	72338.00	45030.00	8802.60	0.00	126171	13.68
Dec-21	158	36	12548	8286	0.66	98629.20	45030.00	10774.44	0.00	154434	12.31
Jan-22	158	42	14310	10046	0.70	112549.00	45030.00	11818.43	0.00	169397	11.84
Feb-22	158	211	10942	7084	0.65	85941.80	80316.80	15510.92	40553.60	222323	20.32
Mar-22	158	200	5078	3604	0.71	40441.00	45030.00	3649.00	0.00	89120	17.55







Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	411	237	84306	76638	0.91	685482.92	117135.00	60196.34	0.00	862814	10.2
May-21	411	204	89976	82032	0.91	731619.71	117135.00	63656.60	0.00	912411	10.1
Jun-21	411	250	125640	116334	0.93	1345139.00	126209.00	86102.00	0.00	1557450	12.4
Jul-21	411	287	107784	99366	0.92	876523.41	117135.00	74524.38	0.00	1068183	9.9
Aug-21	411	317	135966	124290	0.91	1105840.34	122884.40	92154.38	0.00	1320879	9.7
Sep-21	411	300	122028	112878	0.93	995266.00	117135.00	83217.00	0.00	1195618	9.8
Oct-21	411	267	103236	101718	0.99	839516.33	117135.00	71748.85	0.00	1028400	10.0
Nov-21	411	164	51156	49434	0.97	415741.37	117135.00	39965.73	0.00	572842	11.2
Dec-21	411	149	59880	57312	0.96	486728.56	117135.00	45289.77	0.00	649153	10.8
Jan-22	411	170	73878	72564	0.98	600630.29	117135.00	53832.40	0.00	771598	10.4
Feb-22	411	180	60204	58842	0.98	489364.95	117135.00	45487.50	0.00	651987	10.8
Mar-22	411	200	44202	40488	0.92	350952.00	117135.00	35721.00	0.00	503808	11.4










Account No. 4540285915; QMH(New 100 Bedded hospital); 4540285915 Registrar , KGMU




Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	333.33	60	12,472	12,224	0.98	2,00,703.00	95,190.00	14,491.00	0.00	3,10,384	24.9
May-21	333.33	65	34,832	34,452	0.99	2,74,872.80	95,190.00	27,739.71	0.00	3,97,803	11.4
Jun-21	333.33	91	33,672	33,436	0.99	2,65,508.80	95,190.00	27,052.41	0.00	3,87,751	11.5
Jul-21	333.33	72	41,248	40,736	0.99	3,25,359.20	95,190.00	31,541.19	0.00	4,52,090	11.0
Aug-21	333.33	75	31,048	30,592	0.99	2,44,779.20	95,190.00	25,497.69	0.00	3,65,467	11.8
Sep-21	333.33	70	37,640	37,096	0.99	2,99,796.00	95,190.00	29,403.00	0.00	4,24,389	11.3
Oct-21	333.33	73	23,704	23,500	0.99	1,86,761.60	95,190.00	21,146.37	0.00	3,03,098	12.8
Nov-21	333.33	38	14,756	14,620	0.99	1,16,072.40	95,190.00	15,844.68	0.00	2,27,107	15.4
Dec-21	333.33	45	22,112	22,004	1.00	1,74,184.80	95,190.00	20,203.11	0.00	2,89,578	13.1
Jan-22	333.33	64	30,216	30,044	0.99	2,38,206.40	95,190.00	25,004.73	0.00	3,58,401	11.9
Feb-22	333.33	64	16,580	16,416	0.99	1,30,482.00	95,190.00	16,925.40	0.00	2,42,597	14.6
Mar-22	333.33	64	21,760	21,400	0.98	1,90,026.00	95,190.00	1,994.00	0.00	2,87,210	13.2










Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	540	454	197950	179030	0.90	1883305.00	174192.00	130312.28	0.00	1867810	9.4
May-21	540	470	247570	223950	0.90	1955303.00	178448.00	160031.33	0.00	2293782	9.3
Jun-21	540	510	261400	228740	0.88	2392945.00	168932.00	187872.00	0.00	2749749	10.5
Jul-21	540	470	247570	223950	0.90	1955303.00	178448.00	160031.33	0.00	3882708	15.7
Aug-21	540	530	236210	200990	0.85	1863339.00	201552.00	155033.33	0.00	2244366	9.5
Sep-21	540	500	267570	238240	0.89	2345873.00	209152.00	174776.00	0.00	2729801	10.2
Oct-21	540	434	241240	229100	0.95	1905296.00	165072.00	155277.60	0.00	2247994	9.3
Nov-21	540	213	95340	93980	0.99	752656.00	153900.00	67993.95	0.00	984326	10.3
Dec-21	540	183	95000	93480	0.98	750000.00	153900.00	67792.50	0.00	1114555	11.7
Jan-22	540	198	101720	99050	0.97	803088.00	153900.00	71774.10	0.00	1039076	10.2
Feb-22	540	202	89440	87540	0.98	706076.00	153900.00	64498.20	0.00	933740	10.4
Mar-22	540	230	132330	114920	0.87	1367657.00	172064.00	91273.00	0.00	1630994	12.3










Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	1087	693	199200	184000	0.92	1573180.00	309795.00	141223.13	0.00	2024198	10.16
May-21	1087	614	172660	159820	0.93	1363514.00	309795.00	125498.18	0.00	1798807	10.42
Jun-21	1087	894	232820	219000	0.94	1838778.00	339872.00	163398.75	0.00	2342049	10.06
Jul-21	1087	810	319800	302300	0.95	2525920.00	309795.00	212678.63	0.00	3048394	9.53
Aug-21	1087	810	319800	302300	0.95	2525920.00	309795.00	212678.63	0.00	3048394	9.53
Sep-21	1087	850	208240	195160	0.94	not obtain	328624.00	147991.00	0.00	2123263	10.20
Oct-21	1087	800	214200	197120	0.92	1691680.00	309795.00	150110.63	0.00	2151586	10.04
Nov-21	1087	345	131800	117080	0.89	1040720.00	309795.00	101288.63	0.00	1451804	11.02
Dec-21	1087	446	176160	163500	0.93	1391164.00	309795.00	127571.93	0.00	1828531	10.38
Jan-22	1087	547	206780	197680	0.96	1633062.00	309795.00	145714.28	0.00	2088571	10.10
Feb-22	1087	434	144140	131460	0.91	1138206.00	309795.00	108600.08	0.00	1556601	10.80
Mar-22	1087	400	173020	159240	0.92	not obtain	309795.00	125711.00	0.00	1783564	10.31










Monthly Electrical bill detail KGMU Year 2021-2022												
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Total Billed Unit (KVAH)	Electricity Bill Energy charge
Apr-21	2632	3145	456300	357200	0.78	3377030.00	617120.00	345845.00	389880.00	4339995	456300.00	9.5
May-21	2632	2316	250100	230200	0.92	1975230.00	880080.00	214152.75	0.00	3069463	250100.00	12.3
Jun-21	2632	2400	404700	303800	0.75	4929833.00	937840.00	310085.00	0.00	6177758	404700.00	15.3
Jul-21	2632	2580	230800	220100	0.95	1822820.00	980400.00	210241.50	0.00	3013462	230800.00	13.1
Aug-21	2632	2560	794000	687340	0.87	6272100.00	972800.00	543367.00	0.00	7788267	794000.00	9.8
Sep-21	2632	2800	1300100	1111200	0.85	10476660.00	1080720.00	863410.00	161120.00	12420790	1300100.00	9.6
Oct-21	2632	3132	1396400	1197800	0.86	11031060.00	1190160.00	945091.50	380000.00	13546312	1396400.00	9.7
Nov-21	2632	1928	734700	599400	0.82	5803630.00	750120.00	491531.25	0.00	7045281	734700.00	9.6
Dec-21	2632	1572	700600	595700	0.85	5534240.00	750120.00	471327.00	0.00	6755687	700600.00	9.6
Jan-22	2632	1668	670200	593400	0.89	5294080.00	750120.00	453315.00	0.00	6497515	670200.00	9.7
Feb-22	2632	1612	539000	453700	0.84	4257600.00	750120.00	375579.00	0.00	5383299	539000.00	10.0
Mar-22	2632	1800	648200	541300	0.84	Not Obtain	750120.00	440280.00	0.00	6310680	648200.00	9.7










Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge
Apr-21	45	54	7000	6860	0.98	64404.52	14472.00	5514.04	0.00	84391	12.1
May-21	45	58	8200	8040	0.98	63860.52	15552.00	6466.24	6804.00	92683	11.3
Jun-21	45	78	11600	11400	0.98	90652.52	21168.00	9739.24	18036.00	139596	12.0
Jul-21	45	75	15120	14920	0.99	118390.12	20304.00	11625.16	16308.00	166627	11.0
Aug-21	45	77	9600	9440	0.98	74892.52	20736.00	8460.04	17172.00	121261	12.6
Sep-21	45	72	11000	10840	0.99	87065.00	20304.00	9190.00	16308.00	132867	12.1
Oct-21	45	70	7808	7664	0.98	60771.56	19008.00	7012.17	13716.00	100508	12.9
Nov-21	45	22	2432	2336	0.96	18408.68	9112.50	2064.09	0.00	29585	12.2
Dec-21	45	21	3440	3360	0.98	26351.72	9112.50	2659.82	0.00	38124	11.1
Jan-22	45	30	4920	4880	0.99	38014.12	9112.50	3534.50	0.00	50661	10.3
Feb-22	45	29	3280	3200	0.98	25090.92	9112.50	2565.26	0.00	36769	11.2
Mar-22	45	35	5240	5080	0.97	40671.00	9504.00	3753.00	0.00	53928	10.3







Monthly Electrical bill detail KGMU Year 2021-2022												
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Total Billed Unit (KVAH)	Electricity Bill Energy charge Rs/KVAh
Apr-21	698	468	45099	43551	0.97	355782.10	198930.00	3687.87	0.00	558400	45099.00	12.4
May-21	698	473	43679	42005	0.96	344564.10	198930.00	40762.06	0.00	584256	43679.00	13.4
Jun-21	698	574	84681	79748	0.94	668479.90	218120.00	66494.99	0.00	953095	84681.00	11.3
Jul-21	698	570	141140	132920	0.94	1114506.00	216600.00	99832.95	0.00	1430939	141140.00	10.1
Aug-21	698	593	75004	69920	0.93	592031.60	225340.00	61302.87	0.00	878674	75004.00	11.7
Sep-21	698	550	80364	75384	0.94	634375.00	198930.00	62498.00	0.00	895803	80364.00	11.1
Oct-21	698	556	84572	82529	0.98	667618.80	211280.00	65917.41	0.00	944816	84572.00	11.2
Nov-21	698	87	25667	24205	0.94	202269.30	198930.00	30089.95	0.00	431289	25667.00	16.8
Dec-21	698	119	26075	22913	0.88	205492.50	198930.00	30331.69	0.00	434754	26075.00	16.7
Jan-22	698	153	32463	29717	0.92	255957.70	198930.00	34116.58	0.00	489004	32463.00	15.1
Feb-22	698	149	26146	23548	0.90	206053.40	198930.00	30373.76	0.00	435357	26146.00	16.7
Mar-22	698	200	37271	35556	0.95	358102.00	198930.00	36965.00	0.00	593997	37271.00	15.9








Account No. 4747481000; Cancer unit; 678442 Registrar . KGMU



Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	112	26	2052	2004	0.98	19436.92	31920.00	3661.72	0.00	55019	26.8
May-21	112	35	5872	5584	0.95	47265.46	31920.00	5938.91	0.00	85124	14.5
Jun-21	112	30	15512	12289	0.79	189986.00	31920.00	11822.00	0.00	233728	15.1
Jul-21	112	32	3620	3296	0.91	28940.94	31920.00	4564.57	0.00	65426	18.1
Aug-21	112	17	1548	1540	0.99	12277.19	31920.00	3314.79	0.00	47512	30.7
Sep-21	112	35	19548	15372	0.79	158595.00	31920.00	14285.00	0.00	204800	10.5
Oct-21	112	45	2732	2496	0.91	21715.28	31920.00	4022.65	0.00	57658	21.1
Nov-21	112	18	144	152	1.06	1142.06	31920.00	2479.65	0.00	35542	246.8
Dec-21	112	7	628	624	0.99	4980.00	31920.00	2767.55	0.00	39668	63.2
Jan-22	112	16	2032	2032	1.00	16115.79	31920.00	3602.68	0.00	51638	25.4
Feb-22	112	7	384	372	0.97	3045.00	31920.00	2622.41	0.00	37587	97.9
Mar-22	112	10	860	732	0.85	6835.00	31920.00	2905.00	0.00	41660	48.4










Type-5 Faculty building(J.N Road); 7200191928 Registrar , KGMU




Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	444.44	100	16400	15910	0.97	104058.00	33041.00	6818.00	0.00	143917	8.8
May-21	444.44	132	52890	51980	0.98	333207.00	33041.25	18312.41	0.00	384561	7.3
Jun-21	444.44	177	61560	60750	0.99	387828.00	33041.25	21043.46	0.00	441913	7.2
Jul-21	444.44	139	94050	92910	0.99	592515.00	33041.25	31277.81	0.00	656834	7.0
Aug-21	444.44	170	47840	47140	0.99	301392.00	33041.25	16721.66	0.00	351155	7.3
Sep-21	444.44	153	75040	73940	0.99	476999.00	33041.00	25289.00	0.00	535329	7.1
Oct-21	444.44	116	48150	47250	0.98	303345.00	33041.25	16819.31	0.00	353206	7.3
Nov-21	444.44	82	29420	28530	0.97	185346.00	33041.25	10919.36	0.00	229307	7.8
Dec-21	444.44	117	38570	37680	0.98	242991.00	33041.25	13801.61	0.00	289834	7.5
Jan-22	444.44	177	62810	61830	0.98	395703.00	33041.25	21437.21	0.00	450181	7.2
Feb-22	444.44	513	44530	43540	0.98	280539.00	50787.00	16902.90	6732.00	354961	8.0
Mar-22	444.44	300	19500	18810	0.96	49774.00	33041.00	77419.00	0.00	160234	8.2










Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	445	132	27486	17922	0.65	223138.58	126825.00	26247.27	0.00	376211	13.7
May-21	445	120	26028	17454	0.67	211274.84	126825.00	25357.49	0.00	363457	14.0
Jun-21	445	225	35802	28296	0.79	290805.87	126825.87	31322.32	0.00	448954	12.5
Jul-21	445	239	64092	50304	0.78	521001.60	126825.00	48587.00	0.00	696414	10.9
Aug-21	445	249	34218	25926	0.76	277916.67	126825.00	30355.64	0.00	435097	12.7
Sep-21	445	220	33594	30984	0.92	274801.00	126825.00	29974.00	0.00	431600	12.8
Oct-21	445	224	40500	29292	0.72	329033.50	126825.00	34189.39	0.00	490048	12.1
Nov-21	445	125	34026	15960	0.47	276354.56	126825.00	30238.47	0.00	433418	12.7
Dec-21	445	137	41142	20844	0.51	334257.45	126825.00	34581.00	0.00	495663	12.0
Jan-22	445	156	43956	25086	0.57	357154.97	126825.00	36298.50	0.00	520278	11.8
Feb-22	445	146	37560	19338	0.51	305110.72	126825.00	32395.18	0.00	464331	12.4
Mar-22	445	130	18282	11268	0.62	143850.00	126825.00	20630.00	0.00	291305	15.9









Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	667	126	61008	57612	0.94	495907.10	190095.00	61450.16	0.00	747452	12.3
May-21	667	135	60324	57756	0.96	490341.39	190095.00	51032.73	0.00	731469	12.1
Jun-21	667	150	16104	14172	0.88	516632.00	190095.00	24046.00	0.00	730773	45.4
Jul-21	667	154	65904	63468	0.96	535745.85	190095.00	54438.06	0.00	780279	11.8
Aug-21	667	123	112812	108096	0.96	922276.00	190095.00	83064.00	0.00	1195435	10.6
Sep-21	667	120	100860	95808	0.95	824946.00	190095.00	75770.00	0.00	1090811	10.8
Oct-21	667	129	53940	50520	0.94	438394.78	190095.00	47136.73	0.00	675627	12.5
Nov-21	667	105	38520	34692	0.90	312922.24	190095.00	37726.29	0.00	540744	14.0
Dec-21	667	173	70068	67032	0.96	569628.32	190095.00	56979.25	0.00	816703	11.7
Jan-22	667	207	90432	88524	0.98	735330.18	190095.00	69406.89	0.00	994832	11.0
Feb-22	667	180	53964	51120	0.95	438590.07	190095.00	47151.38	0.00	675836	12.5
Mar-22	667	150	73212	34068	0.47	not obtain	190095.00	36928.00	0.00	523106	7.1






Monthly Electrical bill detail KGMU Year 2021-2022												
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Total Billed Unit (KVAH)	Electricity Bill Energy charge Rs/KVAh
Apr-21	1334	550	175240	146060	0.83	1383896.00	380190.00	132306.45	0.00	1896392	175240.00	10.82
May-21	1334	721	175400	146280	0.83	1385160.00	380190.00	132401.00	0.00	1897751	175400.00	10.82
Jun-21	1334	747	129060	107120	0.83	535752.00	380190.00	65695.65	0.00	981638	129060.00	7.61
Jul-21	1334	791	434880	362200	0.83	3435052.00	380190.00	286143.15	0.00	4101385	434880.00	9.43
Aug-21	1334	808	427600	351880	0.82	3770540.00	380180.00	281829.75	0.00	4432550	427600.00	10.37
Sep-21	1334	150	377200	310240	0.82	3016580.00	380190.00	241967.00	0.00	3638737	377200.00	9.65
Oct-21	1334	783	353720	289560	0.82	2793888.00	380190.00	238055.85	0.00	3412134	353720.00	9.65
Nov-21	1334	537	216000	174680	0.81	1705900.00	380190.00	156456.75	0.00	2242547	216000.00	10.38
Dec-21	1334	498	167560	142920	0.85	1323224.00	380190.00	127756.05	0.00	1831170	167560.00	10.93
Jan-22	1334	502	140120	124200	0.89	1106448.00	380190.00	11497.85	0.00	1498136	140120.00	10.69
Feb-22	1334	505	130320	112560	0.86	1029028.00	380190.00	105691.35	0.00	1514909	130320.00	11.62
Mar-22	1334	555	239280	174480	0.73	1865187.00	380190.00	170250.00	0.00	2415627	239280.00	10.10












Account No. 2747481000; Cardiology Department; 577925 Registrar, KGMU




Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	223	105	35132	33030	0.94	291094.81	63555.00	26509.04	0.00	381159	10.8
May-21	223	105	38874	36486	0.94	315802.74	63555.00	28451.83	0.00	407810	10.5
Jun-21	223	134	42804	40776	0.95	476921.00	63555.00	30850.00	0.00	571326	0.0
Jul-21	223	98	50508	47934	0.95	410468.00	63555.00	35551.77	0.00	509575	10.1
Aug-21	223	98	52578	50394	0.96	427312.19	63555.00	36815.04	0.00	527682	10.0
Sep-21	223	130	49158	46692	0.95	399483.65	63555.00	34727.00	0.00	497766	10.1
Oct-21	223	130	35544	33330	0.94	289396.00	63555.00	26419.00	0.00	379370	0.0
Nov-21	223	65	19710	18642	0.95	159865.27	63555.00	16756.52	0.00	240177	12.2
Dec-21	223	62	28020	27288	0.97	227483.74	63555.00	21827.91	0.00	312867	11.2
Jan-22	223	70	29376	29070	0.99	238517.51	63555.00	22655.44	0.00	324728	11.1
Feb-22	223	68	22632	22116	0.98	183641.58	63555.00	18539.74	0.00	265736	11.7
Mar-22	223	79	34632	32868	0.95	282291.00	63555.00	25863.00	0.00	371709	0.0







Account No. 7077481000; T.G. Hostel; 9202 Registrar , KGMU




Monthly Electrical bill detail KGMU Year 2021-2022												
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Total Billed Unit (KVAH)	Electricity Bill Energy charge Rs/KVAh
Apr-21	198	73	33380	23580	0.71	206772.00	56430.00	23972.00	0.00	287174	33720.00	8.52
May-21	198	75	33720	30540	0.91	265888.00	56430.00	24173.85	0.00	346492	33720.00	10.28
Jun-21	198	95	37900	34960	0.92	298910.00	56430.00	26650.00	0.00	381990	37900.00	10.08
Jul-21	198	95	37900	34960	0.92	298910.00	56430.00	26650.00	0.00	381990	37900.00	10.08
Aug-21	198	110	42410	37770	0.89	468594.00	56430.00	29322.00	0.00	554346	42410.00	13.07
Sep-21	198	150	40910	37960	0.93	423812.00	56430.00	28433.00	0.00	508675	40910.00	12.43
Oct-21	198	135	36110	32160	0.89	276301.00	65840.00	25589.00	0.00	367730	36110.00	10.18
Nov-21	198	125	35460	30980	0.87	282019.00	56430.00	25204.00	0.00	363653	35460.00	10.26
Dec-21	198	162	62140	61070	0.98	490406.00	61560.00	41397.45	0.00	593363	62140.00	9.55
Jan-22	198	213	96190	95370	0.99	759401.00	80940.00	63880.58	11400.00	915622	96190.00	9.52
Feb-22	198	176	52290	50890	0.97	412591.00	66880.00	35960.33	0.00	515431	52290.00	9.86
Mar-22	198	180	43520	39740	0.91	347900.00	56430.00	29980.00	0.00	434310	43520.00	9.98








Account No. 6357245033; T.G. Hostel Residential Type -2; 10057 Registrar , KGMU




Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	334	91	42924	32638	0.76	270421.20	24799.50	14761.04	0.00	309982	7.2
May-21	334	103	47260	38010	0.80	297738.00	24799.50	16126.88	0.00	338664	7.2
Jun-21	334	103	51622	44256	0.86	325220.00	24799.00	17500.00	0.00	367519	7.1
Jul-21	334	118	50420	42698	0.85	317646.00	24799.50	17122.28	0.00	359568	7.1
Aug-21	334	96	40050	37740	0.94	378784.00	24799.00	13855.00	0.00	417438	10.4
Sep-21	334	121	62878	57330	0.91	330806.00	24799.00	21046.00	0.00	376651	6.0
Oct-21	334	115	58678	46334	0.79	774763.00	24799.00	19723.00	0.00	819285	14.0
Nov-21	334	115	58678	46334	0.79	1004803.00	24799.00	19723.00	0.00	1049325	17.9
Dec-21	334	91	45542	28844	0.63	286914.60	24799.50	15585.71	0.00	327300	7.2
Jan-22	334	124	58728	48604	0.83	369986.40	24799.50	19739.30	0.00	414525	7.1
Feb-22	334	80	39854	23614	0.59	293441.40	24799.00	15912.05	0.00	334152	8.4
Mar-22	334	94	29060	23674	0.81	247383.00	24799.00	13543.00	0.00	285725	9.8






Monthly Electrical bill detail KGMU Year 2021-2022								
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	334	278	121400	117470	0.97	0.00	2049838	16.88
May-21	334	278	144790	140550	0.97	0.00	1352586	9.34
Jun-21	334	298	116100	112530	0.97	0.00	1079306	9.30
Jul-21	334	273	120790	115370	0.96	0.00	1136955	9.41
Aug-21	334	273	120790	115370	0.96	0.00	434509	3.60
Sep-21	334	305	52910	49190	0.93	0.00	434509	8.21
Oct-21	334	305	52910	49190	0.93	0.00	434509	8.21
Nov-21	334	278	11135	10835	0.97	0.00	434509	39.02
Dec-21	334	94	32140	25440	0.79	0.00	374741	11.66
Jan-22	334	94	32140	25440	0.79	0.00	578314	17.99
Feb-22	334	102	40820	35860	0.88	0.00	448456	10.99
Mar-22	334	94	32140	25440	0.79	0.00	344665	10.72












Account No. 4042748045; Employees Quarter Type-1; 4042748045 Registrar , KGMU

Monthly Electrical bill detail KGMU Year 2021-2022											
Months	Sanctioned Load (KVA)	MDI	KVAH	KWH	Power Factor	Total Electricity Charge	Fixed /Demand Charge	ED (electricity duty)	Excess Demand penalty	Total (Rs.)	Electricity Bill Energy charge Rs/KVAh
Apr-21	78	95	48528	13990	0.29	305726.40	9428.78	16843.10	0.00	331998	6.84
May-21	78	97	57940	18458	0.32	365022.00	9571.32	18822.13	1849.32	395265	6.82
Jun-21	78	97	18368	15104	0.82	348004.00	5791.00	6075.00	0.00	359870	19.59
Jul-21	78	80	16758	14542	0.87	397542.00	5791.00	5568.00	0.00	408901	24.40
Aug-21	78	99	66970	19128	0.29	421911.00	9801.00	21689.55	2079.00	455481	6.80
Sep-21	78	67	10528	8848	0.84	296675.50	5791.00	6922.00	0.00	309389	29.39
Oct-21	78	67	10528	8848	0.84	296675.50	5791.00	6922.00	0.00	309389	29.39
Nov-21	78	58	10533	9279	0.88	66357.90	5791.50	6925.37	0.00	79075	7.51
Dec-21	78	58	10533	9279	0.88	66357.90	5791.50	6925.37	0.00	79075	7.51
Jan-22	78	60	27340	16176	0.59	442013.00	9203.00	6925.37	2051.00	453267	16.58
Feb-22	78	57	12432	10512	0.85	78321.60	5791.50	4205.66	0.00	88319	7.10
Mar-22	78	57	12432	10512	0.85	78321.60	5791.50	4205.66	0.00	88319	7.10








Seasonal Variation

Table : Seasonal Variation of Energy Consumption during April 2021 to March 2022

Connection Name	Summer Electricity, kWh	Winter Electricity, kWh
NEW MORTUARY DEPARTMENT	1,125,876	239,238
C.T.V.S	738,880	432,535
HOSPITAL SUBSTATION	1,180,314	813,950
New Dental	410,630	224,080
COBALT SUBSTATION	1,076,832	788,200
PSYCHIATRIC DEPARTMENT	129,024	44,026
QUEEN MARRY HOSPITAL	611,538	380,358
QMH (NEW 100 BEDED HOSPITAL)	188,536	127,984
TRAUMA CENTER	1,329,500	718,070
OLD MORTUARY SUBSTATION	1,362,580	966,080
KALAM CENTER	2,909,840	3,981,300
PHI	61,500	26,520
NEW OPD BLOCK	443,528	218,468
CANCER UNIT	40,085	6,408


TYPE 5 FACULTY BUILDING	342,630	237,640
OLD DENTAL	170,886	121,788
GAUTAM BUDHA HOSPITAL	396,912	325,956
SHATABDI HOSPITAL	1,423,780	1,018,400
CARDIOLOGY DEPARTMENT	255,312	163,314
T G HOSTEL	199,770	310,210
T G HOSTEL RESIDENTIAL TYPE 2	252,672	217,404
ARTIFICIAL LIMB CENTER	461,160	147,180
EMPLOYEES QUARTER TYPE -1	90,070	64,606



Observation :- Winter Energy Consumption of Kalam Center is more than Summer; the load is mix and other than the Kalam Center.

Load connected to different meters in the total electricity consumption

Department Name	Account No.	% load connected to different meters from April 2021 to March 2022
NEW MORTUARY DEPARTMENT	3747481000	5
C.T.V.S	9747481000	4
HOSPITAL SUBSTATION	8547481000	7
COBALT SUBSTATION	9547481000	7
Others (PSYCHIATRIC DEPARTMENT +QMH (NEW 100 BEDED HOSPITAL)+PHI+ Cancer Unit+Old Dental+ Employee Qtr, Type 1+Artificial Limb Center+TG Hostel+TG Hostel Residential Type 2+Cardiology Dept+New OPD Block+Type 5 Faculty Building+New Dental+Gautam Buddha Hospital)	1747481000	21
QUEEN MARRY HOSPITAL	7547481000	4
TRAUMA CENTER	5747481000	8
OLD MORTUARY SUBSTATION	7747481000	8
KALAM CENTER	9753334424	26
SHATABDI HOSPITAL	1647481000	9



The above chart indicates that the Kalam Center meter needs a special attention for Energy Conservation initiatives as it contributes around 1/4th of the total electricity consumption of the Hospital.

DG Sets Performance Analysis

On sample basis, the performance of some DG sets have been analysed based on the log book data which is as below :-

Trauma DG 1

Location	DG Spec kVA	Month	Running in Minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
Trauma DG 1	125	Apr-21	47	30	0.78	38.46	100
Trauma DG 1	125	May-21	127	117	2.11	55.45	100
Trauma DG 1	125	Jun-21	183	50	3.05	16.39	50
Trauma DG 1	125	Jul-21	126	56	2.10	26.67	75
Trauma DG 1	125	Aug-21	67	53	1.11	47.75	100
Trauma DG 1	125	Sep-21	57	25	0.95	26.32	75
Trauma DG 1	125	Oct-21	426	140	7.10	19.72	50
Trauma DG 1	125	Nov-21	127	83	2.11	39.34	100
Trauma DG 1	125	Dec-21	57	26	0.95	27.37	75
Trauma DG 1	125	Jan-22	245	66	4.08	16.18	50
Trauma DG 1	125	Feb-22	7	Not Available(NA)	0.11	NA	NA
Trauma DG 1	125	Mar-22	126	59	2.10	28.10	75

Trauma DG 2

Location	DG Spec KVA	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
Trauma DG2	250	Apr-21	62	25	1.03	24.19	25
Trauma DG2	250	May-21	543	175	9.05	19.34	25
Trauma DG2	250	Jun-21	426	122	7.10	17.18	25
Trauma DG2	250	Jul-21	124	46	2.07	22.26	25
Trauma DG2	250	Aug-21	38	12	0.63	18.95	25
Trauma DG2	250	Sep-21	68	33	1.13	29.12	25
Trauma DG2	250	Oct-21	31	11	0.52	21.29	25
Trauma DG2	250	Nov-21	NA	NA	NA	NA	NA
Trauma DG2	250	Dec-21	NA	10	NA	NA	NA
Trauma DG2	250	Jan-22	45	20	0.75	26.67	25
Trauma DG2	250	Feb-22	69	50	1.15	43.48	70
Trauma DG2	250	Mar-22	79	35	1.32	26.58	25

Trauma DG 3

DG Spec KVA	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
250	Apr-21	47	14	0.78	17.87	25
250	May-21	242	43	4.03	10.66	25
250	Jun-21	176	21	2.93	7.16	25
250	Jul-21	179	26	2.98	8.72	25
250	Aug-21	109	21	1.82	11.56	25
250	Sep-21	54	11	0.90	12.22	25
250	Oct-21	506	82	8.43	9.72	25
250	Nov-21	169	31	2.82	11.01	25
250	Dec-21	57	21	0.95	22.11	25
250	Jan-22	214	53	3.57	14.86	25
250	Feb-22	21	3	0.35	8.57	25
250	Mar-22	127	29	2.12	13.70	25

Trauma DG 4

DG Spec	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
250	Apr-21	47	37	0.78	47.23	75
250	May-21	255	146	4.25	34.35	50
250	Jun-21	211	97	3.52	27.58	25
250	Jul-21	158	63	2.63	23.92	25
250	Aug-21	100	60	1.67	36.00	50
250	Sep-21	54	28	0.90	31.11	50
250	Oct-21	468	261	7.80	33.46	50
250	Nov-21	171	134	2.85	47.02	75
250	Dec-21	57	53	0.95	55.79	75
250	Jan-22	242	89	4.03	22.07	25
250	Feb-22	12	NA	0.20	NA	NA
250	Mar-22	121	73	2.02	36.20	50

Rheumatology DG

DG Spec	Month	Running Time in minutes	Monthly Fuel Consumption in lit	Hour	Litre /hour	Load %
250	Apr-21	168	30	2.80	10.71	25
250	May-21	870	116	14.50	8.00	25
250	Jun-21	1353	142	22.55	6.30	25
250	Jul-21	868	102	14.47	7.05	25
250	Aug-21	1768	188	29.47	6.38	25
250	Sep-21	1990	154	33.17	4.64	25
250	Oct-21	377	46	6.28	7.32	25
250	Nov-21	55	8	0.92	8.73	25
250	Dec-21	723	134	12.05	11.12	25
250	Jan-22	306	44	5.10	8.63	25
250	Feb-22	159	38	2.65	14.34	25
250	Mar-22	202	32	3.37	9.50	25

Microbiology DG

DG Spec	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
250	Apr-21	1050	356	17.50	20.34	25
250	May-21	1677	481	27.95	17.21	25
250	Jun-21	880	236	14.67	16.09	25
250	Jul-21	426	134	7.10	18.87	25
250	Aug-21	811	171	13.52	12.65	25
250	Sep-21	225	46	3.75	12.27	25
250	Oct-21	102	18	1.70	10.59	25
250	Nov-21	NA	NA	NA	NA	NA
250	Dec-21	60	18	1.00	18.00	25
250	Jan-22	245	50	4.08	12.24	25
250	Feb-22	150	30	2.50	12.00	25
250	Mar-22	139	48	2.32	20.72	25

Old Dental DG

DG Spec KVA	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
61	Apr-21	75	8	1.25	6.40	25 to 50
61	May-21	171	14	2.85	4.91	25 to 50
61	Jun-21	50	6	0.83	7.20	25 to 50
61	Jul-21	128	10	2.13	4.69	25 to 50
61	Aug-21	165	10	2.75	3.64	25
61	Sep-21	115	12	1.92	6.26	25 to 50
61	Oct-21	165	14	2.75	5.09	25 to 50
61	Nov-21	65	6	1.08	5.54	25 to 50
61	Dec-21	307	18	5.12	3.52	25
61	Jan-22	105	10	1.75	5.71	25 to 50
61	Feb-22	70	7	1.17	6.00	25 to 50
61	Mar-22	168	8	2.80	2.86	25

Gandhi Ward, DG 2

DG Spec	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
320 KVA	Apr-21	170	67	2.83	23.65	25
320 KVA	May-21	376	235	6.27	37.50	25
320 KVA	Jun-21	346	257	5.77	44.57	50
320 KVA	Jul-21	166	84	2.77	30.36	25
320 KVA	Aug-21	125	62	2.08	29.76	25
320 KVA	Sep-21	607	315	10.12	31.14	25
320 KVA	Oct-21	166	65	2.77	23.49	25
320 KVA	Nov-21	131	76	2.18	34.81	25
320 KVA	Dec-21	411	167	6.85	24.38	25
320 KVA	Jan-22	233	105	3.88	27.04	25
320 KVA	Feb-22	64	24	1.07	22.50	25
320 KVA	Mar-22	177	85	2.95	28.81	25

Gandhi Ward DG 1

DG Spec KVA	Month	Running Time in minutes	Monthly Fuel Consumption in lit	Hour	Litre /hour	Load %
320	Apr-21	107	52	1.78	29.16	25
320	May-21	359	198	5.98	33.09	25
320	Jun-21	379	195	6.32	30.87	25
320	Jul-21	149	68	2.48	27.38	25
320	Aug-21	61	52	1.02	51.15	50
320	Sep-21	596	315	9.93	31.71	25
320	Oct-21	306	185	5.10	36.27	25
320	Nov-21	111	55	1.85	29.73	25
320	Dec-21	405	187	6.75	27.70	25
320	Jan-22	114	65	1.90	34.21	25
320	Feb-22	29	15	0.48	31.03	25
320	Mar-22	58	19	0.97	19.66	25

Mortuary DG

DG Spec	Month	Running Time in minutes	Monthly Fuel Consumption in lit	Hour	Litre /hour	Load %
50	Apr-21	1255	126	20.92	6.02	50
50	May-21	1605	128	26.75	4.79	25
50	Jun-21	645	58	10.75	5.40	25
50	Jul-21	326	30	5.43	5.52	25
50	Aug-21	802	80	13.37	5.99	25
50	Sep-21	289	39	4.82	8.10	50
50	Oct-21	102	13	1.70	7.65	50
50	Nov-21	40	4	0.67	6.00	25
50	Dec-21	110	6	1.83	3.27	25
50	Jan-22	190	14	3.17	4.42	25
50	Feb-22	50	5	0.83	6.00	25
50	Mar-22	104	11	1.73	6.35	50

RALC DG 4

DG Spec	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
500	Apr-21	NA	NA	NA	NA	NA
500	May-21	510	490	8.50	57.65	50
500	Jun-21	1072	410	17.87	22.95	25
500	Jul-21	559	437	9.32	46.91	50
500	Aug-21	1503	818	25.05	32.65	25
500	Sep-21	196	89	3.27	27.24	25
500	Oct-21	577	350	9.62	36.40	50
500	Nov-21	NA	NA	NA	NA	NA
500	Dec-21	843	622	14.05	44.27	50
500	Jan-22	326	233	5.43	42.88	50
500	Feb-22	238	215	3.97	54.20	50
500	Mar-22	237	160	3.95	40.51	50

Central Library DG


DG Spec	Month	Running Time	Monthly Fuel Consumption in lit	Hour	Litre /hour	Load %
200	Apr-21	1060	240	17.67	13.58	25
200	May-21	1572	272	26.20	10.38	25
200	Jun-21	885	190	14.75	12.88	25
200	Jul-21	261	84	4.35	19.31	50
200	Aug-21	963	218	16.05	13.58	25
200	Sep-21	249	51	4.15	12.29	25
200	Oct-21	82	28	1.37	20.49	50
200	Nov-21	35	8	0.58	13.71	25
200	Dec-21	50	17	0.83	20.40	50
200	Jan-22	125	48	2.08	23.04	50
200	Feb-22	175	48	2.92	16.46	50
200	Mar-22	134	44	2.23	19.70	50

CTVS DG1

DG Spec	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
320	Apr-21	100	45	1.67	27.00	25
320	May-21	332	150	5.53	27.11	25
320	Jun-21	229	105	3.82	27.51	25
320	Jul-21	189	90	3.15	28.57	25
320	Aug-21	83	45	1.38	32.53	25
320	Sep-21	87	50	1.45	34.48	25
320	Oct-21	70	30	1.17	25.71	25
320	Nov-21	65	35	1.08	32.31	25
320	Dec-21	94	35	1.57	22.34	25
320	Jan-22	131	55	2.18	25.19	25
320	Feb-22	60	30	1.00	30.00	25
320	Mar-22	168	50	2.80	17.86	25

CTVS DG 2

DG Spec KVA	Month	Running Time in minutes	Monthly Fuel Consumption in litre	Hour	Litre /hour	Load %
125	Apr-21	100	18	1.67	10.80	25
125	May-21	332	60	5.53	10.84	25
125	Jun-21	254	38	4.23	8.98	25
125	Jul-21	189	34	3.15	10.79	25
125	Aug-21	83	16	1.38	11.57	25
125	Sep-21	82	18	1.37	13.17	25
125	Oct-21	60	12	1.00	12.00	25
125	Nov-21	75	14	1.25	11.20	25
125	Dec-21	94	12	1.57	7.66	25
125	Jan-22	97	20	1.62	12.37	25
125	Feb-22	55	12	0.92	13.09	25
125	Mar-22	168	26	2.80	9.29	25



Observations :-

1. Average load of the DGs is around 32%
2. Average operating hrs is 0.70 hrs per day

Power Factor Analysis

Connection wise Operating Power Factor

S. No.	Department Name	Account No.	Operating PF 2021-22
1	NEW MORTUARY DEPARTMENT	3747481000	0.95
2	2. C.T.V.S	9747481000	0.87
3	HOSPITAL SUBSTATION	8547481000	0.97
4	New Dental	5134370261	0.92
5	COBALT SUBSTATION	9547481000	1.00
6	PSYCHIATRIC DEPARTMENT	1747481000	0.78
7	QUEEN MARRY HOSPITAL	7547481000	0.94
8	QMH (NEW 100 BEDED HOSPITAL)	4540285915	0.99
9	TRAUMA CENTER	5747481000	0.92
10	OLD MORTUARY SUBSTATION	7747481000	0.93
11	KALAM CENTER	9753334424	0.85
12	PHI	1214770000	0.98
13	NEW OPD BLOCK	4697779403	0.94
14	CANCER UNIT	4747481000	0.85
15	TYPE 5 FACULTY BUILDING	7200191928	0.98
16	OLD DENTAL	6747481000	0.66
17	GAUTAM BUDHA HOSPOITAL	1133332000	0.90
18	SHATABDI HOSPITAL	1647481000	0.83
19	CARDIOLOGY DEPARTMENT	2747481000	0.96
20	T G HOSTEL	7077481000	0.91
21	T G HOSTEL RESIDENTIAL TYPE 2	6357245033	0.80
22	ARTIFICIAL LIMB CENTER	2157481000	0.94
23	EMPLOYEES QUARTER TYPE -1	4042748045	0.51

Performance of APFC Installed at Various Locations

Performance of APFC Panels				
S.NO.	DEPARTMENT/PLACE	A/C NO.	CAPACITY IN (KVAR)	WORKING STATUS
1	HOSPITAL SUBSTATION	854748100 REGISTRAR,KGMU	800A ,495KVAR*2	OFF
2	QUEEN MARRY HOSPITAL	7547481000 REGISTAR, KGMU	400KVAR 630A	FOUND OK
3	COBALT SUBSTATION	9547481000 REGISTAR,KGMU	Not Available	-----
4	PSYCHIATRIC DEPARTMENT	1747481000 REGISTAR,KGMU	250KVAR *2	FOUND OK
5	TRAUMA CENTRE	5747481000 REGISTAR,KGMU	800A, 450 KVAR 800A, 450 KVAR	OFF FOUND OK
6	OLD MORTUARY SUBSTATION	7747481000 REGISTAR,KGMU	800A,495 KVAR 800A,495 KVAR	OFF
7	CARDIOLOGY DEPARTMENT	2747481000 REGISTAR,KGMU	Not Available	-----
8	NEW MORTUARY SUBSTATION	3747481000 REGISTAR,KGMU	2x495 kVAR	Not Connected
09	OLD DENTAL BUILDING	6747481000 REGISTRA,KGMU	495KVAR 800A	FOUND OK
10	GAUTAM BUDHA HOSTEL	1133332000 REGISTAR,KGMU	Not Available
11	SHATABDI HOSPITAL	1647481000 REGISTRAR,KGMU	3x200 kVAR	OFF
12	C.T.V.S. DEPARTMENT	9747481000 REGISTRAR,KGMU	800A,495KVAR	OFF
13	NEW DENTAL	5134370261 REGISTRAR,KGMU	800A,495KVAR	FOUND OK
14	DENTAL SCIENCE UNIVERSITY	1214770000 REGISTRAR,KGMU	450 KVAR	OK
15	NEW OPD BLOCK	4697779403 REGISTRAR,KGMU	600KVAR	OFF

16	NEW OPD BLOCK	4697779403 REGISTRAR,KGMU	800A,495KVAR	FOUND OK
17	TEACHING BLOCK (KALAM CENTRE)	9753334425 REGISTRAR,KGMU	800A,495KVAR*2	OFF
18	TYPE -5 FACULTY BUILDING (J.N. ROAD)	7200191928 REGISTRAR,KGMU	400KVAR	FOUND OK
19	QMH (NEW 100 BADED HOSPITAL)	4540285915 REGISTRAR,KGMU	450 KVAR	OFF
20	VRIDDHA MANSIK	-----	400A, 250KVAR 400A	OFF
21	SATABADI PHASE1	----	400A,200KVAR*3	OFF
22	SATABADI PHASE 2	-----	630A,300KVAR*4	OFF
23	T.G HOSTEL CAMPUS	7077481000	450KVAR,800A	FOUND OK
24	T.G EMPLOYEE RESIDENCE TYPE 2	6357245033	250KVAR,400A	OFF
25	COVID HOSPITAL PREMISES	2157481000	2x 550KVAR	01 is ON and another is OFF
26	EMPLOYEE RESIDENCE TYPE-1	4042748045	400A,250KVAR	FOUND OK

Recommendations for Power Factor Improvement

Table : PF Improvement Recommendation for New Mortuary Department

Particulars	UoM	NEW MORTUARY DEPARTMENT
		A/C NO:- 3747481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	664
Power factor corresponding to maximum demand	pf	0.95
Maximum Demand Recorded from Apr-21 Mar'22	kW	627
Sanctioned Load/Contract Demand	KVA	223
% Utilization of Maximum Demand	%	298%
Operating PF avg.	PF	0.95
Annual Unit Consumed	kVAh	1441199
Annual Unit Consumed	kWh	1365114
Annual Energy Billed	Rs.	16324531
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.329
Penalty Charges	Rs./kVA	760
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	206
Capacitor Bank Size Required	kVAR	210
Saving in Maximum demand by improving the power factor close to unity	KW	63
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	137879
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	145564
Annual Monetary Savings	INR in Lakh	10
Percentage Saving in Energy was achieved, if power factor maintained	%	10%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	10.5
Payback Period	Months	12

The PF improvement will reduce the kVA demand. Besides the sanctioned load needs to be extended or need to explore the other possibilities like taking power from other less utilised contract demand meters.

Table : PF Improvement Recommendation for CTVS Departments

Particulars	UoM	C.T.V.S DEPARTMENT
		A/C NO:- 9747481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	490
Power factor corresponding to maximum demand	pf	0.85
Maximum Demand Recorded from Apr-21 Mar'22	kW	418
Sanctioned Load/Contract Demand	KVA	445
% Utilization of Maximum Demand	%	110%
Operating PF avg.	PF	0.87
Annual Unit Consumed	kVAh	1352125
Annual Unit Consumed	kWh	1171415
Annual Energy Billed	Rs.	14281417
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.567
Penalty Charges	Rs./kVA	760
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	237
Capacitor Bank Size Required	kVAR	240
Saving in Maximum demand by improving the power factor close to unity	KW	104
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	290432
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	335236
Annual Monetary Savings	INR in Lakh	24
Percentage Saving in Energy was achieved, if power factor maintained	%	25%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	12.0
Payback Period	Months	6

The PF improvement will reduce the KVA demand . Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilised contract demand meters.

Table : PF Improvement Recommendation for New Dental Extension Block

Particulars	UoM	NEW DENTAL EXTENSION BLOCK
		A/C NO:- 5134370261
Maximum Demand Recorded from Apr-21 Mar'22	kVA	664
Power factor corresponding to maximum demand	pf	0.92
Maximum Demand Recorded from Apr-21 Mar'22	kW	608
Sanctioned Load/Contract Demand	KVA	737
% Utilization of Maximum Demand	%	90%
Operating PF avg.	PF	0.91
Annual Unit Consumed	kVAh	696110
Annual Unit Consumed	kWh	634710
Annual Energy Billed	Rs.	9315074
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.456
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	277
Capacitor Bank Size Required	kVAR	280
Saving in Maximum demand by improving the power factor close to unity	KW	102
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	105973
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	116225
Annual Monetary Savings	INR in Lakh	8
Percentage Saving in Energy was achieved, if power factor maintained	%	17%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	14.0
Payback Period	Months	20

The PF improvement will reduce the KVA demand .

Table : PF Improvement Recommendation for Psychiatric Department

Particulars	UoM	PSYCHIATRIC DEPARTMENT
		A/C NO:- 1747481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	211
Power factor corresponding to maximum demand	pf	0.74
Maximum Demand Recorded from Apr-21 Mar'22	kW	157
Sanctioned Load/Contract Demand	KVA	158
% Utilization of Maximum Demand	%	134%
Operating PF avg.	PF	0.84
Annual Unit Consumed	kVAh	207066
Annual Unit Consumed	kWh	173050
Annual Energy Billed	Rs.	2413829
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.646
Penalty Charges	Rs./kVA	760
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	101
Capacitor Bank Size Required	kVAR	110
Saving in Maximum demand by improving the power factor close to unity	KW	47
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	51944
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	62154
Annual Monetary Savings	INR in Lakh	4
Percentage Saving in Energy was achieved, if power factor maintained	%	30%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	5.5
Payback Period	Months	15

The PF improvement will reduce the KVA demand . Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilised contract demand meters.

Table : PF Improvement Recommendation for Queen Marry Hospital

Particulars	UoM	QUEEN MARRY HOSPITAL
		A/C NO:- 7547481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	317
Power factor corresponding to maximum demand	pf	0.91
Maximum Demand Recorded from Apr-21 Mar'22	kW	290
Sanctioned Load/Contract Demand	KVA	411
% Utilization of Maximum Demand	%	77%
Operating PF avg.	PF	0.94
Annual Unit Consumed	kVAh	1058256
Annual Unit Consumed	kWh	991896
Annual Energy Billed	Rs.	11095144
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.363
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	105
Capacitor Bank Size Required	kVAR	110
Saving in Maximum demand by improving the power factor close to unity	KW	35
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	118752
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	126697
Annual Monetary Savings	INR in Lakh	9
Percentage Saving in Energy was achieved, if power factor maintained	%	12%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	2.8
Payback Period	Months	4

The PF improvement will reduce the KVA demand .

Table : PF Improvement Recommendation for Trauma Center

Particulars	UoM	TRAUMA CENTER
		A/C NO:- 5747481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	470
Power factor corresponding to maximum demand	pf	0.88
Maximum Demand Recorded from Apr-21 Mar'22	kW	413
Sanctioned Load/Contract Demand	KVA	540
% Utilization of Maximum Demand	%	87%
Operating PF avg.	PF	0.91
Annual Unit Consumed	kVAh	2260060
Annual Unit Consumed	kWh	2047570
Annual Energy Billed	Rs.	23718901
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.456
Penalty Charges	Rs./kVA	760
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	188
Capacitor Bank Size Required	kVAR	220
Saving in Maximum demand by improving the power factor close to unity	KW	73
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	363557
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	401286
Annual Monetary Savings	INR in Lakh	28
Percentage Saving in Energy was achieved, if power factor maintained	%	18%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	11.0
Payback Period	Months	5

The PF improvement will reduce the KVA demand .

Table : PF Improvement Recommendation for Old Mortuary Substation

Particulars	UoM	OLD MORTUARY SUBSTATION
		A/C NO:- 7747481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	894
Power factor corresponding to maximum demand	pf	0.94
Maximum Demand Recorded from Apr-21 Mar'22	kW	841
Sanctioned Load/Contract Demand	KVA	1087
% Utilization of Maximum Demand	%	82%
Operating PF avg.	PF	0.93
Annual Unit Consumed	kVAh	2498620
Annual Unit Consumed	kWh	2328660
Annual Energy Billed	Rs.	25245761
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.395
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	332
Capacitor Bank Size Required	kVAR	335
Saving in Maximum demand by improving the power factor close to unity	KW	109
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	301972
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	324012
Annual Monetary Savings	INR in Lakh	23
Percentage Saving in Energy was achieved, if power factor maintained	%	13%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	16.8
Payback Period	Months	9

The PF improvement will reduce the KVA demand .

Table : PF Improvement Recommendation for Techning Block (Kalam Centre)

Particulars	UoM	TEACHING BLOCK (KALAM CENTER)
		A/C NO:- 9753334424
Maximum Demand Recorded from Apr-21 Mar'22	kVA	3132
Power factor corresponding to maximum demand	pf	0.86
Maximum Demand Recorded from Apr-21 Mar'22	kW	2687
Sanctioned Load/Contract Demand	KVA	2632
% Utilization of Maximum Demand	%	119%
Operating PF avg.	PF	0.85
Annual Unit Consumed	kVAh	8125100
Annual Unit Consumed	kWh	6891140
Annual Energy Billed	Rs.	82348508
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.62
Penalty Charges	Rs./kVA	760
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	1666
Capacitor Bank Size Required	kVAR	1675
Saving in Maximum demand by improving the power factor close to unity	KW	750
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	1924247
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	2268812
Annual Monetary Savings	INR in Lakh	161
Percentage Saving in Energy was achieved, if power factor maintained	%	28%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	41.9
Payback Period	Months	3

The PF improvement will reduce the KVA demand . Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilised contract demand meters.

Table : PF Improvement Recommendation for New OPD Block

Particulars	UoM	NEW OPD BLOCK
		A/C NO:- 4697779403
Maximum Demand Recorded from Apr-21 Mar'22	kVA	593
Power factor corresponding to maximum demand	pf	0.93
Maximum Demand Recorded from Apr-21 Mar'22	kW	553
Sanctioned Load/Contract Demand	KVA	698
% Utilization of Maximum Demand	%	85%
Operating PF avg.	PF	0.94
Annual Unit Consumed	kVAh	702161
Annual Unit Consumed	kWh	661996
Annual Energy Billed	Rs.	8630386
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.363
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	201
Capacitor Bank Size Required	kVAR	210
Saving in Maximum demand by improving the power factor close to unity	KW	60
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	72390
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	76782
Annual Monetary Savings	INR in Lakh	5
Percentage Saving in Energy was achieved, if power factor maintained	%	11%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	10.5
Payback Period	Months	23

The PF improvement will reduce the KVA demand .

Table : PF Improvement Recommendation for Cancer Unit

Particulars	UoM	CANCER UNIT
		A/C NO:- 4747481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	45
Power factor corresponding to maximum demand	pf	0.91
Maximum Demand Recorded from Apr-21 Mar'22	kW	41
Sanctioned Load/Contract Demand	KVA	112
% Utilization of Maximum Demand	%	40%
Operating PF avg.	PF	0.85
Annual Unit Consumed	kVAh	54932
Annual Unit Consumed	kWh	46493
Annual Energy Billed	Rs.	955362
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.62
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	25
Capacitor Bank Size Required	kVAR	30
Saving in Maximum demand by improving the power factor close to unity	KW	12
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	13121
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	15503
Annual Monetary Savings	INR in Lakh	1
Percentage Saving in Energy was achieved, if power factor maintained	%	28%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	1.5
Payback Period	Months	16

The Highest MD in a particular month is even less than 75% of the contract demand ; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.

Table : PF Improvement Recommendation for Old Dental

Particulars	UoM	OLD DENTAL
		A/C NO:- 6747481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	249
Power factor corresponding to maximum demand	pf	0.76
Maximum Demand Recorded from Apr-21 Mar'22	kW	189
Sanctioned Load/Contract Demand	KVA	445
% Utilization of Maximum Demand	%	56%
Operating PF avg.	PF	0.67
Annual Unit Consumed	kVAh	436686
Annual Unit Consumed	kWh	292674
Annual Energy Billed	Rs.	5446777
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		1.108
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	209
Capacitor Bank Size Required	kVAR	210
Saving in Maximum demand by improving the power factor close to unity	KW	104
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	160945
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	240138
Annual Monetary Savings	INR in Lakh	17
Percentage Saving in Energy was achieved, if power factor maintained	%	55%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	10.5
Payback Period	Months	7

The Highest MD in a particular month is even less than 75% of the contract demand ; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.

Table : PF Improvement Recommendation for Gautam Buddha Hospital

Particulars	UoM	GAUTAM BUDHA HOSPITAL
		A/C NO:- 1133332000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	207
Power factor corresponding to maximum demand	pf	0.98
Maximum Demand Recorded from Apr-21 Mar'22	kW	203
Sanctioned Load/Contract Demand	KVA	667
% Utilization of Maximum Demand	%	31%
Operating PF avg.	PF	0.91
Annual Unit Consumed	kVAh	797148
Annual Unit Consumed	kWh	722868
Annual Energy Billed	Rs.	9503066
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.456
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	93
Capacitor Bank Size Required	kVAR	100
Saving in Maximum demand by improving the power factor close to unity	KW	36
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	127250
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	140325
Annual Monetary Savings	INR in Lakh	10
Percentage Saving in Energy was achieved, if power factor maintained	%	18%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	5.0
Payback Period	Months	6

The Highest MD in a particular month is even less than 75% of the contract demand ; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.

Table : PF Improvement Recommendation for Shatabdi Hospital

Particulars	UoM	SHATABDI HOSPITAL
		A/C NO:- 1647481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	808
Power factor corresponding to maximum demand	pf	0.82
Maximum Demand Recorded from Apr-21 Mar'22	kW	665
Sanctioned Load/Contract Demand	KVA	1334
% Utilization of Maximum Demand	%	61%
Operating PF avg.	PF	0.82
Annual Unit Consumed	kVAh	2966380
Annual Unit Consumed	kWh	2442180
Annual Energy Billed	Rs.	29862976
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.698
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	464
Capacitor Bank Size Required	kVAR	470
Saving in Maximum demand by improving the power factor close to unity	KW	213
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	783554
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	951739
Annual Monetary Savings	INR in Lakh	68
Percentage Saving in Energy was achieved, if power factor maintained	%	32%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	23.5
Payback Period	Months	4

The Highest MD in a particular month is even less than 75% of the contract demand ; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.

Table : PF Improvement Recommendation for T G Hostel

Particulars	UoM	T G HOSTEL
		A/C NO:- 7077481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	213
Power factor corresponding to maximum demand	pf	0.99
Maximum Demand Recorded from Apr-21 Mar'22	kW	211
Sanctioned Load/Contract Demand	KVA	198
% Utilization of Maximum Demand	%	108%
Operating PF avg.	PF	0.92
Annual Unit Consumed	kVAh	551930
Annual Unit Consumed	kWh	509980
Annual Energy Billed	Rs.	5650776
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.456
Penalty Charges	Rs./kVA	760
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	96
Capacitor Bank Size Required	kVAR	100
Saving in Maximum demand by improving the power factor close to unity	KW	31
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	73705
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	79768
Annual Monetary Savings	INR in Lakh	6
Percentage Saving in Energy was achieved, if power factor maintained	%	14%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	5.0
Payback Period	Months	11

The PF improvement will reduce the KVA demand . Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilised contract demand meters.

Table : PF Improvement Recommendation for T G Hostel Residential Type 2

Particulars	UoM	T G HOSTEL RESIDENTIAL TYPE 2
		A/C NO:- 6357245033
Maximum Demand Recorded from Apr-21 Mar'22	kVA	124
Power factor corresponding to maximum demand	pf	0.83
Maximum Demand Recorded from Apr-21 Mar'22	kW	103
Sanctioned Load/Contract Demand	KVA	334
% Utilization of Maximum Demand	%	37%
Operating PF avg.	PF	0.80
Annual Unit Consumed	kVAh	585694
Annual Unit Consumed	kWh	470076
Annual Energy Billed	Rs.	5400134
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.75
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	77
Capacitor Bank Size Required	kVAR	80
Saving in Maximum demand by improving the power factor close to unity	KW	37
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	166665
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	207657
Annual Monetary Savings	INR in Lakh	15
Percentage Saving in Energy was achieved, if power factor maintained	%	35%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	4.0
Payback Period	Months	3

The Highest MD in a particular month is even less than 75% of the contract demand ; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvemnet will reduce the kVA demand further.

Table : PF Improvement Recommendation for Artificial Limb Center(RALC BUILDING)

Particulars	UoM	ARTIFICIAL LIMB CENTER (RALC BUILDING)
		A/C NO:- 2157481000
Maximum Demand Recorded from Apr-21 Mar'22	kVA	305
Power factor corresponding to maximum demand	pf	0.93
Maximum Demand Recorded from Apr-21 Mar'22	kW	284
Sanctioned Load/Contract Demand	KVA	334
% Utilization of Maximum Demand	%	91%
Operating PF avg.	PF	0.94
Annual Unit Consumed	kVAh	878065
Annual Unit Consumed	kWh	822685
Annual Energy Billed	Rs.	9102897
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		0.363
Penalty Charges	Rs./kVA	
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	103
Capacitor Bank Size Required	kVAR	105
Saving in Maximum demand by improving the power factor close to unity	KW	34
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	99055
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	105723
Annual Monetary Savings	INR in Lakh	8
Percentage Saving in Energy was achieved, if power factor maintained	%	12%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	5.3
Payback Period	Months	8

The PF improvement will reduce the KVA demand .

Table : PF Improvement Recommendation for Employees Quarter Type-1

Particulars	UoM	EMPLOYEES QUARTER TYPE -1
		A/C NO:- 4042748045
Maximum Demand Recorded from Apr-21 Mar'22	kVA	99
Power factor corresponding to maximum demand	pf	0.29
Maximum Demand Recorded from Apr-21 Mar'22	kW	28
Sanctioned Load/Contract Demand	KVA	78
% Utilization of Maximum Demand	%	127%
Operating PF avg.	PF	0.51
Annual Unit Consumed	kVAh	302890
Annual Unit Consumed	kWh	154676
Annual Energy Billed	Rs.	3358346
Energy Cost as per existing Tariff	Rs./kVAh	7.1
Desired PF (nearby unity)	PF	0.999
PF correction		1.687
Penalty Charges	Rs./kVA	760
Capacitors Required for maintaining nearby unity pf at every load condition	kVAR	48
Capacitor Bank Size Required	kVAR	50
Saving in Maximum demand by improving the power factor close to unity	KW	21
Avg. Annual saving has been achieved on improving power factor to nearby unity	kWh	114259
Avg. Annual saving has been achieved on improving power factor to nearby unity	kVAh	223744
Annual Monetary Savings	INR in Lakh	16
Percentage Saving in Energy was achieved, if power factor maintained	%	74%
Investments Required for the capacitor Bank (APFC Panel)	INR in Lakh	2.5
Payback Period	Months	2

The PF improvement will reduce the KVA demand . Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilised contract demand meters.

Ref :

1. kVA Selection Chart ; [Ch-01_gopsons.qxd \(beeindia.gov.in\)](#)
2. The Above Rate and Charges as approved by U.P. Electricity Regulatory Commission

Maximum Demand Analysis

The MD analysis for the period April 2021 to March 2022 has been done as below

S. N.	Location	Contract Demand, kVA	Highest Value of MD During the Year , kVA	Annual Excess Demand Penalty Paid (Rs.)	Remarks
1	New Mortuary Department	223	664	1923373.6	Excess demand penalty is found in all months except July, Nov, Dec 2021 and Feb 2022. The meter connection date is 1st Jan 2001 and over the years the load has increased. The PF improvement will reduce the kVA demand. Besides the sanctioned load needs to be extended or need to explore the other possibilities like taking power from other less utilized contract demand meters.
2	C.T.V.S DEPARTMENT	445	490	262713	Excess demand penalty is found in April, June, July, Aug and Sept 2021. The PF improvement will reduce the KVA demand. Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilized contract demand meters.
3	Hospital Substation	1137	953	0	NIL
4	New Dental Extension Block	737	664	0	The PF improvement will reduce the KVA demand.
5	Cobalt Substation	659	620	0	NIL
6	PSYCHIATRIC DEPARTMENT	158	211	80620.8	Excess demand penalty is found in Oct 2021 and Feb 2022. The PF improvement will reduce the KVA demand. Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilized contract demand meters.
7	Queen Mary Hospital	411	317	0	The PF improvement will reduce the KVA demand.
8	QMH (New 100 Bedded)	333	91	0	The Highest MD in a particular month is even less than 75% of the contract demand; the meter connection date is 27th April 2019; the load balancing is needed as per the requirement
9	Trauma Center	540	470	0	The PF improvement will reduce the KVA demand.

10	Old Mortuary Substation	1087	894	0	The PF improvement will reduce the KVA demand.
11	TEACHING BLOCK (KALAM CENTER)	2632	3145	931000	Excess demand penalty is found in April, Sept and Oct 2021. The PF improvement will reduce the KVA demand. Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilized contract demand meters.
12	Dental Science University	45	78	88344	Excess demand penalty is found from May to Oct 2021. The sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilized contract demand meters.
13	New OPD Block	698	593	0	The PF improvement will reduce the KVA demand.
14	Cancer Unit	112	45	0	The Highest MD in a particular month is even less than 75% of the contract demand; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.
15	Type 5 Faculty Building	444	513	6732	Excess demand penalty found in Feb 2022. The meter connection date is 16th Feb 2005. The sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilized contract demand meters.
16	Old Dental	445	249	0	The Highest MD in a particular month is even less than 75% of the contract demand; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.
17	Gautam Buddha HOSPITAL	667	207	0	The Highest MD in a particular month is even less than 75% of the contract demand; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.
18	Shatabdi Hospital	1334	808	0	The Highest MD in a particular month is even less than 75% of the contract demand; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.
19	Cardiology Department	223	134	0	NIL

20	T. G Hostel	198	213	11400	Excess demand penalty found in Jan 2022. The PF improvement will reduce the KVA demand. Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less utilized contract demand meters.
21	T. G Residential Type 2	334	124	0	The Highest MD in a particular month is even less than 75% of the contract demand; if there is no plan for the further extension of load in near future the contract demand reduction is suggested. The PF improvement will reduce the kVA demand further.
22	Artificial LIMB Center	334	305	0	The PF improvement will reduce the KVA demand.
23	Employees Quarter	78	99	5979.32	Excess demand penalty found in May, Aug 2021 and Jan 2022. The PF improvement will reduce the KVA demand. Besides the sanctioned load may need to be extended or need to explore the other possibilities like taking power from other less contract demand utilized meters.

Observations :-

1. Some of the meters have lower sanctioned load than actual demand and these connections are paying MD penalty charges A total of Rs. 33.10 Lac penalty on MD extra charges have been paid by the hospital during April 2021-March 2022
2. There are some meters where the Maximum Demand in a particular month even less than 75% of the contract demand .

Transformers Study

About 25 No. of transformers are installed at KGMU to meet their power requirement. Capacity details of Transformer are summarized in below table:-

Table 1 Transformer details installed at KGMU

S.NO.	NAME OF SUBSTATION	T/F-1	T/F-2	T/F-3	T/F-4	TRANSFORMER MAKE
1	TEACHING BLOCK	1000KVA	1000KVA	-----	-----	CG-MAKE 250+250=500
2	OLD MURCHARY	1000KVA	1000KVA	-----	-----	CG-MAKE 350LTRS.
3	NEW MURCHARY	1000KVA	630KVA	-----	-----	ALSTOM LTD. 250LTRS.
4	HOSPITAL MAIN BUILDING	1000KVA	1000KVA	-----	-----	ALSTOM LTD.600LTRS.
5	TRAUMA CENTRE	800KVA	800KVA	-----	-----	ALSTOM LTD.500LTRS.
6	TRAUMA CENTRE 2nd FLOOR	750KVA	-----	-----	-----	CG-MAKE
7	DENTAL OLD (DENTAL VIGYAN)	630KVA	-----	-----	-----	ALSTOM
8	NEW DENTAL (DENTAL UNIVERSITY)	750KVA	750KVA	-----	-----	CG-MAKE 200LTRS.
9	PSYCHIATRY DEPTT.	750KVA	750KVA	-----	-----	GREAVES
10	QUEEN MARRY	630KVA	-----	-----	-----	AREVA
11	SHATABDI PHASE 2nd	1250KVA	1250KVA	1250KVA	1250KVA	CG-MAKE 300LTRS.
12	GAUTAM BUDDHA HOSTEL	630KVA	1000KVA	-----	-----	AREVA 300+150=450LTRS.
13	C.T.V.S.	750KVA	750KVA	-----	-----	CG-MAKE 300LTRS.
14	TYPE-5 QUARTER (JAGAT NARAYAN ROAD)	630KVA	-----	-----	-----	KIRLOSKER-MAKE
15	R.A.L.C. DEPTT.	1000KVA	1000KVA	-----	-----	KIRLOSKER-MAKE
16	SERVANT QUARTER, TYPE-1 (RALC)	400KVA	-----	-----	-----	MIRZAPUR ELECTRICAL INDUSTRIES
17	NEW O.P.D.	750KVA	630KVA	-----	-----	ABB& KIRLOSKER-MAKE
18	T.G. HOSTEL	800KVA	400KVA	400KVA	-----	ALSTOM, AREVA & MIRZAPUR ELECTRICAL INDUSTRIAL LTD.

19	SATABDI PHASE 1st	750KVA	750KVA	750KVA	-----	AREVA-MAKE
20	33/11KV SUBSTATION	5000KVA	5000KVA	-----	-----	SCHNIEDER-MAKE
21	NEW GIRLS HOSTEL	400KVA	-----	----	----	CG-MAKE
22	SKILL DEPTT.	400KVA	-----	----	----	SAINATH INDUSTRIES
23	LORI CARDIOLOGY DEPTT.	400KVA	-----	-----	-----	BY LEASA (LESA TRANSFORMER)
24	COBALT	1000KVA	----	----	----	SERVOKON
25	PHI BUILDING(HYGIENE)	250KVA	-----	----	----	BY LEASA (LESA TRANSFORMER)

To ascertain the loading on the transformer's, hourly loading pattern has been developed of loading Transformer. The typical loading pattern is discussed below:-

Table 2 Transformer Analysis

Location	UoM	New 100 Bedded Hospital	Main hospital TR--1	Queen Marry Hospital	RALC TR-1
Transformer Capacity	kVA	630	1000	630	1000
No load Voltage, LV	V	433			433
Measurements					
V avg.	V	424	397	410	419
V min.	V	422	397	412	418
V max	V	424	398	413	419
I avg.	A	125	659	253	576
I min.	A	122	644	251	577
I max.	A	145	672	254	579
PF avg.		0.99	0.98	0.81	0.82
PF min.		0.98	0.98	0.8	0.82
PF max.		0.99	0.98	0.81	0.83
Apparent Power avg.	kVA	91.8	453.1	189.0	445.2
Apparent Power min.	kVA	89.2	442.8	193.4	428.2
Apparent Power max.	kVA	106.5	463.2	186.3	425.3

Loading (%) avg	%	15%	45%	30%	45%
Loading (%) min	%	14%	44%	31%	43%
Loading (%) max	%	17%	46%	30%	43%
Voltage THD avg.	%f	1.06	1.1	1.8	5.4
Voltage THD min.	%f	1.04	1.13	1.8	5.23
Voltage THD max.	%f	1.15	1.15	1.99	5.6
Current THD avg.	%f	5.08	3.9	4.8	37.88
Current THD min.	%f	3.08	3.5	3.6	21.6
Current THD max.	%f	4.6	4.1	5.2	39

Observations & Recommendations

- New 100 Bedded Hospital, Main Hospital TR-1, Queen Marry Hospital & RALC TR-1 transformer is installed with rated capacity of 630kVA, 1000KVA, 630KVA & 1000KVA respectively. During Audit team noticed maximum loading on these transformers are about 17%, 46%, 30% & 43% respectively. It shows the transformer is optimally loaded except New 100 Bedded Hospital.




Figure : % Loading of the Transformer

- It is evident from Table 2 above that Power factor of New 100 Bedded Hospital, Main Hospital TR-1, Queen Marry Hospital & RALC TR-1 transformer is about 0.99, 0.98, 0.81 & 0.82 respectively. Higher power factor of New 100 Bedded Hospital & Main Hospital TR-1 because of operation of APFC panel. Thus, Audit team recommends Power factor improvement for Transformers installed at Queen Marry Hospital & RALC.

- It is evident from the above figure that the maxm. voltage THD (%) for New 100 Bedded Hospital, Main Hospital TR-1 & Queen Marry Hospital transformer was observed to be in range of 1.0% to 2.0% which is in the prescribed limit as per IEE standard of Voltage harmonics of 5%.

However, voltage THD (%) for RALC TR-1 transformer was varied in range from 5.2% to 5.6% with average voltage THD (%) noticed to be about 5.4% which is slightly on higher side of prescribed limit as per IEE standard of Voltage harmonics of 5%.




Figure : Voltage THD profile (%)

Table 3 Transformer Analysis

Location	UoM	New OPD		CTVS		Gautam Buddha Hostel	
		AC Plant	TR-1	TR- 1	TR-2	TR- 1	TR-2
Transformer Capacity	kVA	750	630	750	750	630	1000
No load Voltage, LV	V	433	433				
Measurements							
V avg.	V	400	404	400	400	416	396
V min.	V	400	404	409	400	414	394
V max	V	401	405	409	400	416	396
I avg.	A	398	110	243	186	39.18	109
I min.	A	389	111	239	184	37.19	108
I max.	A	399	114	245	190	41.97	112
PF avg.		0.86	0.9	0.9	0.9	0.92	0.93
PF min.		0.87	0.9	0.89	0.9	0.92	0.92

PF max.		0.87	0.92	0.9	0.91	0.92	0.93
Apparent Power avg.	kVA	304.0	99.0	216.5	170.6	32.9	98.4
Apparent Power min.	kVA	312.6	102.8	212.2	173.8	30.8	67.8
Apparent Power max.	kVA	294.0	106.6	211.1	176.2	27.8	99.2
Loading (%) avg	%	41%	16%	29%	23%	5%	10%
Loading (%) min	%	42%	16%	28%	23%	5%	7%
Loading (%) max	%	39%	17%	28%	23%	4%	10%
Voltage THD avg.	%f	1.5	1.7	1.29	1.52	1.32	1.52
Voltage THD min.	%f	1.4	1.5	1.26	1.5	1.3	1.5
Voltage THD max.	%f	1.58	1.7	1.4	1.54	1.34	1.58
Current THD avg.	%f	2.1	2.2	5.8	3.1	10.25	4.9
Current THD min.	%f	2.2	2.1	5.2	2.79	8.6	4.5
Current THD max.	%f	2.3	2.4	5.92	3.13	12.6	5.2

Observations & Recommendations

- New OPD having rated capacity of AC Plant Transformer (750KVA) & TR-1 (630KVA), CTVS TR-1 & 2 each having of 750kVA & Gautam Buddha Hostel (TR-1 & 2) having capacity of 630KVA & 1000kVA respectively. From Above table team noticed Gautam Buddha Hostel transformer TR-1 & 2 having maximum loading of 5% and 10% respectively, which on lower side. Thus, recommends transferring load on one transformer to another based on possibility.




Figure : % Loading of the Transformer

- It is evident from Table above that Average Power factor of New OPD AC Plant & TR-1, CTVS TR-1 & 2 & Gautam Buddha Hostel TR-1 & 2 are about 0.87, 0.9, 0.89, 0.9, 0.92 & 0.92 respectively. Lower power factor was noticed across the transformers. Thus, Audit team recommends improvement of Power Factor for energy savings.
- It is evident from the above figure that the maxm. voltage THD (%) for New OPD AC Plant & TR-1, CTVS TR-1 & 2 & Gautam Buddha Hostel TR-1 & 2 are about 1.58%, 1.7%, 1.4%, 1.54%, 1.34% & 1.58% respectively, which is in the prescribed limit as per IEE standard of Voltage harmonics of 5%.




Figure : Voltage THD profile (%f)

Table 4 : Transformer Analysis

Shatabdi						
Location	UoM	Phase-1 (TR-1)	Phase-1 (TR-3)	Phase-2 (TR-1)	Phase-2 (TR-2)	Phase-2 (TR-4)
Transformer Capacity	kVA	750	750	1250	1250	1250
No load Voltage, LV	V					
Measurement						
V avg.	V	402	422	410	405	422
V min.	V	400	420	409	402	422
V max	V	403	425	410	405	422
I avg.	A	236	396	242	990	318
I min.	A	230	383	240	886	316
I max.	A	239	406	244	992	322
PF avg.		0.89	0.88	0.85	0.82	0.84

PF min.		0.88	0.87	0.85	0.82	0.84
PF max.		0.9	0.88	0.85	0.82	0.84
Apparent Power avg.	kVA	170.1	268.1	171.8	694.4	424.4
Apparent Power min.	kVA	159.3	255.1	170.0	616.9	461.9
Apparent Power max.	kVA	170.6	276.8	173.3	695.8	411.9
Loading (%) avg	%	23%	36%	14%	56%	34%
Loading (%) min	%	21%	34%	14%	49%	37%
Loading (%) max	%	23%	37%	14%	56%	33%
Voltage THD avg.	%f	1.37	1.7	1.6	1.8	2.28
Voltage THD min.	%f	1.3	1.6	1.6	1.6	2.2
Voltage THD max.	%f	1.51	1.73	1.7	2.6	2.37
Current THD avg.	%f	3.39	4.1	2.2	4.6	2.29
Current THD min.	%f	3.33	3.9	2.2	4.2	2.2
Current THD max.	%f	3.49	4.14	2.3	5.4	2.31

Observations & Recommendations

- Maximum loading of Shatabdi phase- 1 TR-1 & 2 and phase- 2 TR 1, 2 & 4 are about 23%, 37%, 14%, 56% and 37% respectively, which is optimally loaded except Phase 2 Transformer 1. Thus, recommends transfer of load of TR1 to TR 2 & 4, if loading pattern on these transformers varied in same range, this will reduce the loading loss of Pase 2 TR 1.




Figure : % Loading of the Transformers

- It is evident from table that Average Power factor of Shatabdi phase- 1 TR-1 & 2 and phase- 2 TR 1, 2 & 4 are about 0.89, 0.88, 0.85, 0.82 & 0.84 respectively. Lower power factor was noticed across the transformers. Thus, Audit team recommends Power factor improvement which will lead to energy savings.




Figure : Power factor profile of the Transformer

- It is evident from the above table that maxm. voltage THD (%) of Shatabdi phase- 1 TR-1 & 2 and phase- 2 TR 1, 2 & 4 are about 1.51%, 1.73%, 1.7%, 2.6% & 2.37% respectively, which is in the prescribed limit as per IEE standard of Voltage harmonics of 5%.

Table 5: Transformer Analysis

Location	UoM	New Dental TR- 1	Psychiatric Department	Kalam Centre TR-1	TG Hostel TR- 1	TG Hostel TR-3
Transformer Capacity	kVA	750	750	1000	400	400
No load Voltage, LV	V			433	433	433
Measurement						
V avg.	V	396	412	407	409	409
V min.	V	396	410	407	408	408
V max	V	397	412	409	411	410
I avg.	A	490	192	175	30	22
I min.	A	482	185	179	27	20
I max.	A	493	198	187	31	24

PF avg.		0.87	0.92	0.84	0.96	0.94
PF min.		0.86	0.9	0.85	0.94	0.92
PF max.		0.88	0.94	0.85	0.96	0.96
Apparent Power avg.	kVA	336.1	137.0	123.4	26.8	22.5
Apparent Power min.	kVA	359.9	131.4	126.2	24.2	20.0
Apparent Power max.	kVA	335.2	141.3	132.5	28.6	25.2
Loading (%) avg	%	45%	18%	12%	6.7%	5.6%
Loading (%) min	%	48%	18%	13%	6.1%	5.0%
Loading (%) max	%	45%	19%	13%	7.2%	6.3%
Voltage THD avg.	%f	1.34	1.9	2.1	1.7	1.67
Voltage THD min.	%f	1.32	1.64	2.1	1.66	1.65
Voltage THD max.	%f	1.39	2.1	2.3	1.73	1.7
Current THD avg.	%f	1.8	5.2	8.3	7	11.27
Current THD min.	%f	1.4	4.8	8.2	6.9	10
Current THD max.	%f	1.9	5.61	8.5	7.48	12.4

Observations & Recommendations

- New Dental TR-1, Psychiatric Department, Kalam Centre TR-1 & TG Hostel 1 & 3 transformer is installed with rated capacity of 750kVA, 750KVA, 1000KVA, 400KVA & 400KVA respectively. During Audit team noticed maximum loading on these transformers are about 48%, 19%, 13%, 7.2% & 6.3% respectively. It shows the transformer is optimally loaded except TG Hospital TR 1 & 3. Thus, Team recommends to shift the load on 1 (one) TG transformer, if they having common bus coupler, this will results in saving in load loss.




Figure : % Loading of the Transformer

- It is evident from table that Average Power factor of New Dental TR-1, Psychiatric Department, Kalam Centre TR-1 & TG Hostel 1 & 3 transformer are about 0.87, 0.92, 0.84, 0.96 & 0.94 respectively. Lower power factor was noticed across the transformers. Thus, Audit team recommends installation of Power factor and increase the power factor 0.99 at every load condition will results in energy savings.




Figure : Power factor profile of the Transformer

- It is evident from the above Table 5 that maximum voltage THD (%) of New Dental TR-1, Psychiatric Department, Kalam Centre TR-1 & TG Hostel 1 & 3 transformer are about 1.39%, 2.1%, 2.3%, 1.73% & 1.7% respectively, which is in the prescribed limit as per IEE standard of Voltage harmonics of 5%. It is also noticed from above table that Maximum Current THD (%) are about 1.9%, 5.6%, 8.5%, 7.5% & 12.4% respectively. Slightly higher Current THD is due to low load.

Pumps

Monoblock Pumps at New OPD

Pump Identification	Unit	Pump 1	Pump 2
Rated Parameters			
Running Status		Running	Running
Pump Make		Kirloskar	Kirloskar
Speed	RPM	1480	1480
Rated Flow	m ³ /hr	54	54
Rated Head	M	32	32
Rated Power	KW	11.18	11.18
Motor Efficiency	%	95.0	95.0
Parameters Measured			
Measured Flow	m ³ /hr	48.12	51.2
Discharge Pressure (A)	Kg/cm ²	3.4	3.4
Suction Pressure (B)	Kg/cm ²	0.3	0.3
Fluid Density	Kg/ m ³	1000	1000
Performance Evaluation			
Total Head $(=(A-B) \times 10)$	M	31.0	31.0
Head Utilization	%	96.9	96.9
Flow Utilization	%	89.1	94.8
Measured Input power	KW	11	11
Shaft Power	KW	10	10
Hydraulic Power	KW	4.1	4.3
Pump Efficiency	%	39.0	41.6
Overall (Pump Set) Efficiency	%	37.1	39.5
Throttling Suction	%	Nil	Nil
Throttling Discharge	%	Nil	Nil
Running Hour		6 hour/day	6 hour/day

Monoblock Pumps at Buddha Hostel

Pump Identification	Unit	Pump 1	Pump 2
Rated Parameters			
Running Status		Standby	Running
Pump Make		Kirloskar	Kirloskar
Speed	RPM	2940	2940
Rated Flow	m ³ /hr	60.1	60.1
Rated Head	M	56	56
Rated Power	KW	15	15
Motor Efficiency	%	90.5	90.5
Parameters Measured			
Measured Flow	m ³ /hr		55.4
Discharge Pressure (A)	Kg/cm ²		5.5
Suction Pressure (B)	Kg/cm ²		0.3
Fluid Density	Kg/ m ³		1000
Performance Evaluation			
Total Head $(=(A-B) \times 10)$	M	Tripping Problem Found	52.0
Head Utilization	%		92.9
Flow Utilization	%		92.2
Measured Input power	KW		14
Shaft Power	KW		13
Hydraulic Power	KW		7.9
Pump Efficiency	%		60.0
Overall (Pump Set) Efficiency	%		54.3
Throttling Suction	%		Nil
Throttling Discharge	%		Nil
Running Hour			6 hour/day

Monoblock Pumps at Trauma Center


Pump Identification	Unit	Pump 1	Pump 2	Pump 3
Rated Parameters				
Running Status		Running	Running	Running
Pump Make		Crompton	Kirloskar	Kirloskar
Speed	RPM	-	-	-
Rated Flow	m ³ /hr	26.28	26.28	26.28
Rated Head	M	72	40	40
Rated Power	KW	11	9	9
Motor Efficiency	%	95.0	90.0	90.0
Parameters Measured				
Measured Flow	m ³ /hr	22.1	18.2	18.6
Discharge Pressure (A)	Kg/cm ²	5.8	3.8	3.8
Suction Pressure (B)	Kg/cm ²	-0.1	-0.1	-0.1
Fluid Density	Kg/ m ³	1000	1000	1000
Performance Evaluation				
Total Head $(=(A-B) \times 10)$	M	59.0	39.0	39.0
Head Utilization	%	81.9	97.5	97.5
Flow Utilization	%	84.1	69.3	70.8
Measured Input power	KW	8	8	7
Shaft Power	KW	8	7	7
Hydraulic Power	KW	3.6	1.9	2.0
Pump Efficiency	%	45.6	28.2	29.6
Overall (Pump Set) Efficiency	%	43.3	25.4	26.6
Throttling Suction	%	Nil	Nil	Nil
Throttling Discharge	%	Nil	Nil	Nil
Running Hour		24 hour/day		

Recommendations for Pumps replacement with EE Pumps

Present System	UOM	TRAUMA	
		Pump 2	Pump 3
Pump Efficiency	%	28.20	29.60
Average Power consumption of Pump	KW	8.00	7.00
Operating days per annum	days	365	365
Operating hours per day	hrs	24	24
Energy consumption	KWh	70080.00	61320.00
Proposed System; New Energy Efficient Pumps			
Pump Efficiency	%	50	50
Power consumption	KW	4.51	4.14
Operating days per annum	days	365	365
Operating hours per day	hrs	24	24
Energy consumption	KWh	39525.12	36301.44
Net reduction in power consumption	KWH	30554.88	25018.56
Electric Power Rate	Rs per KWh	13.52	13.52
Monetary Saving for One Pump	Rs Lacs	4.13	3.38
Investment	Rs Lacs	1.50	
Payback Period	months	2.40	

Energy Management System

Integrated Energy Management System (EMS), collect electrical energy consumption as well as helps in monitoring critical indicators on Control Panels. It is also capable of sending Alerts, Alarms, Notifications over Voice/SMS/ Email etc which can be easily configurable by the user himself. The below is the EMS schematics :-



Features :-

- IoT Based System
- Wireless and Retrofit
- Remote Monitoring and Control
- Maintain Energy Efficiency
- Save Energy by Corrective Actions
- Covers All Industrial Electrical Parameters like kVA, kVArH, kWh, kW, PF, Voltage, Current, Harmonics etc
- System Auto Alert on Identified Violation, Area of Loss & Suggest Preventive Steps

Recommendations :

- EMS can be used for better energy management practices including grid and solar pv power. There will be potential to have savings due to Maximum Demand penalty.
- Approximate investment @ Rs.50,000/- per meter connection .
- The savings will be indirect and payback is expected immediately.

Air Conditioning Systems

The importance of Air Conditioning in Hospitals goes beyond the comfort. Air Conditioning and HVAC Systems Control Temperature and Humidity, Ventilation, and Air Filtration, Which All Matter to Hospitals. HVAC units play a significant role in maintaining the safety of hospitals. Most hospitals admit patients with a wide variety of illnesses, some of which are highly dangerous via airborne transmission. In combination with the vulnerable nature of patients, it becomes vital to maintain correct air ventilation and temperature control, as recycled contaminated air moving between wards could prove fatal.



Fig. Chiller system at KGMU



Fig. Window and Split ACs

List of available Window and Split ACs are as below:-

S.NO.	DEPARTMENT NAME	No of Window ACs	No of Split ACs
1	ADMINISTRATIVE BUILDING	5	51
2	VICE CHANCELLOR'S OFFICE	4	14
3	RESEARCH CELL DEPARTMENT	7	4
4	CENTRAL LIBRARY	11	79
5	NEW GUEST HOUSE	0	28
6	OLD GUEST HOUSE	0	7
7	ANATOMY DEPARTMENT	2	42
8	PHI BUILDING	13	26
9	PHYSIOLOGY AND BIOMETRIC	27	28
10	MICROBIOLOGY DEPARTMENT	6	14
11	PATHALOGY DEPARTMENT	44	89
12	SURGERY DEPARTMENT /WARD	17	28
13	UROLOGY DEPARTMENT	34	13
14	PHARMACOLOGY DEPARTMENT	16	16
15	MEDICINE DEPARTMENT	2	0
16	EYE DEPARTMENT(NEW/OLD)	16	13
17	PLASTIC SURGERY DEPARTMENT	46	33
18	CHILD DEPARTMENT	21	23
19	SPM DEPARTMENT	23	15
20	T.B.H DEPARTMENT	3	22
21	SAVICHEEDAN HOUSE	0	7
22	NEW DENTAL FAULTY BUILDING AND DEAN'S OFFICE	1	12
23	OLD DENTAL BUILDING	67	43
24	ELECTRICAL DEPARTMENT	1	2
25	CONSTRUCTION DEPARTMENT	6	4
26	NEW O.P.D BUILDING	0	5
27	OLD O.P.D BUILDING	7	52

28	KALAM CENTRE	0	24
29	FORENSIC MEDICINE	0	29
30	ENVIRONMENT DEPARTMENT	2	8
31	GANDHI WARD	11	18
32	NEUROLOGY DEPARTMENT	31	28
33	RESIDENT HOSTEL	2	5
34	NEHRU P.G HOSTEL	1	2
35	SARDAR PATEL HOSTEL	0	0
36	NEW CV. HOSTEL	0	2
37	OLD CV. HOSTEL	0	0
38	MAHAMAYA HOSTEL	0	0
39	CHATRA CHATRA VAS	0	0
40	DK. HOSTEL	0	0
41	NURSES HOSTEL	0	0
42	PEDIATRIC SURGERY	23	20
43	CENTRAL STORE	0	1
44	L.P. MEDICINE COUNTER	1	3
45	MAIN HOSPITAL BUILDING INCLUDING ALL SURGICAL WARD	33	97
46	PRIVATE DELUXE WARD	0	24
47	INFECTIOUS DISEASES Dept	16	26
48	Center for advance research	0	32
49	H.I.V UNIT	5	10
50	Mental Department	31	14
51	Geriatric Department	50	50
52	Lari Cardiology	44	8
53	Trauma Center	8	20
54	Rheumatology Department	0	56
55	RALC Covid Hospital	0	52
Total		637	1199

Energy Savings Possibilities in Windows and Split ACs

There are 1836 numbers of Window and Split ACs are operating of different make in the KGMU complex in different locations. The 80% of the ACs are of 1.5 TR capacity and these are recommended here for energy savings replacing with higher Star rated ACs; can be undertaken as and when requirement basis.

Energy Savings replacing with higher Star rated ACs

Type of AC	TR	Star Level	Energy Input, kW	Star Level 5 Energy Input, kW	Savings Per AC, kW	Nos Considered	Total Savings Possible, kWh	Amount Savings Possibility
Window	1.5	2	1.95	1.60	0.355253	254.8	135777.52	1832996.45
Window	1.5	3	1.82	1.60	0.220502	254.8	84275.70	1137721.94
Split	1.5	2	1.60	1.17	0.426303	479.6	306682.40	4140212.40
Split	1.5	3	1.51	1.17	0.334952	479.6	240964.74	3253024.03

The savings is calculated with the below considerations: -

Star Level	EER /ISER Window ACs		EER/ISER Split ACs	
	Minimum	Maximum	Minimum	Maximum
1 Star	2.5	2.69	3.1	3.29
2 Star	2.7	2.89	3.3	3.49
3 Star	2.9	3.09	3.5	3.99
4 Star	3.1	3.29	4	4.49
5 Star	3.3	NIL	4.5	NIL
EER Rating= TR Capacity (in BTU)/Input Power in Watt)				
1 TR = 12000 BTU				
Cooling Capacity of 1 TR = 3.517 kW				

Ref: https://www.beestarlabel.com/Content/Files/AC_Notification.pdf

Working Hrs have been calculated considering 06 months, 25 days per month and 10 hrs daily usages

Total AC	Total No	1.5 TR	2 Star	3 Star
Window	637	509.6	254.8	254.8
Split	1199	959.2	479.6	479.6

Again, inverter technology can be used while replacing an AC and there is a potential of about 35% of electricity savings over a standard air conditioner.

Other Air-Conditioned Plant Details

DETAILS OF AIR CONDITIONED PLANTS INSTALLED IN KGMU CAMPUS			
SR NO.	MAKE/MODEL	Plant Details (TON/HP)	PLACE OF INSTALLATION
1	TRAIN PLANT	300*1=300TR.	TRAUMA CENTRE 4th FLOOR; N.ICU PICU 5th FLOOR; CCU DEPTT. & EYE BANK.
2	DAIKIN V.R.V	12*8=96HP 18*1=18HP 24*1=24HP 36*2=72HP 26*1=26HP 30*3=90HP 48*1=48HP	TRAUMA CENTRE G.F; CASULATY,HALL,DENTAL UNIT,EMERGENCY MEICINE (O2ROOM),ORTHO O.T. 1st FLOOR: R.S.O (ABC WARD),HALL, EMERGENCY WARD, TRAUMA SURGERY WARD &O.T,NEURO SURGERY O.T. 2nd FLOOR;MEDICINE STORE,DR. ROOM,MEDICINE 3 ROOM.
3	L.G	03*03=9TON	TRAUMA CENTRE CASULATY EXTENSION
4	VOLTAS PLANT	300*2=600TR.	TRAUMA CENTRE G.F; DIGNOSIS AREA, EMERGENCY MEDICINE 1st FLOOR; R.S.O WARD,NEURO POSTOP, 2nd FLOOR;MEDICINE WARD ,NEUROLOGY WARD & PEDIARTRIC ORTHO WARD & ORTO WARD, 3rdFLOOR;NEURO SURGERY ,TRAUMA SURGERY VENTILTOR UNIT (C.C.U).
5	TRAIN PLANT	175*4=700TR.	SHATABDI PHASE-1
6	TRAIN PLANT	400*5=2000TR.	SHATABDI PHASE-2
7	BLUE STAR PLANT	250*2=500TR. 300*1=300TR.	C.T.V.S.
8	BLUE STAR PLANT	280*2=560TR. 320*1=320TR.	KALAM CENTRE
9	DAIKIN DUCTABLE	11*3=33TR. 16*2=32TR.	QUEEN MARY O.T &POST OPERATIVE
10	DAIKIN VOLTAS HITACHI	8.5*3=25.5TR. 8.5*2=17TR. 3*2=6TR. 5.5*5=27.5TR.	LARI CARDIOLOGY DEPARTMENT ICU & OPD
11	MIITSUBISHI V.R.V	6*2=12HP	ANIMAL HOUSE PHARMACOLOGY
12	MIITSUBISHI V.R.V	20HP*1=20HP 12HP*1=12HP 6HP*1=6HP 14HP*1=14HP	GANDHI WARD MEDICINE ICU & DR. ROOM.
13	MIITSUBISHI V.R.V	22*2=44HP 14*2=28HP	SURGERY GENERAL O.T & POST OPERATIVE
14	DAIKIN V.R.F	30*1=30HP 28*1=28HP	PEDIARTRIC ONCOLOGY 2nd FLOOR & 3rd FLOOR,
15	VOLTAS	34*1=34HP 20*1=20HP	PEDIARTRIC WARD & ROOMS.
16	BLUE STAR	7.5*3=22.5TR.	PEDIARTIC WARD & ROOMS BACK SIDE
17	MIITSUBISHI V.R.V	8HP*1=8HP 24HP*2=48HP 22HP*1=22HP 20HP*3=60HP	V.C OFFICE, EXAMINATION HALL & SALBY HALL
18	MIITSUBISHI V.R.V MIITSUBISHI	14HP*2=28HP 16HP*2=32HP 14HP*5=70HP 12HP*1=12HP	PLASTIC SURGERY DR.ROOM ,O.T
19	DAIKIN	20HP*3=60HP	PLASTIC SURGERY
20	CAREER PLANT	270*2=540TR.	NEW OPD
21	CAREER PLANT	270*2=540TR.	NEW DENTAL
22	VOLTAS CASSETE	5*2=10TR.	6th FLOOR HALL
23	L.G DUCTABLE	8.5*2=17TR.	NEW DENTAL
24	VOLTAS DUCTABLE	10*2=20TR. 7.5*2=15TR.	OLD DENTAL 2nd FLOOR
25	CAREER DUCTABLE	8.5*8=68TR. 5.5*8=44TR.	EYE DEPARTMENT O.T1 O.T 2.
26	VOLTAS	7.5*3=22.5TR.	SEMINOR HALL
27	BLUE STAR DUCTABLE	8.75*1=8.75TR	R.A.L.C ORTHO O.T.
28	CARRIER	3.0*57=171TR 1.0*21=21TR 1.5*15=22.5TR 2.0*16=32TR 4.0*17=68TR AHU OF 7000CFM 01 NO, 8000 CFM 01 NO, 9000 CFM 02 NO, 12000CFM 02 NO.	R.A.L.C CAMPUS
29	VOLTAS	120*1=120TR.	CONVESTION CENTRE
30	TRAIN PLANT	125*2=250TR.	CONVESTION CENTRE
31	MIITSUBISHI ELECTRIC	03HP*30=90HP 20HP*02=40HP 16HP*02=32HP 14HP*02=28HP 10HP*01=10HP	SKILL DEVLOPMENT & RADIO FM DEPTT. (2nd FLOOR CONVESTION CENTRE)

Chillers Performance Study

Shatabdi Phase I Hospital

Sr. No.	Particulars	Chiller # 1	Chiller # 2	Chiller # 3	Chiller # 4
1	Make	Trance	Trance	Trance	Trance
2	Rated TR	175	175	175	175
3	Date of Measurement	19/08/2022	19/08/2022	19/08/2022	19/08/2022
4	Voltage, V	Standby	409	Standby	415
5	Current, A		165.7		159.7
6	Power Consumption, kW		102.2		98.2
7	PF		0.87		0.86
8	Chilled Water Inlet Temp, °C		12		11
9	Chilled Water Outlet Temp, °C		7		7
10	Cooling Water Inlet Temp, °C		36		36
11	Cooling Water Outlet Temp, °C		39		39.2
12	Chilled Water Inlet Pressure (kg/cm ²)		2.2		2.2
13	Chilled Water Outlet Pressure (kg/cm ²)		1.2		1.2
14	Cooling Water Inlet Pressure (kg/cm ²)	3.2	3.2		
15	Cooling Water Outlet Pressure (kg/cm ²)	2.8	2.8		
16	Chilled Water Flow (m ³ /hr)	105	108		
17	Cooling Water Flow (m ³ /hr)	245	236		
18	Output TR	174	143		
19	Specific Power Consumption(kW/TR)	0.59	0.69		
20	COP		5.98		5.12

New OPD

Sr. No.	Particulars	Chiller # 1	Chiller # 2
1	Make	Carrier	Carrier
2	Rated TR	270	270
3	Date of Measurement	20/08/2022	20/08/2022
4	Loading %		66
5	Voltage, V	Standby	404
6	Current, A		145.3
7	Power Consumption, kW		89.6
8	PF		0.88
9	Chilled Water Inlet Temp, °C		15
10	Chilled Water Outlet Temp, °C		11
11	Cooling Water Inlet Temp, °C		26.5
12	Cooling Water Outlet Temp, °C		30
13	Chilled Water Inlet Pressure (kg/cm ²)		4.8
14	Chilled Water Outlet Pressure (kg/cm ²)		4.0
15	Cooling Water Inlet Pressure (kg/cm ²)		4.2
16	Cooling Water Outlet Pressure (kg/cm ²)		4.0
17	Chilled Water Flow (m ³ /hr)		128
18	Cooling Water Flow (m ³ /hr)		280
19	Output TR		169
20	Specific Power Consumption(kW/TR)	0.53	
21	COP	6.65	

New Dental

Sr. No.	Particulars	Chiller # 1	Chiller # 2
1	Make	Carrier	Carrier
2	Rated TR	270	270
3	Date of Measurement	21/08/2022	21/08/2022
4	Loading %	50	66
5	Voltage, V	405	406
6	Current, A	128.7	238.7
7	Power Consumption, kW	78.6	147.2
8	PF	0.87	0.88
9	Chilled Water Inlet Temp, °C	16.1	16.2
10	Chilled Water Outlet Temp, °C	12.2	11.1
11	Cooling Water Inlet Temp, °C	37.3	37.5
12	Cooling Water Outlet Temp, °C	40.3	41.6
13	Chilled Water Inlet Pressure (kg/cm ²)	4.2	4.4
14	Chilled Water Outlet Pressure (kg/cm ²)	3.5	3.8
15	Cooling Water Inlet Pressure (kg/cm ²)	5	4.2
16	Cooling Water Outlet Pressure (kg/cm ²)	4.2	3.5
17	Chilled Water Flow (m ³ /hr)	110	112
18	Cooling Water Flow (m ³ /hr)	145	152
19	Output TR	142	189
20	Specific Power Consumption(kW/TR)	0.55	0.78
21	COP	6.35	4.51

Both the Chillers have satisfactory performances.

Kalam Center

Sr. No.	Particulars	Chiller # 1	Chiller # 2	Chiller # 3
1	Make	Blue Star	Blue Star	Blue Star
2	Rated TR	280	280	320
3	Date of Measurement	21/08/2022	21/08/2022	21/08/2022
4	Loading %	90	Standby	60
5	Voltage, V	406		409
6	Current, A	293.7		232.7
7	Power Consumption, kW	175.4		113.7
8	PF	0.85		0.69
9	Chilled Water Inlet Temp, °C	18		18
10	Chilled Water Outlet Temp, °C	12		14
11	Cooling Water Inlet Temp, °C	31		31
12	Cooling Water Outlet Temp, °C	3		34
13	Chilled Water Inlet Pressure (kg/cm ²)	3.8		3.8
14	Chilled Water Outlet Pressure (kg/cm ²)	3.5		3.5
15	Cooling Water Inlet Pressure (kg/cm ²)	4.8		5.5
16	Cooling Water Outlet Pressure (kg/cm ²)	4.4		4.2
17	Chilled Water Flow (m ³ /hr)	120		110
18	Cooling Water Flow (m ³ /hr)	155		156
19	Output TR	239		146
20	Specific Power Consumption(kW/TR)	0.74		0.78
20	COP	4.77	4.5	

Both the Chillers have satisfactory performances.

CTVS

Sr. No.	Particulars	Chiller # 1	Chiller # 2	Chiller # 3
1	Make	Blue Star	Blue Star	Blue Star
2	Rated TR	300	250	250
3	Date of Measurement	19/08/2022	19/08/2022	19/08/2022
4	Loading %	60	Standby	Standby
5	Voltage, V	396		
6	Current, A	169.3		
7	Power Consumption, kW	99		
8	PF	0.86		
9	Chilled Water Inlet Temp, °C	16.1		
10	Chilled Water Outlet Temp, °C	11.5		
11	Cooling Water Inlet Temp, °C	24.		
12	Cooling Water Outlet Temp, °C	28.		
13	Chilled Water Inlet Pressure (kg/cm ²)	5.8		
14	Chilled Water Outlet Pressure (kg/cm ²)	4.4		
15	Cooling Water Inlet Pressure (kg/cm ²)	5		
16	Cooling Water Outlet Pressure (kg/cm ²)	3		
17	Chilled Water Flow (m ³ /hr)	128		
18	Cooling Water Flow (m ³ /hr)	210		
19	Output TR	195		
20	Specific Power Consumption(kW/TR)	0.51		
20	COP	6.85		

The chiller has satisfactory performances

Chilled Water & Condenser Pumps Study
CTVS

Chilled Water PUMP's

Pump Identification	Unit	Pump-1	Pump-2	Pump-3	Pump-4	Pump-5
Rated Parameters						
Running Status		Standby	Running	Standby	Running	Standby
Pump Make		Kirloskar	Kirloskar	Kirloskar	Kirloskar	Kirloskar
Speed	RPM		2880	2880	2880	2880
Rated Flow	m ³ /hr		93.6	93.6	93.6	93.6
Rated Head	M		35	35	35	35
Rated Power	KW	13.5	10	10	10	10
Motor Efficiency	%	91.0	63.0	63.0	63.0	63.0
Parameters Measured						
Measured Flow	m ³ /hr	NIL	62.3	NIL	65.4	
Discharge Pressure (A)	Kg/cm ²	NIL	5.8	NIL	5.8	
Suction Pressure (B)	Kg/cm ²	NIL	3	NIL	3	
Fluid Density	Kg/ m ³	NIL	1000	NIL	1000	
Performance Evaluation						
Total Head $(=(A-B) \times 10)$	M	NIL	28.0	NIL	28.0	NIL
Head Utilization	%	NIL	80.0	NIL	80.0	NIL
Flow Utilization	%	NIL	66.6	NIL	69.9	NIL
Measured Input power	KW	NIL	10	NIL	10	NIL
Shaft Power	KW	NIL	6	NIL	6	NIL
Hydraulic Power	KW	NIL	4.8	NIL	5.0	NIL
Pump Efficiency	%	NIL	76.2	NIL	79.5	NIL
Overall (Pump Set) Efficiency	%	NIL	48.0	NIL	50.1	NIL
Throttling Suction	%	NIL	Nil	NIL	Nil	NIL
Throttling Discharge	%	NIL	Nil	NIL	Nil	NIL

CTVS

Condenser water pumps

Pump Identification	Unit	Pump-1	Pump-2	Pump-3	Pump-4
Rated Parameters					
Running Status		Standby	Running	Standby	Standby
Pump Make		Kirloskar	Kirloskar	Kirloskar	Kirloskar
Speed	RPM	1450	1450	1450	1450
Rated Flow	m ³ /hr	245.1	245.1	245.1	245.1
Rated Head	M	30.48	30.48	30.48	30.48
Rated Power	KW	30	30	30	30
Motor Efficiency	%	92.0	92.0	92.0	92.0
Parameters Measured					
Measured Flow	m ³ /hr	NIL	221.2	NIL	NIL
Discharge Pressure (A)	Kg/cm ²	NIL	6.2	NIL	NIL
Suction Pressure (B)	Kg/cm ²	NIL	3.2	NIL	NIL
Fluid Density	Kg/ m ³	NIL	1000	NIL	NIL
Performance Evaluation					
Total Head $(=(A-B) \times 10)$	M	NIL	30.0	NIL	NIL
Head Utilization	%	NIL	98.4	NIL	NIL
Flow Utilization	%	NIL	90.2	NIL	NIL
Measured Input power	KW	NIL	29	NIL	NIL
Shaft Power	KW	NIL	27	NIL	NIL
Hydraulic Power	KW	NIL	18.1	NIL	NIL
Pump Efficiency	%	NIL	66.9	NIL	NIL
Overall (Pump Set) Efficiency	%	NIL	61.6	NIL	NIL
Throttling Suction	%	NIL	NIL	Nil	NIL
Throttling Discharge	%	NIL	NIL	Nil	NIL

KALAM CENTRE

Chilled Water PUMP's

Pump Identification	Unit	Pump-1	Pump-2
Rated Parameters			
Running Status		Standby	Running
Pump Make		KSB	KSB
Speed	RPM	2925	2925
Rated Flow	m ³ /hr	150	150
Rated Head	M	35	35
Rated Power	KW	22	22
Motor Efficiency	%	92.1	92.1
Parameters Measured			
Measured Flow	m ³ /hr	NIL	140.2
Discharge Pressure (A)	Kg/cm ²	NIL	4.0
Suction Pressure (B)	Kg/cm ²	NIL	2.6
Fluid Density	Kg/ m ³	NIL	1000
Performance Evaluation			
Total Head $(=(A-B) \times 10)$	M	NIL	14.0
Head Utilization	%	NIL	40.0
Flow Utilization	%	NIL	93.5
Measured Input power	KW	NIL	7
Shaft Power	KW	NIL	7
Hydraulic Power	KW	NIL	5.3
Pump Efficiency	%	NIL	78.6
Overall (Pump Set) Efficiency	%	NIL	72.4
Throttling Suction	%	NIL	NIL
Throttling Discharge	%	NIL	NIL

KALAM CENTRE

Condenser water pump's

Pump Identification	Unit	Pump-1	Pump-2
Rated Parameters			
Running Status		Running	Standby
Pump Make		NA	NA
Speed	RPM	NA	NA
Rated Flow	m ³ /hr	254	254
Rated Head	M	40	40
Rated Power	KW	45	45
Motor Efficiency	%	92.9	92.9
Parameters Measured			
Measured Flow	m ³ /hr	245.2	NIL
Discharge Pressure (A)	Kg/cm ²	4.8	NIL
Suction Pressure (B)	Kg/cm ²	2.4	NIL
Fluid Density	Kg/ m ³	1000	NIL
Performance Evaluation			
Total Head $(=(A-B) \times 10)$	M	24.0	NIL
Head Utilization	%	60.0	NIL
Flow Utilization	%	96.5	NIL
Measured Input power	KW	28	NIL
Shaft Power	KW	26	NIL
Hydraulic Power	KW	16.0	NIL
Pump Efficiency	%	62.1	NIL
Overall (Pump Set) Efficiency	%	57.7	NIL
Throttling Suction	%	Nil	NIL
Throttling Discharge	%	Nil	NIL

NEW DENTAL

Chilled Water PUMP's

Pump Identification	Unit	Pump-1	Pump-2	Pump-3
Rated Parameters				
Running Status		Standby	Running	Standby
Pump Make		Wilo	Wilo	Wilo
Speed	RPM	2905	2905	2905
Rated Flow	m ³ /hr	147	147	147
Rated Head	M	27	27	27
Rated Power	KW	15	15	15
Motor Efficiency	%	89.0	89.0	89.0
Parameters Measured				
Measured Flow	m ³ /hr	NIL	130.5	NIL
Discharge Pressure (A)	Kg/cm ²	NIL	4.8	NIL
Suction Pressure (B)	Kg/cm ²	NIL	2.4	NIL
Fluid Density	Kg/ m ³	NIL	1000	NIL
Performance Evaluation				
Total Head $(=(A-B) \times 10)$	M	NIL	24.0	NIL
Head Utilization	%	NIL	88.9	NIL
Flow Utilization	%	NIL	88.8	NIL
Measured Input power	KW	NIL	14	NIL
Shaft Power	KW	NIL	13	NIL
Hydraulic Power	KW	NIL	8.5	NIL
Pump Efficiency	%	NIL	67.8	NIL
Overall (Pump Set) Efficiency	%	NIL	60.4	NIL
Throttling Suction	%	NIL	Nil	NIL
Throttling Discharge	%	NIL	Nil	NIL

NEW DENTAL

Condenser water pump's

Pump Identification	Unit	Pump-1	Pump-2	Pump-3
Rated Parameters				
Running Status		Running	Standby	Standby
Pump Make		Wilo	Wilo	Wilo
Speed	RPM	2940	2940	2940
Rated Flow	m ³ /hr	245	245	245
Rated Head	M	27	27	27
Rated Power	KW	30	30	30
Motor Efficiency	%	92.6	92.6	92.6
Parameters Measured				
Measured Flow	m ³ /hr	235.2	NIL	NIL
Discharge Pressure (A)	Kg/cm ²	4.4	NIL	NIL
Suction Pressure (B)	Kg/cm ²	2.1	NIL	NIL
Fluid Density	Kg/ m ³	1000	NIL	NIL
Performance Evaluation				
Total Head $(=(A-B) \times 10)$	M	23.0	NIL	NIL
Head Utilization	%	85.2	NIL	NIL
Flow Utilization	%	96.0	NIL	NIL
Measured Input power	KW	23	NIL	NIL
Shaft Power	KW	22	NIL	NIL
Hydraulic Power	KW	14.7	NIL	NIL
Pump Efficiency	%	68.0	NIL	NIL
Overall (Pump Set) Efficiency	%	63.0	NIL	NIL
Throttling Suction	%	Nil	NIL	NIL
Throttling Discharge	%	Nil	NIL	NIL

New OPD

Chilled Water PUMP's

Pump Identification	Unit	Pump-1	Pump-2	Pump-3
Rated Parameters				
Running Status		Running	Running	Standby
Pump Make		Wilo	Wilo	Wilo
Speed	RPM	2905	2905	2905
Rated Flow	m ³ /hr	147	147	147
Rated Head	M	26	26	26
Rated Power	KW	15	15	15
Motor Efficiency	%	89.0	89.0	89.0
Parameters Measured				
Measured Flow	m ³ /hr	118.5	120.4	NIL
Discharge Pressure (A)	Kg/cm ²	4.8	4.8	NIL
Suction Pressure (B)	Kg/cm ²	2.4	2.4	NIL
Fluid Density	Kg/ m ³	1000	1000	NIL
Performance Evaluation				
Total Head $(=(A-B) \times 10)$	M	24.0	24.0	NIL
Head Utilization	%	92.3	92.3	NIL
Flow Utilization	%	80.6	81.9	NIL
Measured Input power	KW	13	13	NIL
Shaft Power	KW	12	12	NIL
Hydraulic Power	KW	7.7	7.9	NIL
Pump Efficiency	%	66.5	66.1	NIL
Overall (Pump Set) Efficiency	%	59.2	58.8	NIL
Throttling Suction	%	Nil	Nil	NIL
Throttling Discharge	%	Nil	Nil	NIL

NEW OPD

Condenser water pump's

Pump Identification	Unit	Pump-1	Pump-2	Pump-3
Rated Parameters				
Running Status		Running	Running	Standby
Pump Make		Wilo	Wilo	Wilo
Speed	RPM	2940	2940	2940
Rated Flow	m ³ /hr	245	245	245
Rated Head	M	26	26	26
Rated Power	KW	30	30	30
Motor Efficiency	%	92.6	92.6	92.6
Parameters Measured				
Measured Flow	m ³ /hr	228.1	224.4	NIL
Discharge Pressure (A)	Kg/cm ₂	4.4	4.4	NIL
Suction Pressure (B)	Kg/cm ₂	2.1	2.1	NIL
Fluid Density	Kg/m ³	1000	1000	NIL
Performance Evaluation				
Total Head $(=(A-B) \times 10)$	M	23.0	23.0	NIL
Head Utilization	%	88.5	88.5	NIL
Flow Utilization	%	93.1	91.6	NIL
Measured Input power	KW	25	25	NIL
Shaft Power	KW	23	23	NIL
Hydraulic Power	KW	14.3	14.1	NIL
Pump Efficiency	%	62.9	61.0	NIL
Overall (Pump Set) Efficiency	%	58.3	56.5	NIL
Throttling Suction	%	Nil	Nil	NIL
Throttling Discharge	%	Nil	Nil	NIL

SHATABADI PHASE -1

Chilled Water PUMP's

Pump Identification		Pump-1	Pump-2	Pump-3	Pump-4
Unit					
Rated Parameters					
Running Status		Running	Running	Running	Standby
Pump Make		Kirloskar	Kirloskar	Kirloskar	Kirloskar
Speed	RPM	1440	1440	1440	1440
Rated Flow	m ³ /hr	190.08	190.08	190.08	190.08
Rated Head	M	54.8	54.8	54.8	54.8
Rated Power	KW	7.5	7.5	7.5	7.5
Motor Efficiency	%	86.0	86.0	86.0	86.0
Parameters Measured					
Measured Flow	m ³ /hr	142.2	148.3	144.2	NIL
Discharge Pressure (A)	Kg/cm ²	2.2	2.2	2.2	NIL
Suction Pressure (B)	Kg/cm ²	1	1	1	NIL
Fluid Density	Kg/ m ³	1000	1000	1000	NIL
Performance Evaluation					
Total Head $(=(A-B) \times 10)$	M	12.0	12.0	12.0	NIL
Head Utilization	%	21.9	21.9	21.9	NIL
Flow Utilization	%	74.8	78.0	75.9	NIL
Measured Input power	KW	7	7	7	NIL
Shaft Power	KW	6	6	6	NIL
Hydraulic Power	KW	4.6	4.8	4.7	NIL
Pump Efficiency	%	77.4	81.4	77.7	NIL
Overall (Pump Set) Efficiency	%	66.6	70.0	66.8	NIL
Throttling Suction	%	NIL	NIL	NIL	NIL
Throttling Discharge	%	NIL	NIL	NIL	NIL

SHATABADI PHASE -1 ;Condenser water pump's

Pump Identification	Unit	Pump-1	Pump-2	Pump-3	Pump-4
Rated Parameters					
Running Status		Running	Standby	Standby	Running
Pump Make		Kirloskar	Kirloskar	Kirloskar	Kirloskar
Speed	RPM	1450	1450	1450	1450
Rated Flow	m ³ /hr	NA	NA	NA	NA
Rated Head	M	NA	NA	NA	NA
Rated Power	KW	18.5	18.5	18.5	18.5
Motor Efficiency	%	90.6	90.6	90.6	90.6
Parameters Measured					
Measured Flow	m ³ /hr	230	NIL	NIL	235
Discharge Pressure (A)	Kg/cm ²	4.0	NIL	NIL	4.0
Suction Pressure (B)	Kg/cm ²	2	NIL	NIL	2
Fluid Density	Kg/ m ³	1000	NIL	NIL	1000
Performance Evaluation					
Total Head (=A-B)X10)	M	20.0	NIL	NIL	20.0
Head Utilization	%	NIL	NIL	NIL	NIL
Flow Utilization	%	NIL	NIL	NIL	#
Measured Input power	KW	18	NIL	NIL	18
Shaft Power	KW	16	NIL	NIL	16
Hydraulic Power	KW	12.5	NIL	NIL	12.8
Pump Efficiency	%	77.6	NIL	NIL	80.0
Overall (Pump Set) Efficiency	%	70.3	NIL	NIL	72.5
Throttling Suction	%	NIL	NIL	NIL	NIL
Throttling Discharge	%	NIL	NIL	NIL	NIL

Observation:The efficiency of the pumps are found more than 50% which is acceptable.

Cooling Towers Study
Shatabdi Phase I

Sr. No.	Particulars	Unit	UNIT I	UNIT II	UNIT III	UNIT IV
1	Fan Rated kW		9.3	9.3	9.3	9.3
2	Application		Chiller	Chiller	Chiller	Chiller
3	Range	°C	NA	NA	NA	NA
4	Approach	°C	NA	NA	NA	NA
5	Rated Water Flow	m ³ /hr.	NA	NA	NA	NA
6	Rated Hot Cooling Water Inlet to Tower	°C	NA	NA	NA	NA
7	Rated Cold Cooling Water Outlet from Tower	°C	NA	NA	NA	NA
8	Design Air Inlet Temperature (DBT)	°C	NA	NA	NA	NA
9	Design Air Inlet Temperature (WBT)	°C	NA	NA	NA	NA
Measured Parameters						
	CT FAN		Fan 1	Fan 2	Fan 3	Fan 4
10	Voltage	V	406			406
11	Ampere	I	11			10.5
12	Measured Power	kW	6.4	0.0	0	6.2
13	Power Factor	P.F	0.83			0.84
14	Total Cooling Water Flow	m ³ /hr.	210			220
15	Riser Throttling	%	Nil	NIL	NIL	NIL
16	Hot Cooling Water Inlet to Tower	°C	39	NIL	NIL	39
17	Cold Cooling Water Outlet from Tower	°C	27	NIL	NIL	27
18	Air Inlet (DBT)	°C	30	NIL	NIL	30
19	(WBT)	°C	22	NIL	NIL	22
20	Operating Range	°C	12.00	NIL	NIL	12.00
21	Approach	°C	5.00	NIL	NIL	5.00
22	Effectiveness of Cooling Tower	%	70.6	NIL	NIL	70.6
23	Cooling Duty Handled by C.T	TR	833	NIL	NIL	873
24	Heat Dissipated	Million kcal/hr	2.52	NIL	NIL	2.64
25	Evaporation loss	m ³ /hr.	3.86	NIL	NIL	4.04
26	Evaporation loss	%	1.84	NIL	NIL	1.84
27	Remarks		Running	Standby	Standby	Running

New OPD

Sr. No.	Particulars	Unit	UNIT I		UNIT II	
1	Fan Rated kW		11.2	11.2	11.2	11.2
2	Application		Chiller	Chiller	Chiller	Chiller
3	Range	°C	NA	NA	NA	NA
4	Approach	°C	NA	NA	NA	NA
5	Rated Water Flow	m ³ /hr.	NA	NA	NA	NA
6	Rated Hot Cooling Water Inlet to Tower	°C	NA	NA	NA	NA
7	Rated Cold Cooling Water Outlet from Tower	°C	NA	NA	NA	NA
8	Design Air Inlet Temperature (DBT)	°C	NA	NA	NA	NA
9	Design Air Inlet Temperature (WBT)	°C	NA	NA	NA	NA
Measured Parameters						
	CT FAN		Fan 1	Fan 2	Fan 3	Fan 4
10	Voltage	V	401	401.8	NIL	NIL
11	Ampere	I	15.2	16.3	NIL	NIL
12	Measured Power	kW	9.0	9.6	NIL	NIL
13	Power Factor	P.F	0.85	0.85	NIL	NIL
14	Total Cooling Water Flow	m ³ /hr.	121	125	NIL	NIL
15	Riser Throttling	%	Nil	Nil	NIL	NIL
16	Hot Cooling Water Inlet to Tower	°C	31	31	NIL	NIL
17	Cold Cooling Water Outlet from Tower	°C	26	26	NIL	NIL
18	Air Inlet (DBT)	°C	30	30	NIL	NIL
19	(WBT)	°C	22	22	NIL	NIL
20	Operating Range	°C	5.00	5.00	NIL	NIL
21	Approach	°C	4.00	4.00	NIL	NIL
22	Effectiveness of Cooling Tower	%	55.6	55.6	NIL	NIL
23	Cooling Duty Handled by C.T	TR	200	207	NIL	NIL
24	Heat Dissipated	Million kcal/hr	0.61	0.63	NIL	NIL
25	Evaporation loss	m ³ /hr.	0.93	0.96	NIL	NIL
26	Evaporation loss	%	0.77	0.77	NIL	NIL
27	Remarks		Running	Running	Standby	Standby But

New Dental

Sr. No.	Particulars	Unit	UNIT I		UNIT II	
1	Fan Rated kW		11.2	11.2	11.2	11.2
2	Application		Chiller	Chiller	Chiller	Chiller
3	Range	°C	NA	NA	NA	NA
4	Approach	°C	NA	NA	NA	NA
5	Rated Water Flow	m ³ /hr.	NA	NA	NA	NA
6	Rated Hot Cooling Water Inlet to Tower	°C	NA	NA	NA	NA
7	Rated Cold Cooling Water Outlet from Tower	°C	NA	NA	NA	NA
8	Design Air Inlet Temperature (DBT)	°C	NA	NA	NA	NA
9	Design Air Inlet Temperature (WBT)	°C	NA	NA	NA	NA
Measured Parameters						
	CT FAN		Fan 1	Fan 2	Fan 3	Fan 4
10	Voltage	V	401.8	401.8	NIL	NIL
11	Ampere	I	14.2	14.1	NIL	NIL
12	Measured Power	kW	8.5	8.4	NIL	NIL
13	Power Factor	P.F	0.86	0.86	NIL	NIL
14	Total Cooling Water Flow	m ³ /hr.	108	110	NIL	NIL
15	Riser Throttling	%	Nil	Nil	NIL	NIL
16	Hot Cooling Water Inlet to Tower	°C	41	41	NIL	NIL
17	Cold Cooling Water Outlet from Tower	°C	36	36	NIL	NIL
18	Air Inlet (DBT)	°C	31	31	NIL	NIL
19	(WBT)	°C	24	24	NIL	NIL
20	Operating Range	°C	5.00	5.00	NIL	NIL
21	Approach	°C	12.00	12.00	NIL	NIL
22	Effectivness of Cooling Tower	%	29.4	29.4	NIL	NIL
23	Cooling Duty Handled by C.T	TR	179	182	NIL	NIL
24	Heat Dissipated	Million kcal/hr	0.54	0.55	NIL	NIL
25	Evaporation loss	m ³ /hr.	0.83	0.84	NIL	NIL
26	Evaporation loss	%	0.77	0.77	NIL	NIL
27	Remarks		Running	Running	Standby	Standby But

Kalam Center

Sr. No.	Particulars	Unit	UNIT I	UNIT II	UNIT III	UNIT IV
1	Fan Rated kW		5.5	5.5	5.5	5.5
2	Application		Chiller	Chiller	Chiller	Chiller
3	Range	°C	NA	NA	NA	NA
4	Approach	°C	NA	NA	NA	NA
5	Rated Water Flow	m ³ /hr.	NA	NA	NA	NA
6	Rated Hot Cooling Water Inlet to Tower	°C	NA	NA	NA	NA
7	Rated Cold Cooling Water Outlet from Tower	°C	NA	NA	NA	NA
8	Design Air Inlet Temperature (DBT)	°C	NA	NA	NA	NA
9	Design Air Inlet Temperature (WBT)	°C	NA	NA	NA	NA
Measured Parameters						
	CT FAN		Fan 1	Fan 2	Fan 3	Fan 4
10	Voltage	V	401.2	401.1	401.3	401.1
11	Ampere	I	6.8	6.9	7.1	7.1
12	Measured Power	kW	3.3	3.4	3.5	3.5
13	Power Factor	P.F	0.7	0.7	0.7	0.7
14	Total Cooling Water Flow	m ³ /hr.	74	70	65	68
15	Riser Throttling	%	Nil	Nil	Nil	Nil
16	Hot Cooling Water Inlet to Tower	°C	34.2	34.1	34	34.2
17	Cold Cooling Water Outlet from Tower	°C	31.2	31.3	31.2	31
18	Air Inlet (DBT)	°C	30	30	30	30
19	(WBT)	°C	24	24	24	24
20	Operating Range	°C	3.00	2.80	2.80	3.20
21	Approach	°C	7.20	7.30	7.20	7.00
22	Effectiveness of Cooling Tower	%	29.4	27.7	28.0	31.4
23	Cooling Duty Handled by C.T	TR	73	65	60	72
24	Heat Dissipated	Million kcal/hr	0.22	0.20	0.18	0.22
25	Evaporation loss	m ³ /hr.	0.34	0.30	0.28	0.33
26	Evaporation loss	%	0.46	0.43	0.43	0.49
27	Remarks		Standby	Running	Standby	Running

CTVS

Sr. No.	Particulars	Unit	UNIT I	UNIT II	UNIT III	UNIT IV
1	Fan Rated kW		9.3	9.3	9.3	9.3
2	Application		Chiller	Chiller	Chiller	Chiller
3	Range	°C	NA	NA	NA	NA
4	Approach	°C	NA	NA	NA	NA
5	Rated Water Flow	m ³ /hr.	NA	NA	NA	NA
6	Rated Hot Cooling Water Inlet to Tower	°C	NA	NA	NA	NA
7	Rated Cold Cooling Water Outlet from Tower	°C	NA	NA	NA	NA
8	Design Air Inlet Temperature (DBT)	°C	NA	NA	NA	NA
9	Design Air Inlet Temperature (WBT)	°C	NA	NA	NA	NA
Measured Parameters						
	CT FAN		Fan 1	Fan 2	Fan 3	Fan 4
10	Voltage	V	NIL	401.8	NIL	401.8
11	Ampere	I	NIL	10.7	NIL	10.5
12	Measured Power	kW	NIL	6.3	NIL	6.1
13	Power Factor	P.F	NIL	0.84	NIL	0.84
14	Total Cooling Water Flow	m ³ /hr.	NIL	72	NIL	68
15	Riser Throttling	%	NIL	Nil	NIL	Nil
16	Hot Cooling Water Inlet to Tower	°C	NIL	28	NIL	28
17	Cold Cooling Water Outlet from Tower	°C	NIL	25	NIL	24.8
18	Air Inlet (DBT)	°C	NIL	24	NIL	24
19	(WBT)	°C	NIL	18	NIL	18
20	Operating Range	°C	NIL	3.00	NIL	3.20
21	Approach	°C	NIL	7.00	NIL	6.80
22	Effectiveness of Cooling Tower	%	NIL	30.0	NIL	32.0
23	Cooling Duty Handled by C.T	TR	NIL	71	NIL	72
24	Heat Dissipated	Million kcal/hr	NIL	0.22	NIL	0.22
25	Evaporation loss	m ³ /hr.	NIL	0.33	NIL	0.33
26	Evaporation loss	%	NIL	0.46	NIL	0.49
27	Remarks		Standby	Running	Standby	Running

Study of Air Handling Units (AHUs)

The chilled water through secondary pumps circulate to the AHUs which in turn deliver cool air to the premises. It is important to note that the AHUs are operated manually and there is no control through any automatised system.

AHU of CTVS

Floor ID		Third Floor	Third Floor	Second Floor	Second Floor	First Floor	Ground Floor
AHU ID	Unit	Ward	Private Ward	ICU	Doctors Room	Rest Area	OPD
Design Details							
AHU Number		3	2			6	1
Supply Air flow	CFM	10000	15000	8000	5900	4000	7000
Power consumption	kW	5.5	5.5	3.7	3.7	2.2	3.7
Measurement							
Area	m ²	2.16	2.70	1.44	1.08	0.72	1.35
Velocity	m/s	2.10	2.30	2.40	2.40	1.60	2.40
Return Air DBT	°C	28	28	31	31	27	31
Return Air WBT		14	14	15	15	18	15
Return Air RH	%	17.1	17.1	14.6	14.6	41.3	14.6
Supply Air DBT	°C	19	17	19.0	19.0	15.0	19.0
Supply Air WBT		9	7	8	8	12	8
Supply Air RH	%	22.50	18	16.1	16.1	70.7	16.1
Power consumption	kW	3.82	3.99	2.80	2.10	1.33	4.33
Calculations							
Air Flow	CFM	9604	13148	7317	5488	2439	6860
Air Flow	Kg/hr	18942	25933	14432	10824	4811	13530
Return Air Enthalpy	kJ/Kg	38.90	38.90	41.50	41.50	50.50	41.50

Supply Air Enthalpy	kJ/Kg	26.8	22.5	24.6	24.6	34.0	24.6
Cooling Delivered	TR	18.10	33.59	19.26	14.45	6.25	18.06
Sp. Power Consumption	kW/TR	0.21	0.12	0.15	0.15	0.21	0.24
Sp. Air Consumption	CFM/TR	531	391	380	380	390	380
Remark		All AHU Filters are dirty					

Observation: All AHU Filters are Dirty.

AHU of Kalam Centre

Floor ID		Sixth Floor	First Floor
AHU ID	Unit		
Design Details			
AHU Number		21	2
Supply Air flow	CFM		
Power consumption	kW	11	3.7
Measurement			
Area	m ²	3.84	1.50
Velocity	m/s	2.10	2.40
Return Air DBT	°C	28	31
Return Air WBT		14	15
Return Air RH	%	17.1	14.6
Supply Air DBT	°C	19	19.0
Supply Air WBT		9	8
Supply Air RH	%	22.50	16.1
Power consumption	kW	7.40	2.59
Calculations			
Air Flow	CFM	17074	7622
Air Flow	Kg/hr	33675	15034

Return Air Enthalpy	kJ/Kg	38.90	41.50
Supply Air Enthalpy	kJ/Kg	26.8	24.6
Cooling Delivered	TR	32.18	20.07
Sp. Power Consumption	kW/TR	0.23	0.13
Sp. Air Consumption	CFM/TR	531	380
Remark		All AHU Filters are dirty	

AHU of New Dental

Floor ID		Fifth Floor	Third Floor	Ground Floor
AHU ID	Unit	North Wing	South Wing	
Design Details				
AHU Number				
Supply Air flow	CFM	16000	12000	16000
Power consumption	kW	7.5	5.5	7.5
Measurement				
Area	m ²	3.15	2.16	3.15
Velocity	m/s	2.10	2.30	2.40
Return Air DBT	°C	28	28	25
Return Air WBT		14	14	14
Return Air RH	%	17.1	17.1	27.7
Supply Air DBT	°C	17	18	19
Supply Air WBT		7	8	10
Supply Air RH	%	18	20.3	29.12
Power consumption	kW	4.20	3.10	4.10
Calculations				
Air Flow	CFM	14006	10519	16006

Air Flow	Kg/hr	27624	20746	31571
Return Air Enthalpy	kJ/Kg	38.90	38.90	39.00
Supply Air Enthalpy	kJ/Kg	22.5	24.6	29.1
Cooling Delivered	TR	35.78	23.43	24.61
Sp. Power Consumption	kW/TR	0.12	0.13	0.17
Sp. Air Consumption	CFM/TR	391	449	650
Remark		All AHU Filters are dirty		

AHUs of New OPD .

Floor ID		Fourth Floor	Fourth Floor	Third Floor	Third Floor	Second Floor	Second Floor
AHU ID	Unit	South Wing	North Wing	Neuro Surgery	South Wing	North Wing	South Wing
Design Details							
AHU Number							
Supply Air flow	CFM	10000	25000	20000	10000	20000	10000
Power consumption	kW	5.5	11	7.5	5.5	7.5	5.5
Measurement							
Area	m2	2.16	4.86	3.60	2.16	3.60	2.16
Velocity	m/s	2.10	2.10	2.10	2.10	2.40	2.10
Return Air DBT	°C	28	28	28	28	25	26
Return Air WBT		14	14	14	14	14	13
Return Air RH	%	17.1	17.1	17.1	17.1	27.7	19.2
Supply Air DBT	°C	19	18	17	18	19	15.0

Supply Air WBT		9	8	7	8	10	9
Supply Air RH	%	22.50	20.3	18	20.3	29.12	44.3
Power consumption	kW	3.82	7.51	4.08	3.08	4.10	3.21
Calculations							
Air Flow	CFM	9604	21609	16006	9604	18293	9604
Air Flow	Kg/hr	18942	42620	31571	18942	36081	18942
Return Air Enthalpy	kJ/Kg	38.90	38.90	38.90	38.90	39.00	36.30
Supply Air Enthalpy	kJ/Kg	26.8	24.6	22.5	24.6	29.1	26.9
Cooling Delivered	TR	18.10	48.14	40.89	21.39	28.13	14.06
Sp. Power Consumption	kW/TR	0.21	0.16	0.10	0.14	0.15	0.23
Sp. Air Consumption	CFM/TR	531	449	391	449	650	683
Remark				All AHU Filters are dirty			

AHUs of NEW OPD

Floor ID		First Floor	First Floor	First Floor	Ground Floor	Ground Floor
AHU ID	Unit	North Wing 1	North Wing 2	South Wing	South Wing	North Wing
Design Details						
AHU Number						
Supply Air flow	CFM	5500	15000	10000	28000	8000
Power consumption	kW	3.7	5.5	5.5	11	3.7
Measurement						
Area	m ²	1.30	2.70	2.16	5.18	1.84
Velocity	m/s	1.60	2.10	1.80	2.40	2.00
Return Air DBT	°C	31	30	27	26	31
Return Air WBT		15	17	18	15	15
Return Air RH	%	14.6	16.1	41.3	29.3	14.6
Supply Air DBT	°C	19.0	20.0	15.0	18.0	19.0
Supply Air WBT		8	10	12	11	8
Supply Air RH	%	16.1	24.5	70.7	41.4	16.1
Power consumption	kW	2.04	3.11	3.16	7.48	2.15
Calculations						
Air Flow	CFM	4404	12005	8232	26342	7791
Air Flow	Kg/hr	8686	23678	16236	51956	15368
Return Air Enthalpy	kJ/Kg	41.50	41.60	50.50	41.70	41.50
Supply Air Enthalpy	kJ/Kg	24.6	29.1	34.0	31.5	24.6

Cooling Delivered	TR	11.59	23.34	21.11	41.86	20.51
Sp. Power Consumption	kW/TR	0.18	0.13	0.15	0.18	0.10
Sp. Air Consumption	CFM/TR	380	514	390	629	380
Remark		All AHU Filters are dirty				

SHATABADI PHASE -1

Floor ID		Second Floor	First Floor	First Floor	First Floor	Ground Floor	Ground Floor
AHU ID	Unit	OT	Sister Room	OT	OT	DSALF	CSD
Design Details							
AHU Number				1	2		
Supply Air flow	CFM	8000	8000	4000	4000	22500	9000
Power consumption	kW	5.5	5.5	5.5	5.5	15	5.5
Measurement							
Area	m ²	1.33	1.27	1.00	1.00	4.27	1.68
Velocity	m/s	2.20	2.30	1.80	1.80	1.90	1.80
Return Air DBT	°C	30	31	30	31	31	31
Return Air WBT		18	19	18	18	18	17
Return Air RH	%	30.15	31.44	30.15	27.02	27.02	22.76
Supply Air DBT	°C	17	19.0	19.0	19.0	17.0	18.0
Supply Air WBT		7	8	8	8	7	7
Supply Air RH	%	18.02	16.14	16.14	16.14	18.02	13.7
Power consumption	kW	3.87	3.43	3.55	3.66	10.67	2.79

Calculations							
Air Flow	CFM	6214	6160	3811	3811	17185	6403
Air Flow	Kg/hr	12256	12150	7517	7517	33896	12628
Return Air Enthalpy	kJ/Kg	50.49	53.67	50.49	50.46	50.46	47.39
Supply Air Enthalpy	kJ/Kg	22.6	24.7	24.7	24.7	22.6	22.5
Cooling Delivered	TR	27.04	27.85	15.34	15.32	74.72	24.78
Sp. Power Consumption	kW/TR	0.14	0.12	0.23	0.24	0.14	0.11
Sp. Air Consumption	CFM/TR	230	221	248	249	230	258
Remark		All AHU Filters are dirty					


Recommendation for filter cleaning is being suggested in all the AHUs.

IoT Based Building Management System for Energy Savings

Existing System

- No automatic operation as per the actual need
- No automatic switching off of equipment in case of non-usages
- High electricity bills due to unnecessary usage of heavy load equipment
- No centralised operating system is reported


The solution is HVAC automation system or Building Management Systems (BMS) as below:-




- E. Effect of variation in evaporator temperature on compressor power consumption – A 1°C raise in evaporator temperature can help to save almost 3 % on power consumption
- F. Effect of variation of condenser temperature on compressor power consumption –
- G. Effect of poor maintenance on compressor power consumption

Thermographic Study


TRANSFORMER'S



DESCRIPTION-SHATABADI PHASE -1 TR-3
Panel surface temperature-38.0




DISCRIPTION-SHATABADI PHASE -1 TR-2
Panel surface temperature-28.4



DISCRIPTION –SHATABADI PHASE -2 TR-1
Panel surface temperature -33.4




DESCRIPTION-SHATABADI PHASE-1 TR-3
Panel surface temperature -33.1



DESCRIPTION –CTVS TR -1

Panel surface temp-32.7




DESCRIPTION –CTVS TR-2

Panel surface temp-33.4




DESCRIPTION –NEW DENTAL TR-1

Panel surface temp-30.8




DESCRIPTION-GAUTAM BUDHA HOSTEL TR-1


Panel surface temp-46.8




DESCRIPTION –NEW DENTAL TR -2
Panel surface temperature -38.3




DESCRIPTION –TG HOSTEL TR-3
Panel surface temperature -35.4



DESCRIPTION –TG HOSTEL TR -1
Panel surface temperature -35.5




DESCRIPTION –RALC TR-1
Panel surface temperature -33.3




DESCRIPTION –QUEEN MERRY HOSPITAL

Panel surface temperature -37.3



DESCRIPTION –TYPE -5 FACULTY BUILDING

Panel surface temperature - 35.5




DESCRIPTION –NEW OPD TR-1

Panel surface temperature -30.2




DESCRIPTION –NEW OPD TR AC PLANT

Panel surface temperature - 70.2



DESCRIPTION –MAIN HOSPITAL
Panel surface temperature -45




DESCRIPTION –QUEEN MERRY 100 BEDED
Panel surface temperature - 34.2


SHATABADI PHASE -1




DESCRIPTION –CHILLER-4
Main panel surface temp-25.3




DESCRIPTION –CHILLER-2
Main panel surface temp - 28




DESCRIPTION –Cooling Tower FAN -4
Main panel temp-32.8




DESCRIPTION –Cooling Tower FAN -3
Main Panel temp- 33.5




DESCRIPTION –CONDENSER PUMP -4
Panel surface temp-40.6




DESCRIPTION –CONDENSER PUMP-1
Panel surface temp- 33.7




DESCRIPTION –CHILLED WATER PUMP-1
Panel surface temp-31.6




DESCRIPTION – CHILLED WATER PUMP-2
Panle surface temp- 33.2




DESCRIPTION –GROUND FLOOR AHU
Panel surface temp-37.7



DESCRIPTION – CHIELD WATER PUMP-2
Panel surface temp- 25.3




DESCRIPTION –GROUND FLOOR AHU
Panel surface temp-28




DESCRIPTION – AHU-2 CHD
Panel surface temp- 25.3


CTVS




DESCRIPTION –CHILLER-3
Panel surface temp- 29.6




DESCRIPTION – CHILLER -1
Panel surface temp-29.7



DESCRIPTION –Cooling Tower FAN -3
Panel surface temp-33.9




DESCRIPTION – Cooling Tower FAN -1
Panle surface temp- 29.6




DESCRIPTION –CHILLED WATER PUMP-2

Panel surface temp-32.9




DESCRIPTION – CONDENSER PUMP -2

Panel surface temp- 26.1




DESCRIPTION –CHILLED WATER PUMP- 2

Panel surface temp-24.8




DESCRIPTION-CHILLED WATER PUMP-4


Panel surface temp-26.1




DESCRIPTION –3RD FLOOR AHU-2
Panel surface temp-23.3




DESCRIPTION – 3RD FLOOR AHU -1
Panel surface temp- 22.9




DESCRIPTION –2ND FLOOR AHU-2
Panel surface temp- 24



DISRIPTION – 2ND FLOOR AHU -02
Panel surface temp-24.8



DESCRIPTION –1ST FLOOR AHU-2
Panel surface temp-27.8




DESCRIPTION – 1ST FLOOR AHU –ROOM NO-4
Panel surface temp- 27.9


NEW OPD




DESCRIPTION CONDENSER PUMP-1
Panel surface temp-33.5




DESCRIPTION – CHILLER -2
Panel surface temp- 52.1




DESCRIPTION-CHILLED WATER PUMP -1
Panel surface temp-39.5




DESCRIPTION – CONDENSER PUMP-2
Panel surface temp- 38.5




DESCRIPTION – Cooling Tower FAN -1
Panel surface temp-35




DISCRIPTION – CHILLED WATER PUMP-2
Panel surface temp- 32.1




DESCRIPTION – Cooling Tower FAN -1
Panel surface temp-27.8




DESCRIPTION – Cooling Tower FAN -2
Panel surface temp- 32.1



DESCRIPTION – 4TH FLOOR AHU NORTH WING
Panel surface temp-30.9




DESCRIPTION – 4TH FLOOR AHU SOUTH WING
Panel surface temp- 35.5




DESCRIPTION – 3RDFLOOR AHU NEURO
Panel surface temp-30.9


NEW DENTAL




DESCRIPTION – CHILLER -2
Panel surface temp-32.1




DESCRIPTION – CHILLER -1
Panel surface temp- 34.6




DESCRIPTION-Cooling Tower FAN -1
Panel surface temp-36.3



DESCRIPTION-Cooling Tower FAN -2
Panel surface temp-35.8



DESCRIPTION-CONDENSER PUMP-2
Panel surface temp-66.7



DESCRIPTION-CHILLED WATER P-2
Panel surface temp-38

Observation : No abnormal temperature indication found in the thermography study

Concentrated Solar Thermal (CST) Systems Performance

Present Applications

The steam is utilized in the Hospital Kitchen situated in the Shatabdi Phase II building Ground Floor and food is supplied to all the Hospital departments.



Fig. Patient Kitchen

Key Observations


- LPG Boiler is also in operation as backup steam generator of the Solar Concentrator which consumes 02 cylinders per day
- The kitchen uses another LPG Oven for daily general uses which consumes 01 -02 cylinders per days
- The system capacity is more than the steam requirement of the kitchen
- The steam generation should be started from 10:30 am onwards and keep on generating steam till the evening .
- The better maintenance practices can increase the operation of the CST
- Around 15-16 kg / cm² remains unused which can find other applications

- The generated steam should be used within the evening time as the steam gets Converted into water overnight and become non-usable. The Patient kitchen is used for preparing all the items except roti making which is done in a separate kitchen above the Kitchen 1905.




Performance of Concentrated Solar Thermal (CST)

The below chart shows the non-working of CST on monthly basis.




The CST operation has been affected in Rainy season as well as extreme winter. But, it has performed extremely well from February and there was not a single day generation loss in March and April.

The below chart shows the LPG cylinders (Commercial , 19 kgs) got saved on monthly basis due to the use of CST:-



Again, CST has performed extremely well in some months like February, March, April, May ,etc and it shows that the total steam generated did not use a major percentage, say for example the below chart for the Month of March :-



Recommendations

It is noted from the above that the steam generation capacity of the 30 parabola systems is more than the required quantity, so, a part of the steam can be diverted to other applications like steam sterilizers. These have a designed steam pressure requirement of 2 kg/ cm² which can be met by the CST system. The usage will save a power requirement of 18 kW per machine.




Fig.Steam Sterilizers

A total 54 kW capacity of power can be saved from 03 sterilizers located in the Shatabdi Phase-I building ground floor which is at a distance of around 100 ft from the location of the rooftop of Shatabdi Phase-II building where the CST is installed.

- A total investment for laying the insulated pipes would be Rs.1,50,000/- (Approx)
- The tentative savings in energy would be 129600 kWh
- The tentative monetary savings would be Rs. 1749600/-.
- The payback would be immediate.

Solar PV Power Plants Potential (Grid Connected)

Importance of Solar PV Energy in Healthcare Sectors

India is a tropical country, which receives adequate solar radiation for 300 days. It makes a huge potential for solar energy in the country and the state like Uttar Pradesh. The below points explain the importance of the Solar PV Energy in the Healthcare sector such as KGMU:-

- Solar power is a fundamental choice for healthcare sector — not only because solar energy helps reduce air pollution and makes the world a cleaner, healthier and better place. Hospitals, clinics, nursing homes, testing laboratories all use a large amount of electricity.
- A great way to reduce electricity bills- Running medical equipment such as scanners etc uses a large amount of electricity and some of these facilities run 24x7 with air conditioning making their utility bills touch the sky. For such reasons installing a solar energy system is a great way to reduce electricity bills .
- Hospitals have large rooftop Space - hospitals have large spaces such as rooftop, parking lot canopies etc to install solar panels.
- Clean and Green Operation- unlike Diesel and Grid Power which are originated from highly polluting energy sources like Coal and Diesel; Solar PV Power sources help to have clean and green operations.
- Financial Sustainability – through savings energy cost, the solar plants help in achieving financial sustainability
- NAAC and other similar certification - Choosing alternate energy can reduce KGMU 's carbon emissions and have a positive effect on environmental health.

Economical without Net Metering –

The Net Metering in Uttar Pradesh State is not operational since Jan 2019 in spite of the fact that the generating power through Solar PV is beneficial at KGMU campus since it is operational 24x7 for 365 days.

Potential of Further Solar Plants

There are 107 Buildings exist in the KGMU campus covering various departments, hospitals, hostels, Canteens, guest houses, etc. Solar PV is already installed in 23 Rooftops. Based on our preliminary assessment another 27 Rooftops can be used for Solar PV Power generation with a potential of 2135 kW and generating 29,91,800 units per annum. The list of these buildings are as below: -

S. No.	Name of Department /Buildings	Solar Available (Yes/No)	Tentative Solar Capacity, kW
1	Old Administrative Buildmg	No	99.00
2	Old Administrative Buildmg	No	62.00
3	Old Administrative Buildmg	No	120.00
4	Old CV. Hostel & New CV. Hostel	No	165.00
5	Works Department (Civil Sectio)	No	20.00
6	Anesthesia Department	No	8.50
7	Pharmacology Department	No	98.00
8	Pharmacology Extension Building	No	13.00
9	New OPD. Building	No	103.00
10	New Dental Building Near Gamla Ghar	No	86.00
11	Faculty of Dental Science	No	42.00
12	Ophthalmic Department (South Wing)	No	16.00
13	New VI. Hostel	No	62.00
14	Buddha Hostel Block -A,B,C	No	40.00
15	Buddha Hostel Block -D	No	10.50
16	Buddha Hostel Block -E, F, G	No	48.00
17	Married Block Buddha Hostel	No	18.00
18	Department Of Psychiatry	No	67.00
19	CTVS. Building	No	18.00
20	Cardiology Administrative & OPD. Building	No	31.00
21	Scientific Conversion Centre	No	340.00
22	SP. Hostel	No	270.00
23	New Nehru Hostel	No	25.00
24	Old Nehru Hostel	No	38.00
25	Old Dental Building	No	95.00
26	QMH. Main Building	No	220.00
27	RCH. Building at QMH.	No	22.00

The buildings with existing solar plants also may accommodate additional Solar PV capacity.

The Energy savings potential of the total 2135 kW capacity Solar PV plant is 2991800 units. The corresponding monetry savings would be Rs.40389300/-. The required investment for the said capacity would be Rs.74725000/- (approximately) and tentative pauback period will be 22 months.

Application of Heat Reflective Coating

Heat Reflective Paints – Importance

Reflective roof top coatings can make a home energy efficient by reducing air conditioning load as well as any cooling load. Several researches have shown that external colors of a building have significant impact on cooling load of the building. A white reflective roof coating can potentially reduce up to 60% of heat coming in from the ceiling. But the results vary in different situations.

The concrete roofs tend to get darker over time. Due to the properties of the concrete roof materials as well as due to the darkness of the roof, the concrete roofs absorb heat and get heated increasing the roof temperature beyond 70 deg C in summer. This heat enters into the building and thereby increases the HVAC

How does a reflective coat helps?

A reflective roof coating saves energy in building by reflective UV rays back into the atmosphere. Most roofing systems absorb UV rays, and that heat is transferred into the building. A reflective roof doesn't allow those UV rays into the building, and therefore reduces the amount of heat coming in.

Application Potential in KGMU Buildings


A part of the KGMU buildings have Solar PV Power Plants which protect the rooftop getting heated. There are a few buildings which can be used to install Solar PV Plants as mentioned in the chapter above. The balance buildings are potential for the application of the White Reflective Coating.

The following Benefits can be accrued using the WRC:-

Rooftop coatings not only prevent extra heat from entering a house, but have many other benefits too:-

- a) It can increase the life of the roof by 15 years or more.
- b) Dense cities with lot of swellings in a small area have tendencies of getting heated up significantly. If houses have reflective rooftops, then the amount of heat waves can be reduced.
- c) In general it can add to greening by reducing waste and saving electricity

A list of such potential buildings



S. No.	Name of Department /Buildings	Plinth Area in SQM. Approx.
1	Mortuary House	730.50
2	Microbiology Lab (ICTC. Uinit)	335.82
3	Microbiology Deaparrtment (Old Blood Bank Building)	334.52
4	SPM Building	367.29
5	PHI Building	1,285.49
6	Pawer Grid Vishram Sadan	676.29
7	Canteen -1905	229.52
8	Midwifery Hostel	498.53
9	Nurses School	809.67
10	Nurses Hostel	2,727.00
11	Sanjha Chulha Near Ghandhi Ward	117.24
12	Forensic Department	220.00
13	Forensic Department Extension Building	575.92
14	Alumni Guest House	318.19
15	Central Store	272.78
16	Central Store Building -2	508.00
17	Electric Department	225.00
18	Plastic Surgery Department	1,217.00
19	Pediatic Surgery Department	363.37
20	Neurology Department	1,277.60
21	Private Word. (Paraplegia Ward)	968.09
22	General Surgery Department	1,764.78
23	Respiratory Extension Building	579.96
24	Rain Basera Near Respiratory Medicine Department	227.94
25	Isolation Ward	216.23
26	Environment Cell	261.00
27	Animals House	169.00
28	CT. Scan Centre	380.00
29	Old VL Hostel	821.69
30	UG & PG Girls Hostel	821.69
31	Chatra Vas	477.60
32	DK.Hostel	1,000.39
33	Psychiatry OPD.	546.65
34	Psychiatry Children OPD	842.25
35	Drug De- Addicition Store	274.00
36	VC. Residence	601.00
37	University Guest House	650.71
38	RH. Hostel	1,103.00
39	MCH. A- Block at QMH.	1,151.46
40	MCH. B- Block at QMH.	669.78
41	NCLRH. Hostel	452.93
42	New LRH. Hostel	306.67
43	Center for Excellence of Midwidwey Training in QMH.	785.06
Building OF RALC. & IDH. CAMPUS		
1	RALC. Main Building	3,145.85
2	RALC Building Near Petrol Pump	615.44
Building of TG. CAMPUS		
1	Multistory Teachers Flats	735.04
2	Multistory Boys Hostel	1,278.93
3	Mess/Gym	521.00
4	Naveen Boys Hostel	639.22
5	Dental Hygienist Hostel	367.95
6	Multistory Building (Type-II)	387.71
7	Faculty Residence Building -1	326.18
8	Faculty Residence Building -2	277.45

Induction Cooking in the Cooking Areas

The Energy Audit team surveyed the cooking areas such as canteens, Hostels of KGMU during 3rd week of August month and have the below information :-

S. No.	Name of Fooding Facility	FACILITY DETAILS			
		Type of Fuel	Type of food (Flame/ Steam based)	Number of cylinders/ units/ quantity of fuel	Total Annul LPG Cylenders
1	Divyang Ek Ummeed	Electricity	Tea & Snacks	Electricity Induction	0
2	M/S Mohini Caters Center	LPG, Electricity	Meal (Roti , Rice, Vegetables & Snacks	02 cylinder per day	720
3	CV Hall Mess	LPG	Meal	02 cylinders per day	720
4	Annapurna Kitchen	LPG cylinder & Electricity	Meal	01 cylinder per day	365
5	M/S Brijesh Singh	LPG & Electricity	Meal	2 cylinder per day	720
6	Patient Diet Kitchen (Central Kitchen) of M/s Jaiswal Canteen	LPG, Solar Thermal (CST)	Meal	02 cylinders when solar steam not generated or 01 cylinder when solar steam is used for cooking	500
7	Kitchen 1905	LPG	Meal	1.5-02 cylinders per day	540
8	Nitin Kapoor Cafeteria	LPG, Electricity	Meal	02-03 cylinders per day	750
9	Roti Making Facility	LPG	Meal	08 Cylinders per day	2880
10	Rajendra Kumar	LPG	Meal	0.5 cylinder per day	180
11	Shri Julfikar Hussain	Electricity	Tea & Snacks	Electricity Induction	0
12	Shri Sanjeet Kumar Tiwari	Electricity	Tea & Snacks	Electricity Induction	0
13	Shri Mohammed Nadeem	LPG & Electricity	Meal	25-30 cylinders per month	360
14	Shri Mohammed Amir	LPG & Electricity	Meal	30 cylinders per month	360
15	M/s Chai Canteen	LPG & Electricity	Meal	15-18 cylinders per month	450

The observations :-

1. The meal cooking facilities use LPG
2. The tea and snacks facilities do not use LPG
3. Electric based cooking is already in practice in tea and snacks facilities like Induction Plate, Sandwich Makers, Kettle, micro wave , electric hot case,etc.
4. Total LPG Cylinders are used annually 8545 numbers (approximately) of commercial cylinders, 19 kgs capacity each.
5. The big kitchens have apprehension about the utilisation and cost about using Electric / Induction Cooking



Fig . 1905 Kitchen & Patient Kitchen for Meals and Tea & Snacks joint

Recommendations :-

The commercial scale Induction cooking can be piloted in a particular cooking area which makes meals and the decision can be taken based on that experience.

District Cooling System

Introduction:

At present, air conditioning loads in the Hospital are met by on-site cooling technologies consisting of either window or room air conditioners or central chillers powered by the electricity grid. The efficiency and refrigerant consumption of on-site cooling equipment varies significantly depending on the product, building and cooling system design, operation and maintenance.

The overall energy and refrigerant use for air conditioning has a potential to have far lower if clusters of buildings and even whole KGMU is connected to a District Cooling System (DCS). Global experience and detailed analyses and existing projects in India show that these systems are also more reliable, cost-effective and could be highly beneficial.

Expected Benefits :-

1. Infrastructure benefits
 - a. Peak power demand reduction
 - b. Long-term grid balancing services
2. Environmental Benefits
 - a. Energy Efficiency can be better achieved
 - b. Climate change benefits
 - c. Water savings
 - d. Refrigerant savings
3. Besides there can be capital cost benefits for the individual systems and equipment as well as operating cost benefits

Working Principle :

DCS distributes (supplies and collects back) cooling energy in the form of chilled water from a central district cooling plant to multiple buildings through a distribution network of insulated, underground pipes for space and process cooling. Individual users purchase chilled water for their own building from the operator of the DCS and do not need to install their own chillers or cooling towers.




Figure 7: A schematic of typical district cooling systems
(source: emsd.gov.hk)

A DCS can be broadly divided into three parts:

- An air conditioning plant – generates chilled water for cooling purposes
- Distribution network (DN) – distributes chilled water to end users
- Energy transfer station (ETS) - interface with buildings' own air-conditioning systems




Figure 8: Key components of a typical district cooling system
(source: fujita-ec.com)

Feasibility of DCS in KGMU:

Although DCS is being used in various infrastructure projects but these are new projects. KGMU is an old installation and the Air Conditioning system is already in place. Considering this DCS may not be useful for the hospital.

Carbon Footprint and Sustainability Practices of the KGMU

A carbon footprint is a total greenhouse gas (GHG) emissions caused directly and indirectly by a person, organisation, event or product and is expressed as a Carbon Dioxide equivalent(CO₂-e).

The KGMU is highly conscious regarding the energy consumption within the campus. This is testimony to the fact that it has executed a number of energy efficiency as well as renewable energy projects to reduce the energy consumption as well as dependency on the fossil fuel based energy sources.

Some of the energy conservation and renewable energy measures as were executed: -

- The management replaces regular 250 W sodium lights with 120 W LED lights. Around 600 such LED lights installed for the indoor areas of the hospital, replacing the old 150 lights and addition of remaining 450 new lights. The team also replaces 12 High-mast lights of 850 W with those of 250 W lights, in the outdoor areas.
- installation of APFC panels for Power Factor improvement and thereby KVAh Consumption reduction
- use of Concentrated Solar Thermal system to provide steam for the cooking in lieu of LPG
- installation of Rooftop Solar PV power plants of 1370 kW

besides the above measures, the Hospital is also undertaking waste management and plantation activities.

The carbon footprint of the hospital is as below based on the present energy consumption :-

Items	Units / Yr	Quantity	Emission Factor	kg of CO ₂ e
Electricity Consumption	kWh	24626651	0.85	20932653.4
Petrol	Litres	0	2.296	0
Diesel	Litres	40610	2.653	107738.33
LPG	kg	168891	2.983	503801.853
Carbon Footprint (t CO ₂ e)			21544	
Carbon emission Per sqm			0.215	
Carbon Emission per bed			4.78	

There should be a regular effort to further improve on the carbon footprint as mentioned above. This is possible by undertaking various energy conservation and renewable energy measures as mentioned in various chapters in this report. Besides taking such measures, the hospital also need to undertake a regular maintenance of the already installed systems in operation for its best result expected.

Standard operating practices for efficient use of energy at KGMU.

Hospitals usually function 24 hrs per day all year round. It usually consists of large buildings and need to control the internal climate .

As per CMIE Prowess database Energy expenses in Hospitals is around 3-8 % of the total expenses ; 15-20% of the Hospital O&M expenses. So, Energy Efficiency is very important and this justifies the importance of having a Standard Operating Practices (SOP) for efficient usages of energy. The below steps can be followed in this regard:-

1. Need to find out energy consumption quantity (Electricity, Solar, DG, LPG) to find out different form of Energy Consumption
2. Energy saving approaches – to be undertaken wherever possible like
 - a. Switching off
 - b. Maintenance
 - c. Refurbishment
3. Thermal insulation to be checked on regular basis
4. Ventilation to be maintained as per the national building code , 2005
5. Lighting -sunshades and blinds are to be fitted on the affected windows
6. Benchmarking indicators are important and annual energy consumption per sq m of the campus area or annual energy consumption per inpatient bed in the hospital to be followed and there should be continuous effort to better the benchmark figs.
7. Energy Efficiency Opportunity
 - a. Space cooling and heating
 - i. Eliminating energy waste without compromising patient’s comfort
 - ii. Check Controls
 1. Thermostat is located where sunlight, draughts, radiators or equipment affect the reading
 2. Thermostat being set to minimum level
 3. It is important to ensure that the time settings are reviewed every month or so to check that they are correct

Try to keep external doors open only when absolutely necessary; during summer months open door allows cooled conditioned air to escape and hot air to enter. The thermostat then senses a temperature decrease and automatically switches on cooling which may be unnecessary. The same happens with heated air in winter months. Ac Curtains or Air Cutters are to be used where it is non existing and are to be made functional where it is installed. Where possible O2 sets of doors are also useful.

- iii. Keep systems clear and unobstructed

Need to make sure that the conditioned air is not obstructed by furniture or equipment and also keep filters clean. This ensures better circulation of air into the space and reduces the energy required to meet the cooling and heating demand.

iv. Need to take advantage of natural ventilation , it may be possible to use windows and doors to provide good level of natural ventilation in some areas within a Hospital ; allowing mechanical ventilation to be switched off or turned down to save energy

v. Maintain system components

Energy consumption in HVAC systems may increase substantially if regular maintenance is not undertaken . Dirty or faulty fans, air filters, air ducts and components directly affects system efficiency, running costs and risk of breakdowns. The performance of the whole system should be reviewed annually ; better to engage a maintenance specialist . In general, a chiller loses 2% of the refrigerant charge per annum. With better maintenance, usage of refrigerant leaks can be stopped.

vi. BLDC Fans can be used with fixed rpm for maximum energy savings ; improved fans energy consumption will be around 30 W per fan in lieu of 70-80 W per fan (Fiber body) and 100 W(Metallic Body) of the traditional fans . Traditional fans use Induction motors but improved fans use Brushless DC Motor (BLDC Motor) the later generate same or more air delivery with less energy consumption. The Hospital is using around 10000 traditional fans. A small percentage are BEE star rated; except those fans all are candidate for replacement which should happen phase-wise.

- Energy Savings Possible for 10000 fans is 1620000 units.
- Amount Savings Possible is Rs. 21870000/-
- Tentative Investment for 10000 fans is Rs. 2 Crores
- Tentative Payback is 11 months.

vii. Building Energy Management System may be used for better control of the energy consumption parameters where possible

8. Water saving Devices and practices are to be followed

9. Lighting

a. There should be Switch Off Policy based on the urgency of usages

b. Switching in parallel is another concept needs to be followed for Day lighting and Wire Lighting usage together

c. Occupancy / motion based sensors are to be used in appropriate places like bathroom lights, lobby light , office lights, etc.

- Power Savings potential is 50% .
- The tentative investmnet requirement is Rs.09/- per sq ft

10. Office and small power electrical equipment are to be turned off when not in use

11. Renewable energy and clean energy options are to be used in kitchens

12. Laundry is an extremely energy intensive area; solar hot water/steam usages and other energy efficiency measures are to be incorporated based on possibilities
13. Sterilization and Disinfection, Renewable Energy can be used wherever possible
14. An Energy Manager is to be nominated within the Hospital for leading all the initiatives
15. Energy Management Program is to be defined, agreed internally and followed