



किंग जार्ज चिकित्सा विश्वविद्यालय उ०प्र०, लखनऊ-226003

(विद्युत/यांत्रिक)विभाग,

गोंधी स्मारक एवं सम्बद्ध चिकित्सालय,

पत्रांक ..874....नोटिस/ई०ई०(ई०/एम०)/26

दिनांक.०९/०९/2026

Quotation Notice

The sealed Quotations are invited for Medical Gas Pipe line Work in Emergency Medicine at Trauma Center, KGMU Lucknow. The details of quotation can be seen at the Notice board of the office of undersigned. Interested parties may submit their quotations (For the purpose for estimated Cost of Work) to the office of undersigned by post or by hand duly marked on the envelope the number and date of this notice latest by dated.....14/09/26.....

Sr.No.	Description	Unit	Qty	Rate	Amount Without GST
1.	Supply, fixing testing and commissioning of Medical Grade Copper Pipe used should be half drawn, tapered seamless phosphorous Deoxidized non-arsenic and degreased confirming to latest BS: EN: 13348, LLOYD Certified, including casing conduct etc. of suitable size & quality for underground and Overhead pipes and all Accessories like bends, tees, reducers etc. (Complete in all respect.)				
a.	12 MM (OD) x 0.9 MM(thickness) (Make mexflow/Janya/mandev/Rajco)	Mtr	390		
b.	15 MM (OD) x 0.9 MM(thickness) (Make mexflow/Janya/mandev/Rajco)	Mtr	138		
c.	22 MM (OD) x 0.9 MM(thickness) (Make mexflow/Janya/mandev/Rajco)	Mtr	42		
2.	Supply, fixing testing and commissioning of Terminal Outlets gas specific for the services indicated (viz. O2, Air & Vacuum) and to accept only compatible quick connect Pin/Geometric Index type adapters as per ISO 7396 standard. Manufactured in compliance with CE and ISO 13485.				
a.	BS Type Oxygen Outlet with matching probe/adaptor. (Make Dragger/Aktiv/MR/Becon Medas/Altos/Mediequip)	Nos	64		
b.	BS Type Medical Air Outlet with matching probe/adaptor. (Make Dragger/Aktiv/MR/Becon Medas/Altos/Mediequip)	Nos	64		
c.	BS Type Vacuum Outlet with matching probe/adaptor. (Make Dragger/Aktiv/MR/Becon Medas/Altos/Mediequip)	Nos	64		
3.	The Bed Head Panel (size 2.5 fit or 750mm) shall be wall-mounted and fabricated using high-grade extruded aluminum profiles with a powder-coated finish, ensuring corrosion resistance and long-term durability. The panel shall be equipped with six (06) medical gas outlet points conforming strictly to BS Standard, color-coded as per HTM 02-01 / ISO 7396-1 guidelines.	Nos	32		



किंग जार्ज चिकित्सा विश्वविद्यालय उ0प्र0, लखनऊ-226003

(विद्युत/यांत्रिक)विभाग,

गोंधी स्मारक एवं सम्बद्ध चिकित्सालय,

पत्रांकनोटिस/ई0ई0(ई0/एम0)/26

दिनांक.....2026

4.	Supply, fixing, testing and commissioning of Gas lockable AVSU/CONTROL-CLOSING VALVE BOXES with integrated alarm system as required. Microprocessor based module. Digital LED display of "Normal", "High" & "Low". Digital pressure unit display options - psi/ bar or kg/cm2. Audio Mute option. 3 Gases AVSU	Nos	03		
5.	Supply, fixing, testing and commissioning of indigenous 12mm isolation valve.	Nos	192		
6.	Supply, fixing, testing and commissioning of Indigenous BPC Oxygen Flow Meter with Humidifier Bottle. (0-15L/Min)	Nos	32		
7.	Supply, fixing, testing and commissioning of indigenous Ward Vacuum unit with Vacuum Collection Jar size 600ml as per BS: EN: IS 10079-3 and CE marked.	Nos	32		
8.	Supply, Fixing, testing and Commissioning of Accessories shall include one (01) wall-mounted stainless steel utility basket for Suction Unit / Suction Jar. The complete assembly shall comply with HTM 02-01, ISO 7396-1, and IEC 60601 standards.	Nos	32		
				Gross Total	

Term & conditions

1. All the work shall be completed within the given time period as per work order.
2. G.S.T. paid as per applicable.
3. Quantity can be increase of Decrease as per requirements.
4. Conditional quotaion are liable to be rejected.
5. The undersigned reserves the right to reject quotations in part or whole without assigning any reason.

Yours faithfully

Executive Engineer(E/M)
King George's Medical University
Lucknow.

Section No.....Notice/E.E(E/M)/26 .of Date.....

Copy for information and necessary action to :-

1. Faculty incharge, Website Administration, Data Center , P.H.I Bhawan, KGMU for uploading the Quotation Notice in KGMU. Website from Date 09/09/26 to 14/09/26

Executive Engineer(E/M)
King George's Medical University